

ADDENDUM

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. ONE

PROJECT TITLE: Bradley Park Service
Building Roof Replacement

ISSUANCE DATE: May 9, 2012

The proposed Contract Documents for this Work are modified as follows:

I. **DRAWINGS:**

1. **R-1 ROOF PLAN** Delete all references to the replacement of the four metal roofs using Kynar Coated Steel. See Section 073113, Subsection 2.09 below.

II. **PROJECT MANUAL/SPECIFICATIONS/GENERAL CONDITIONS/ETC.:**

1. **SECTION 073113
LAMINATED ASPHALT SHINGLES
PART 2: PRODUCTS**

Add the following subsections:

2.08 FIBER CEMENT SIDING

A. Provide siding products from one of the following manufacturers:

1. James Hardie Building Products, Inc., which is located at: 26300 Alameda, Suite 400, Mission Viego, CA 92691, toll free 866-274-3464, telephone 949-367-4980, www.jameshardiccommercial.com.
2. CertainTeed Corporation, Siding Products Group, P.O. Box 860, Valley Forge, Pennsylvania 19482. telephone 800-233-8990 (professional) or 800-782-8777 (consumer). www.certainteed.com.

B. For all vertical wall surfaces on the sides of both louvered vents and both dormers, remove the existing asphalt shingles and replace with one of the following products:

1. Lap Siding: Hardie Plank HZ5 7 ¼" Pre-finished lap siding. Type: Select Cedarmill C+ Wood Grain as manufactured by James Hardie Building Products, Inc. Color shall be "Navajo Beige."
2. Lap Siding: Weatherboards siding 7 ¼" Pre-finished lap siding. Type: Colormax Prefinished Cedar Lap, Wood Grain, as manufactured by Certainteed Corporation. Color shall be "Linen."

2.09 METAL ROOF COATING

A. Provide coating product from the following manufacturer:

1. The Garland Company, 3800 East 91st Street, Cleveland, Ohio 44105
Telephone: (800) 762-8225 Website: www.garlandco.com
Local Contact: Brad Davis Phone: 309-258-3874 Fax: 309-387-6497
E-Mail: BDavis@garlandind.com

B. Single Component Aliphatic Urethane Liquid Waterproofing Membrane

1. White-Knight Plus: A multi-purpose, high build, urethane, liquid waterproofing membrane designed to maintain, restore and upgrade the performance of existing profiled metal sheet.
 - a. Elongation (ASTM D 412) 320%
 - b. Tensile Strength (ASTM D 412) 2100 psi (with no reinforcement)
 - c. Tear Resistance (ASTM D 624) 160 lbs/in.
 - d. CRRC Approved Product
 - e. Flash Point 110°F
 - f. Non-Volatile (ASTM D 75) 83%
 - g. Solar Reflective Index (ASTM E 1980) 110
2. The four small metal roofs shall be pressure washed, scrubbed with TSP, thoroughly rinsed and allowed to dry. Apply two (2) coats of Garland White-Knight to all exposed metal surfaces. Allow 24-48 hours dry time between coats.

III. **INVITATION TO BID:**
No change