

ADDENDUM

Peoria Park District
Bradley Park Equipment Service Center
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. TWO

PROJECT TITLE: Family Restroom at
Green Valley Camp

ISSUANCE DATE: November 9, 2012

The proposed Contract Documents for this Work are modified as follows:

I. DRAWINGS: No change

II. PROJECT MANUAL/SPECIFICATIONS/GENERAL CONDITIONS/ETC.:

Section 23 00 00 Heating, Ventilating, and Air Conditioning, Part 2-Products, Paragraph 2.2:
Change wording "sized for two standard cinder block width" to "sized for six standard bricks – 16-3/8"
wide, by 7-1/2" tall with a free area of .30 Sq. Ft." The model number listed is correct. "Or equal"
products are acceptable.

III. INVITATION TO BID: No change

END OF ADDENDUM NO. TWO