

ADDENDUM

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. 1

PROJECT TITLE: Luthy Botanical Garden
Conservatory Vent Repairs

ISSUANCE DATE: April 26, 2012

LOCATION: Luthy Botanical Garden

The proposed Contract Documents for this Work are modified as follows:

I. **DRAWINGS:**

No Change

II. **PROJECT MANUAL/SPECIFICATIONS/GENERAL CONDITIONS/ETC.:**

Proposal Documents, ARTICLE III, **ADD** 3.1.1.3: "Lowest responsible bidder not meeting the Park District's goal of 12% for minority/women participation, must provide proof of efforts made in contacting an adequate number of minority and women owned firms and/or labor. "

Proposal Documents, ARTICLE IX, **DELETE** "B. Add Alternate #2: Add four new energy curtains, including installation and set-up with new controller."

Proposal Documents, Proposal Form, 6. Alternates, **DELETE** "B. Add Alternate #2: Add four new energy curtains, including installation and set-up with new controller."

Division 020000, Design Program, Design Scope, to the following text, "To avoid this problem in the future, the mercury switches will be replaced," **ADD** the following, "with Internal Limit Switch."

Division 020000, Design Program, Design Scope: Clarification: The new controller will only be responsible for operating the vent system at this time. However, it should have the capacity to operate other equipment in the future, including but not limited to shade systems, fans and lights.

Division 020000, Design Program, Design Scope: Clarification: All wiring is to be included in proposal cost. Wiring shall be in 3/4" metal conduit.

Division 020000, Design Program, Alternates, Add Alternate 1, **ADD** the following: "Garden Manager's computer operating system is Windows XP."

Division 020000, Design Program, Alternates, Add Alternate 2, **DELETE** this alternate.

III. **INVITATION TO BID:**

No Change

END OF ADDENDUM NO. 1

Addendum No. 1