

ADDENDUM

Peoria Park District
Bradley Park Equipment Service Center
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. ONE

PROJECT TITLE: District Wide Above Ground
Storage Tanks

ISSUANCE DATE: July 31, 2014

LOCATION: Addendum applies to all tank locations

The proposed Contract Documents for this Work are modified as follows:

I. DRAWINGS:
No Change

II. PROJECT MANUAL/SPECIFICATIONS/GENERAL CONDITIONS/ETC.:

SUPPLEMENTARY INSTRUCTIONS TO BIDDERS, 2. PROJECT DESCRIPTION, 1. BASE BID:
Change "Install new accessories where needed." to "Install new accessories."

SECTION 231323, PART 2 – PRODUCTS, 2.03 MATERIAL, A. Bradley Park Equipment Service:
Change "2. Tank Capacity: 2,500 Gallons" to "2. Tank Capacity: 2,000 Gallons".

SECTION 231323, PART 2 – PRODUCTS, 2.03 MATERIAL, F. Tank Connections and Openings:
Add "Provide and Install all new accessories. Accessories include: Emergency Vents, Pressure Vacuum Vents, Fill Caps, Mechanical Level Gauge, and Mechanical Leak Gauge. Existing Pumps and keytrolls shall be removed and reconnected to new tanks.

Acceptable Accessories:

- A. Morrison Bros 818 Series Clock Gauge
- B. Morrison Bros 178 Series 2" Threaded Style Fill Cap
- C. Morrison Bros 748 Series 2" Pressure/Vacuum Vent
- D. Morrison Bros 244 Series 4" Emergency Vent
- E. Morrison Bros 244 Series 6" Emergency Vent
- F. Equals: Only as approved by Owner"

SECTION 231323, PART 3 – EXECUTION, 3.01 INSTALLATION: Add "C: Removal and proper disposal of existing tanks from Peoria Park District property shall be the responsibility of the contractor installing the new tanks."

III. INVITATION TO BID:
No Change

END OF ADDENDUM NO. ONE