

## ADDENDUM

Peoria Park District  
Planning, Design and Construction Department  
1314 N. Park Road  
Peoria, IL 61604  
Telephone: (309) 686-3386

ADDENDUM NO. ONE  
PROJECT TITLE: Roof Replacement  
Forest Park Nature  
Center

ISSUANCE DATE: October 4, 2018

LOCATION: Forest Park Nature Center

The proposed Contract Documents for this Work are modified as follows:

I. **DRAWINGS:**

Add Addendum 1 drawing as attached. Drawing addresses crickets, removal of 8" flue, and raising of soil vent pipe.

II. **PROJECT MANUAL/SPECIFICATIONS/GENERAL CONDITIONS/ETC.:**

SECTION 07 54 23, Paragraph 2.1 A: TPO membrane by Mule-Hide is acceptable as long as it meets performance criteria listed in the specifications.

SECTION 07 54 23, Delete Paragraphs 2.2 E and 2.2 F with references to Energy Star listings and solar reflectance index. The membrane specified is gray, which does not conform to these standards.

III. **INVITATION TO BID:** NONE

ADD CRICKET, TAPER INSULATION AND ROOF TO DRAIN, ELIMINATE GUTTER

NEW GUTTER

STRIPS OF WOOD TO BE INSTALLED TO PROVIDE A SLOPE FOR DRAINAGE. FLASH PER LOCAL CODE. INSTALL 30# COPPER FLASHINGS.

NEW GUTTER

REMOVE EXISTING 8" CAPPED FLUE. PATCH W/ PLYWOOD AT DECK.

TAPERED INSULATION SLOPE 1/8" PER 1"

TAPERED INSULATION AT 4.25" THICKNESS ON HIGH (SHAKE) SIDE; 0.5" THICKNESS AT GUTTER

REMOVE EXISTING ROOF AND FLASHINGS.

RAISE VENT STACK AS NEEDED. COVER WITH LEAD OR PREMADE MEMBRANE COMPATIBLE UNIT.

REMOVE EXISTING GUTTER, FLASHINGS, AND FLASHINGS.

NEW GUTTER

ADD CRICKET, TAPER INSULATION AND ROOF TO DRAIN, ELIMINATE GUTTER

REMOVE EXISTING INSULATION AND FLASHINGS. ADHERE 60 MIL POLYESTER MEMBRANE TO DECK AND FLASHINGS. SEE LOCAL CODES FOR ANY REQ'S.

CONC. WALK


# ADDENDUM #1

## BIRD WING ROOF at: FOREST PK. NATURE CENTER

PLEASURE DRIVEWAY AND PARK DISTRICT OF PEORIA, ILLINOIS



### ROOF PLAN



NORTH

DRAWN BY:  
MJF

SCALE:  
1"=10'

DATE:  
9/25/2018

SHEET:  
1 of 2