

ADDENDUM

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. ONE
PROJECT TITLE: Barn Roof
Tawny Oaks
Field Station

ISSUANCE DATE: October 24, 2018

LOCATION: Tawny Oaks Field Station

The proposed Contract Documents for this Work are modified as follows:

I. **DRAWINGS**: NONE

II. **PROJECT MANUAL/SPECIFICATIONS/GENERAL CONDITIONS/ETC.:**

Project shall also include the replacement of the gutter. New gutter shall be 10" deep by 10" wide, 20 ga. (0.04 inch) thick Kynar coated aluminum. Provide new aluminum downspout to match existing. Re-use and re-attach aluminum splash guards at low points. Seal joints as necessary to provide watertight function. Slope to drain at 1/4" per foot.

Note: drip edge under shake roof may not be currently present. A new drip edge shall be required at all shake/shingle roof edges.

III. **INVITATION TO BID**: NONE

--END OF ADDENDUM #1--