

ADDENDUM

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. **ONE**
PROJECT TITLE: Columbia Park Playground
Resurfacing

ISSUANCE DATE: October 9, 2019

The proposed Contract Documents for this Work are modified as follows:

I. **DRAWINGS:**

- The assumed fall-height is 72". This will apply to the entire area of poured-in-place surfacing. The surfacing thickness will remain constant across the entire area.

II. **PROJECT MANUAL/SPECIFICATIONS/GENERAL CONDITIONS/ETC.:**

The following products have been examined and shall be considered "or equal" to the basis of design product for the playground surfacing:

- Vitriturf poured-in-place
- Playbound poured-in-place
- GT Impax poured-in-place
- No-Fault poured-in-place

III. **INVITATION TO BID:** None

END OF ADDENDUM NO. **ONE**