

ADDENDUM

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. **THREE**
PROJECT TITLE: Columbia Park Playground
Resurfacing

ISSUANCE DATE: October 14, 2019

The proposed Contract Documents for this Work are modified as follows:

I. **DRAWINGS**: None

II. **PROJECT MANUAL/SPECIFICATIONS/GENERAL CONDITIONS/ETC.:**

Questions from planholders:

1. *Is the Park District going to put up fencing to secure the area?*

No. All fencing and site protection is up to the contractor.

2. *Do you want Site restoration included (seed and straw)?*

No. Site restoration will be by the Park District, with the exception that any ruts created by the contractor need to be graded smooth.

3. *You mentioned that there was compacted stone under the current tile.*

3. Yes. Additional compacted stone and compaction adjacent the curbing is up to the contractor. You should assume that some additional material and compaction would be required at the edges where the new curbing is to go in, and that the field will need to be re-compacted after removing the existing tile. After the existing rubber tile is removed and the gravel recompact, if any low spots are identified that need to be filled, that would be handled by change order. The current rubber tiles are 2-1/2" thick, the same as the new surfacing to go in, and no current bird baths/low spots have been identified, so we are hoping these areas will be minimal.

III. **INVITATION TO BID**: None

END OF ADDENDUM NO. **THREE**