

ADDENDUM ONE

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. 1
PROJECT TITLE: Lodge Kitchen
Exhaust Hood
Peoria Zoo

ISSUANCE DATE: 3/26/21

LOCATION: Peoria Zoo, Glen Oak Park

The proposed Contract Documents for this Work are modified as follows:

I. **GENERAL INFORMATION:**

N/A

II. **DRAWINGS:**

N/A

III. **PROJECT MANUAL/SPECIFICATIONS:**

DIVISION 020000 GENERAL SCOPE: add the following:

Owner will relocate existing water lines and plumbing vents above ceiling as needed to eliminate conflicts with new exhaust hood and ductwork.

Contractor shall be responsible for relocating any sprinkler heads and sprinkler piping that will conflict with the new exhaust hood.

Contractor shall disconnect existing light fixtures that conflict with new exhaust hood and turn them over to Owner. Owner will re-install where appropriate.

Power needed for the new exhaust hood shall come from new electrical panel on north side of room.

Owner will run new 2" gas main from mechanical room to new exhaust hood. Owner will provide and install an ANSUL valve. Contractor shall connect to the line above the ceiling and take it up through the roof.

Owner will provide stainless steel wall protection below new exhaust hood.

IV. **INVITATION TO BID:**

N/A

END OF ADDENDUM NO. 1

(Addendum may be bound into Project Manual, attached to front cover, faxed, mailed, emailed or delivered to bidders.)