

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. 01

PROJECT TITLE: Roof Replacement

ISSUANCE DATE: 4.07.22

LOCATION: Kellogg Golf Course Service Building

The proposed Contract Documents for this Work are modified as follows:

I. GENERAL ITEMS / CLARIFICATIONS:

1. Bid date and time has not changed.
2. Reminder that this project is a Prevailing Wage Project.
3. Substitution requests shall be submitted to Planning Department for review and approval, a minimum of 72 hours before bid date and time in order to be considered for use on the project.

II. DRAWINGS:

1. Reference RF-1
 - a. Contractor shall add (provide) 8 total manufactured aluminum gravity vents for the 2 upper sections of roof – 4 on each. Contractor shall provide in base bid costs associated for labor and materials to cut in all 8 new gravity vents into existing sheathing and flashed in accordingly. Exact locations will be coordinated with awarded contractor.

III. PROJECT MANUAL:

1. Reference Section 073113 – Asphalt shingles
 - a. Locate 2.1.A.1. and change “Landmark TL” to “Landmark Pro”
 - b. Locate 2.1.A.2. and change “As selected by Architect” to “As selected by Owner’s Representative”
 - c. Locate 2.2.A.: Add the words as follows: “or Owen’s Corning Deck Defense”
 - d. Locate 2.3: Delete this paragraph for ridge vents. Ridge Vents are not required for this project.

END OF ADDENDUM NO. 01

(