

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. 01

PROJECT TITLE: Boardwalk Repairs and
Resurfacing – Peoria Zoo #20-028

ISSUANCE DATE: 10.26.22

LOCATION: Peoria Zoo

The proposed Contract Documents for this Work are modified as follows:

I. GENERAL ITEMS / CLARIFICATIONS:

1. Bid date and time has not changed.
2. Reminder that this project is a Prevailing Wage Project.
3. Timber joist hangers will be provided by the owner and contractor installed. Contractor will not need to include the material cost for the hangers, but labor for the install of those called out on the drawings shall be included in his / her bid.
4. Contractor shall temporarily remove all miscellaneous boardwalk mounted signage throughout for the removal and installation of the new timbers and / or HDPE plastic decking. Reinstall signage when decking has been replaced in that area.
5. Contractor shall include cutting or drilling holes of timber boards and / or HPDE plastic decking around all miscellaneous electrical conduits throughout the areas for replacement. These locations are random and vary by location throughout. The conduits may also require disconnection and reconnection including but not limited to removal and reinstallation of components for the new deck boards to match the current condition.
6. All new timber wood board decking shall be kiln dried in order to meet the 19% max. moisture content.

II. PROJECT MANUAL:

1. Reference Supplementary Instructions to Bidders:
 - a. See Page 5 - 2. PROJECT DESCRIPTION: A.1.B.: Add the following to Base Bid 2: “Contractor shall provide staining of all new wood timber boards as part of Base Bid 2.”
 - b. See Page 7 – 12. CONSTRUCTION TIME AND LIQUIDATED DAMAGES CLAUSE: 2.5.1.2): Change the date of April 28, 2022 to read April 28, 2023.

II. DRAWINGS:

1. Sheet A1:
 - a. Reference Detail 3/A1 – See Stainless Steel Screw note.
 1. Change the wording from “4” long screws” to “5” long screws”
 - b. Add the following note below to end of Stainless Steel Screw Note:
 1. See specification sections Exterior Rough Carpentry and HDPE Plastic Decking for specifics on exact fastener types. .
 - c. Reference Legend Key “Base Bid 2” and add the following note to the end of paragraph for base bid 2: “Contractor shall provide / include staining of all new wood timber boards as part of Base Bid 2”

END OF ADDENDUM NO. 01