

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. 01

PROJECT TITLE: Roof Coating -Riverplex

ISSUANCE DATE: 03.09.23

LOCATION: Riverplex Recreation Center - Project# 23-041

The proposed Contract Documents for this Work are modified as follows:

I. GENERAL ITEMS / CLARIFICATIONS:

1. The roofing contractor shall provide in his / her bid to apply acetone by pump spraying method to all **previously** coated roofing. It shall be applied after all cleaning has taken place. The intent for the acetone is for proper adhesion of the new roof coating specified. Apply with a handheld pump sprayer in strict accordance with the roof coating manufacturer's representative's instructions. Do not apply acetone to any roofing that is not already coated (original black EPDM).
2. Bid date and time has not been changed.
3. Reminder that this project is a prevailing wage project.

END OF ADDENDUM NO. 01
This Addendum consists of 1 typed page