

ADDENDUM

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. TWO
PROJECT TITLE: STRUCTURAL
CONCRETE REPAIRS

ISSUANCE DATE: April 10, 2025

LOCATION: CENTRAL PARK POOL

The proposed Contract Documents for this Work are modified as follows:

I. **GENERAL INFORMATION:**

A. At new steel beam location, existing pipe, pipe supports, electrical and electrical conduit will need to be temporarily disconnected and later reconnected by Contractor. Any pipe supports or threaded rod hangers that need to be cut in order for work to take place shall be replaced with new Unistrut pipe supports by Contractor. Picture of new steel beam location is attached.

B. Remove existing pipe hangers at repair locations and provide new pipe hangers necessary to facilitate repairs.

II. **DRAWINGS:**

III. **PROJECT MANUAL/TABLE OF CONTENTS/PROJECT SPECIFICATIONS:**

IV. **INVITATION TO BID:**

END OF ADDENDUM NO. TWO

(Addendum may be bound into Project Manual, attached to front cover, faxed, mailed, emailed or delivered to bidders.)

