

ADDENDUM

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO: 1
PROJECT TITLE: Boiler Replacement

ISSUANCE DATE: August 29, 2025
LOCATION: Luthy Botanical Garden

The proposed Contract Documents for this Work are modified as follows:

I. GENERAL INFORMATION:

Clarification from the pre-bid meeting held on Tuesday, August 26, 2025 at 10:00 am:

1. Condensate pump: Do not replace, connect to existing.
2. Pneumatic control valves: Do not replace, connect to existing.

II. DRAWINGS:

Delete from under NEW BOILER REPLACEMENT:

“PROVIDE, INSTALL AND CONNECT NEW PIPING (INCL. GAS, STEAM, AND CONDENSATE) AS REQUIRED. EXISTING PIPING THAT IS RUST-FREE AND IN GOOD CONDITION MAY BE RE-USED AS APPROPRIATE.”

Replace with:

“PROVIDE, INSTALL AND CONNECT NEW PIPING (INCL. GAS, STEAM, AND CONDENSATE) AS REQUIRED TO CONNECT NEW ITEMS TO EXISTING PIPING SYSTEMS. ASSUME EXISTING PIPING CAN BE RE-USED.”

III. PROJECT MANUAL/SPECIFICATIONS: N/A

IV. INVITATION TO BID: N/A

END OF ADDENDUM NO. 1