

A PROJECT OF THE  
PEORIA PARK DISTRICT  
PEORIA, ILLINOIS

**IRRIGATION IMPROVEMENT  
NEWMAN GOLF COURSE  
2021 W NEBRASKA AVE  
PEORIA, ILLINOIS**



PROJECT # 24-027  
NOVEMBER 18, 2025

PROJECT MANUAL

PACKAGE # \_\_\_\_\_

PROJECT MANUAL INCLUDING SPECIFICATIONS FOR:

**IRRIGATION IMPROVEMENT  
NEWMAN GOLF COURSE  
201 W NEBRASKA AVE  
PEORIA, ILLINOIS**

**ARCHITECT:** EC DESIGN GROUP, LTD.  
ATTN: PETE CHRISTIANSEN  
400 5<sup>TH</sup> STREET  
WEST DES MOINES, IOWA 50265  
TELEPHONE: (515)225-6365

---

**OWNER:** PLEASURE DRIVEWAY AND PARK DISTRICT OF PEORIA,  
PEORIA, ILLINOIS

**TRUSTEES:** ROBERT L. JOHNSON, SR., PRESIDENT  
RON SILVER  
STEVE MONTEZ  
MARK SLOVER  
JOYCE HARANT  
REAGAN LESLIE HILL  
ALEX SIERRA

**PROJECT MANAGER:** DAVID VOORHEES  
PLANNING, DESIGN & CONSTRUCTION DIVISION  
BRADLEY PARK EQUIPMENT SERVICE  
1314 N. PARK ROAD  
PEORIA, ILLINOIS 61604  
TELEPHONE: (309) 678-0560

**ADMINISTRATIVE STAFF:** EMILY CAHILL, EXECUTIVE DIRECTOR  
MATT FREEMAN, SUPERINTENDENT OF PARKS  
KARRIE ROSS, SUPERINTENDENT OF FINANCE  
AND ADMINISTRATIVE SERVICES  
BECKY FREDRICKSON, SUPERINTENDENT OF PLANNING,  
DESIGN AND CONSTRUCTION  
SHALESSE PIE, SUPERINTENDENT OF HUMAN  
RESOURCES  
SCOTT LOFTUS, SUPERINTENDENT OF RECREATION

\*\*\*\*\*

Address all communications regarding this work to the Project Manager listed above.

**ADVERTISEMENT FOR BIDS**

Sealed bids will be received by the Peoria Park District, Peoria, Illinois, hereinafter known as the Owner, for the following project:

IRRIGATION IMPROVEMENT  
NEWMAN GOLF COURSE  
2021 W NEBRASKA AVE PEORIA, ILLINOIS

It is the intent of the Owner to receive Base Bids & Alternates for the project listed above.

Sealed bids will be received until Tuesday, December 2, 2025 at 1:15 pm prevailing time, by the Owner, at the Peoria Park District Administrative Office, 1125 W. Lake Ave., Peoria, Illinois 61614. (The Board Room clock shall be the official time keeping device in respect to the bid submission deadline.)

An electronic file including Bid Documents is available at [www.peoriaparks-planning.org](http://www.peoriaparks-planning.org) at no charge. Bid Documents, including Plans, Specifications and Interpretations for this project may be obtained at the Planning, Design & Construction Department, Bradley Park Equipment Service, 1314 N. Park Road, Peoria, IL 61604. Telephone (309) 686-3386. A non-refundable plan deposit of three hundred dollars (\$300.00) will be charged for each printed set of Bid Documents.

A list of planholders can be obtained upon request. This information will be available up to twenty-four (24) hours prior to the scheduled bid opening time. **After that deadline, no information pertaining to the project will be given.**

A 10% Bid Bond is required, and is to be included with the Bid Proposal. The successful Bidder will be required to furnish a 100% Performance Bond and a 100% Labor and Materials Payment Bond within ten (10) days of formal Award of Contract.

The general prevailing rate of wage for the Peoria area shall be paid for each craft or type of worker needed to execute this contract or perform this work as required by the State of Illinois Department of Labor. Additionally, it is required that provisions of the Illinois Preference Act, the Illinois Drug Free Workplace Act, and the Substance Abuse Prevention on Public Works Act must be adhered to. Bidders are also advised that contract documents for this project include the non-discrimination, equal opportunity and affirmative action provisions in the Human Rights Act and rules and regulations of the Department of Human Rights. The Peoria Park District is an AA/EEO organization and encourages participation by minority and female-owned firms.

The Peoria Park District reserves the right to reject any or all bids, waive technical deficiencies, informalities or irregularities or rebid any project.

PLEASURE DRIVEWAY AND PARK DISTRICT  
OF PEORIA, ILLINOIS

BY: ROBERT L. JOHNSON, SR., President

BY: ALICIA WOODWORTH, Secretary

**TABLE OF CONTENTS**

TITLE PAGE(S)	1-2
INVITATION TO BID	3
TABLE OF CONTENTS	4
BIDDING DOCUMENTS:	
- SUPPLEMENTARY INSTRUCTIONS TO BIDDERS	5-9
- BID FORM(S)	10-15
- SUBCONTRACTORS LIST	16
- CERTIFICATION OF COMPLIANCE OF LISTED PROVISIONS AND LAWS	17
- W-9	18-23
- SEXUAL HARASSMENT POLICY STATEMENT	24
- SAMPLE ADDENDUM FORM	25
CONTRACT DOCUMENTS:	
- AGREEMENT BETWEEN OWNER AND CONTRACTOR	26-30
- PERFORMANCE BOND	31-32
- LABOR & MATERIALS PAYMENT BOND	33-34
- CONTRACTOR'S AFFIDAVIT	35
- LIEN WAIVER FORMS	36-39
- SUPPLEMENTAL GENERAL CONDITIONS	40-56
PROJECT SPECIFICATIONS:	
GENERAL REQUIREMENTS:	
<u>DIVISION 010000: GENERAL REQUIREMENTS</u>	57-68
TECHNICAL SPECIFICATIONS:	
<u>GENERAL IRRIGATION CONDITIONS</u>	69-72
<u>IRRIGATION SYSTEM</u>	73-82
<u>EXECUTION</u>	83-86
<u>ELECTRICAL</u>	87-90
EXHIBITS:	
ATTACHMENT A - INSURANCE REQUIREMENTS	5 PAGES
ATTACHMENT B – SOLICITATION & HIRING FOR QUALIFYING CONSTRUCTION CONTRACTS POLICY & FORMS	21 PAGES
ATTACHMENT C – DIRECTORY OF MINORITY & WOMEN OWNED BUSINESS ENTERPRISES	5 PAGES
ATTACHMENT D – PREVAILING WAGES FOR PEORIA COUNTY – ILLINOIS DEPARTMENT OF LABOR	6 PAGES
DRAWINGS:	
COVER	LI-0
IMPACT COVERAGE PLAN	LI-1
HYDRAULIC PIPING PLAN	LI-2
ELECTRICAL SCHEMATIC PLAN	LI-3
SITE IRRIGATION PLAN	LI-4
IRRIGATION DETAILS	LI-5
EXISTING IRRIGATION DRAWINGS	LI-6

END OF TABLE OF CONTENTS

# SUPPLEMENTARY INSTRUCTIONS TO BIDDERS

## 1. INSTRUCTIONS TO BIDDERS

- A. "Instructions to Bidders", AIA Document A701, 2018 Editions, published by the American Institute of Architects, including revisions adopted before date of this Project Manual, is hereby made part of these specifications with same force and effect as though set forth in full.
- B. The following modifies, changes, deletes from or adds to the **Instructions to Bidders** (AIA Document A701, 2018 Edition). Where any Article of the Instructions to Bidders is modified or any Paragraph, Subparagraph or Clause thereof is modified or deleted by these Supplementary Conditions, the unaltered provisions of that Article, Paragraph, Subparagraph or Clause shall remain in effect.
- C. Parenthesis ( ) indicates the appropriate section and Subparagraph of the Instructions to Bidders which each paragraph of the Supplementary Instructions to Bidders modifies or refers to.

## 2. PROJECT DESCRIPTION

- A. The Project description generally is as follows:
  - 1. **BASE BID:**

The project work includes but is not limited to all labor, materials and equipment needed to upgrade the existing irrigation system. This includes removing existing components and installing a new system with HDPE mains, laterals, and necessary fittings; and expanding the existing satellite-based control system.
  - 2. **ADD ALTERNATE #1:**

Alternate scope of work shall include; Irrigation mainlines, laterals, irrigation controls, and irrigation components for holes #7 and #8 as outlined in the Newman Golf Course Drawings.
  - 3. **ADD ALTERNATE #2:**

Alternate scope of work shall include; Irrigation mainlines, laterals, irrigation controls, and irrigation components for hole #6 as outlined in the Newman Golf Course Drawings.
  - 4. **ADD ALTERNATE #3:**

Alternate scope of work shall include; Irrigation mainlines, laterals, irrigation controls, and irrigation components for holes #4 and #5 as outlined in the Newman Golf Course Drawings.
  - 5. **ADD/DELETE ALTERNATE #4:**

Removal of existing irrigation equipment.
- B. **PRE-BID MEETING :**
  - 1. A pre-bid meeting will be held virtually on November 25, 2025 at 1:00 pm. All plan holders will receive virtual invite from EC Design. Any pre-bid site visits may be done at your convenience.

## 3. ALLOWANCES

N/A

## 4. CODES AND PERMITS

- A. **COSTS ASSOCIATED WITH REGULATORY COMPLIANCE.** All Work performed in connection with this Project shall be in compliance with the requirements of all applicable local, state, and federal laws, regulations, and rules, as well as the requirements of the Construction Documents. The Bid Price shall reflect all costs of compliance to those requirements, whether or not specifically stated in the Construction Documents or specific sections of the Project Manual.
- B. **PERMITS/FEES.** Work shall not commence until all required building (and/or other) permits have been secured by the Contractor and copies of these permits submitted to the Owner's Representative. Cost of permits is to be included in the Bid Price.

## 5. BID GUARANTY

The bid must be accompanied by a Bid Guaranty which shall not be less than 10% of the amount of the Bid. At the option of the Bidder, the 10% Guaranty may be a Certified Check, Cashier's Check, or a Bid Bond. The Bid Bond shall be secured by a Guaranty or a Surety Company acceptable to the Owner. No bid will be considered unless it is accompanied by the required Guaranty. Funds must be made payable to the order of the Owner. Cash deposits will not be accepted. The Bid Guaranty shall ensure the execution of the Agreement and the furnishing of the Surety Bond or Bonds by the successful Bidder, all as required by the Contract Documents.

## 6. AWARD OF CONTRACT/REJECTION OF BIDS:

The Contracts will be awarded on the basis of Paragraph 5.3 of the Instructions to Bidders and Paragraph 16 of the Supplementary Instructions to Bidders. The Bidders to whom the awards are made will be notified at the earliest possible date. The Owner, however, reserves the right to reject any and all Bids, to accept any combination of base bids and alternates and to waive any technical deficiencies, informalities, or irregularities in Bids received whenever such rejection or waiver is in its interest.

No bid shall be withdrawn for a period of sixty (60) days after the opening of bids without the consent of the Owner. The failure of the Bidder to submit a Bid Bond, Certified Check or Cashier's Check in the full amount to cover all proposals bid upon shall be sufficient cause for rejection of his bid. The award will be made contingent upon submittal and evaluation of Contractor's Qualification Statement if requested, Bonds, Certificate of Insurance, Contractor Certifications, including Certification of Compliance of Listed Provisions and Laws, Peoria Park District Certificate of Equal Employment Opportunity Compliance for Contractors and Vendors, Workforce Profile, Company Ownership Certification, Minority/Women Owned Contact Sheet, Contractor/Subcontractor Workforce Plan, etc.

#### **7. EXECUTION OF AGREEMENT:**

Following the award and within ten (10) days after the prescribed forms are prepared and presented for signature by the Owner's Representative, the successful Bidder shall execute and return to the Owner's Representative the Agreement in the form included in the Contract Documents in such number of copies as the Owner may require. The Owner's Representative will provide Notice to Proceed after all bonds and any other required documents have been received by the Park District.

#### **8. PERFORMANCE BOND/LABOR AND MATERIAL PAYMENT BOND & INSURANCE**

- A. BONDS REQUIRED.** Having satisfied all conditions of award as set forth elsewhere in these Documents, the successful Bidder shall, within ten (10) calendar days after award of contract, furnish Surety Bonds in penal sums, each not less than the amount of the Contract as awarded as security for the faithful performance of the Contract (Performance Bond), and for the payment (Labor and Materials Payment Bond) of all persons, firms or corporations to whom the Contractor may become legally indebted for labor, materials, tools, equipment or services employed or used by him in performing the work.
- B. FORM OF BONDS.** Such bonds shall be in the same form as the samples included in the Project Manual and shall bear the same date as or a date subsequent to that of the Agreement. The current Power of Attorney for the person who signs for any Surety Company shall be attached to such Bonds. Bonds shall be signed by a Guaranty or Surety Company acceptable to the Owner.
- C. COST OF PERFORMANCE BOND/LABOR AND MATERIAL PAYMENT BOND.** All costs for the Performance Bond/Labor and Material Payment Bond shall be included in the submitted Bid Price.
- D. INSURANCE.** Insurance requirements for this project are addressed both in the Supplementary General Conditions and in "Attachment A.6 in the "Exhibits" section of this Project Manual.
- a) In respect to the property ("builders risk") insurance coverages referenced in the Supplementary General Conditions: the successful Bidder will be required to provide such coverages as the work of the Project will be accomplished by one general contractor(s).
- E. TIME FRAMES.** The successful Bidder shall, within ten (10) days after award of contract by the Board of Trustees, submit Proof of Insurance coverages/Bonds in the form and amounts required to the Owner's Representative. Should the Bidder be unable to provide the required Proof of Insurance(s)/Bonds within the specified ten day period the Owner reserves the right, at its sole discretion, to withdraw its award of contract from that Bidder.

#### **9. DEFAULT**

- A.** The failure of the successful Bidders to execute the Agreement, supply the required Bonds or proof of required insurance coverage(s) within (ten) 10 days after award of contract, or within such extended period as the Owner may grant based upon reasons determined sufficient by the Owner, may constitute a default. In such case, award of contract will be transferred to the second lowest bidder.

#### **10. CONTRACTOR'S QUALIFICATION STATEMENT**

- A.** Contractor's Qualification Statement (AIA Document 305) shall be submitted by low bidder for evaluation prior to award of contract if so requested by the Owner or his representatives.

#### **11. LIST OF SUBCONTRACTORS/PRODUCT & EQUIPMENT SUBSTITUTIONS**

- A.** Each Bidder shall submit a "SUBCONTRACTORS LIST" proposed to be used in the execution of the Work. If there will be no subcontractors, the Bidder shall state "No Subcontractors" on this form. The completed form is due with the Bid Proposal.
- 1) Identify the trade name, address, telephone number, and category of work of each subcontractor.
  - 2) Failure to submit the "Subcontractors List" with the Bid Proposal may result in the rejection of the Bid.
  - 3) Delete Subparagraphs (6.3.1.1) from AIA A701.
- B.** The Bidder, by submission of a signed bid form, agrees to install all products and equipment by brand name or names specified in the Technical Specifications sections of this Project Manual. "Or equal" substitutions will be allowed only if approved in writing prior to the bid opening and listed in the "Substitutions" section of the Bid Form.

#### **12. CONTRACT ADMINISTRATION FORMS/COSTS OF FORMS**

- A. REQUIRED FORMS.** The following AIA forms will be used (AIA forms will be supplied by the Owner if requested, and charged to the Contractor at cost) in the administration of the project:
- 1) **AIA Document A310:** "Bid Bond", February 1970 edition
  - 2) **AIA Document A305:** "Contractor's Qualification Statement", 1986 edition

- 3) **AIA Document G702:** "Application and Certificate of Payment", May 1992 edition
  - 4) **AIA Document G703:** "Continuation Sheet", May 1992 edition
- B. OTHER FORMS.** Other contract administration forms (to be provided by the Owner unless otherwise noted) required for use in the Project are:
- 1) **Subcontractors List**
  - 2) **Contractor's Affidavit**
  - 3) **Performance Bond**
  - 4) **Labor and Material Payment Bond**
  - 5) **Lien Waiver Forms**
  - 6) **Certified Payroll Form**  
 Please Note: Illinois State Law has changed. As a Contractor on a public works project, Contractor must submit certified payroll directly to the Illinois Department of Labor. See details at <https://www2.illinois.gov/idol/laws-rules/conmed/pages/prevaling-wage-portal.aspx>  
  
 The first time submitting certified payroll to this site requires additional set-up time and specialized forms that must be used.  
  
 After submitting certified payroll directly to the Illinois Department of Labor, Contractor will receive a PDF proof of submittal. A copy of this PDF proof of submittal is required with pay applications to Owner.
  - 7) **Insurance Forms: As required in Attachment A (at end of Project Manual)** (will not be provided by Owner)
  - 8) **Agreement Between Owner and Contractor**
- Examples of these forms are included in the Project Manual.

### **13. CONSTRUCTION TIME AND LIQUIDATED DAMAGES CLAUSE:**

**PROJECT COMPLETION.** The Agreement will include the following paragraph(s) or language substantially the same, regarding construction time and liquidated damages:

- 1) **LIQUIDATED DAMAGES:** Owner and Contractor recognize that time is of the essence of this Agreement and that Owner will suffer financial loss if the Work is not Substantially Complete within the time specified below, plus any extensions thereof allowed in accordance with Article 8 of the General Conditions. They also recognize the delays, expense and difficulties involved in proving in a legal or arbitration proceeding the actual loss suffered by Owner if the Work is not completed on time.
- 2) Accordingly, instead of requiring any such proof, Owner and Contractor agree that as Liquidated Damages for delay (but not as a penalty) Contractor shall pay Owner TWO HUNDRED AND FIFTY DOLLARS (\$250.00) for each calendar day that expires after three hundred and eighty six (386) calendar days from Notice of Award until Substantial Completion is attained. The work is tentatively scheduled to begin on December 11, 2025 and be at Substantial Completion by December 17, 2026.
- 3) After Substantial Completion, if Contractor shall neglect, refuse, or fail to complete the remaining Work necessary to achieve Final Completion within fourteen (14) calendar days or any proper extension thereof granted by Owner, Contractor shall pay Owner TWO HUNDRED AND FIFTY DOLLARS (\$250.00) dollars for each day that expires after the time specified.
- 4) Owner and Contractor agree that the per day liquidated damage amounts set forth in subparagraphs "2" and "3" of this section constitute a reasonable forecast of the financial losses, actual costs and increased expenses the Owner may incur as a result of delayed Substantial or Final Completion of the Project.

### **14. PROJECT MANUAL/PLANS & SITE VISITATION**

- A. A set of Bid Documents may be examined, at no charge, at the office of the Owner's Representative.
- B. **PLAN DEPOSIT.** An electronic file including Bid Documents is available at no charge. A printed set of Bid Documents, including Plans, Specifications and Interpretations for this project may be obtained at the Planning, Design & Construction Department, Bradley Park Equipment Service, 1314 N. Park Road, Peoria, IL 61604. Telephone (309)686-3386. A non-refundable plan deposit of \$300.00 will be charged for each printed set of Bid Documents.
- C. **FAMILIARITY WITH BID DOCUMENTS & SITE VISITATION.** Bidders, by submission of their Bids, represent that they have visited the site to acquaint themselves with the local conditions in which the Work is to occur, and that they are familiar with all the requirements of the Project, as defined in the Project Manual and the Plan(s).

### **15. OTHER MODIFICATIONS TO AIA-701/OTHER CONDITIONS**

- A. Add the following sentence to (4.1.7): "Bidder shall submit two (2) completed copies of Bid Form and retain one (1) copy for his files."
- B. Delete (4.2.1)
- C. Delete Section (6.2) - "Owner's Financial Capability"
- D. In reference to (7.2.1), the Peoria Park District reserves the right of final approval of bonding companies. Replace the first Sentence with "The Bidder shall deliver the required bonds to the Owner not later than ten days following the date of execution of the Contract."
- E. Delete paragraph (7.1.3).

**16. EQUAL EMPLOYMENT OPPORTUNITY/SEXUAL HARASSMENT**

- A. It is a goal of the Peoria Park District to encourage participation of minorities and women on Peoria Park District construction projects through contracts and workforce. Good Faith Effort must be made to encourage the use of minority and women owned businesses as sub-contractors and suppliers on the project.

On all bids \$50,000.00 and over, see requirements listed in **Attachment B "Solicitation and Hiring for Qualifying Construction Contracts & Forms"**.

On all bids less than \$50,000.00, complete and submit the following listed forms (provided in Attachment B) with the Bid. Failure to submit the forms may result in rejection of the bid.

- 1. "Peoria Park District Certificate of Equal Employment Opportunity Compliance for Contractors and Vendors" Form
- 2. "Workforce Profile" Form
- 3. "Company Ownership Certification" Form

- B. Effective July 1, 1993, every party to a public contract and every party bidding on public contracts is required to have a written "**Sexual Harassment Policy**". The Sexual Harassment Policy must contain:

- 1) A definition of sexual harassment under state law;
- 2) A description of sexual harassment utilizing examples;
- 3) A formalized complaint procedure;
- 4) A statement of victim's rights;
- 5) Directions on how to contact the Illinois Department of Human Rights - **Illinois companies**. Out-of-State companies must include directions on how to contact the enforcement agency within their state. Companies that issue a standard policy for all business locations must prepare an addendum providing directions on how to contact the appropriate enforcement agency.
- 6) A recitation that there cannot be any retaliation against employees who elect to file charges.

Recommendation: Your "**Sexual Harassment Policy**" should be drafted in language easy to understand and any revisions should be reviewed by legal counsel. A copy of your policy should be posted in a prominent and accessible location to assure all employees will be notified of the company's position.

**In order to conduct business with the Peoria Park District, you must have a written "Sexual Harassment Policy" that conforms to the Act.**

**FAILURE TO DO SO WILL DISQUALIFY YOU AS AN ELIGIBLE VENDOR.**

**17. BID SUBMISSION**

- A. **DATE, TIME & PLACE OF RECEIVING BIDS.** Bids will be received until the date and time listed in the "Advertisement for Bids", at which time they will be publicly opened, read aloud and recorded. The Bid Opening will be held at the place listed in the "Advertisement for Bids".
- B. **REQUIRED ITEMS.** The following items must be included as part of the "BID":
  - 1) Two (2) signed copies of the **BID FORM**. (Retain the third copy for your files.)
  - 2) The **SUBCONTRACTORS LIST**. (Submit form and state "No Subcontractors" on the form, if none will be used.)
  - 3) The **PEORIA PARK DISTRICT CERTIFICATE OF EQUAL EMPLOYMENT OPPORTUNITY COMPLIANCE FOR CONTRACTORS AND VENDORS** form.
  - 4) The **WORKFORCE PROFILE** form.

- 5) The **COMPANY OWNERSHIP CERTIFICATION** form.
- 6) The **CERTIFICATION OF COMPLIANCE OF THE LISTED PROVISIONS AND LAWS** form.
- 7) Completed **W-9**.
- 8) The **BID GUARANTY**.
- 9) If the bid is over \$50,000.00, the **MINORITY/WOMEN OWNED CONTACT SHEET** form.
- 10) If the bid is over \$50,000.00, the **CONTRACTOR/SUBCONTRACTOR WORKFORCE PLAN** form.

**C. BID SUBMISSION.** The "BID" shall be enclosed in envelopes (outer and inner), both of which shall be sealed and clearly labeled with the following information, in order to prevent premature opening of the bid:

- "PROPOSAL"
- NAME OF PROJECT
- NAME OF BIDDER
- DATE/TIME OF BID OPENING

END OF SUPPLEMENTARY INSTRUCTIONS TO BIDDERS

Bid From: \_\_\_\_\_

PROJECT NO. 24-027  
BID FOR: IRRIGATION IMPROVEMENT  
LOCATION: NEWMAN GOLF COURSE

**BID FORM**

BID TO: PEORIA PARK DISTRICT

UNDERSIGNED:

1. Acknowledges receipt of:

A. Project Manual and Drawings for:

IRRIGATION IMPROVEMENT  
NEWMAN GOLF COURSE  
2021 W NEBRASKA AVE  
PEORIA, ILLINOIS

B. Addenda: No. \_\_\_\_\_ through No. \_\_\_\_\_

2. Has examined facility and the bid documents and shall be responsible for performing work specifically required of him by all parts of bidding documents including specifications for entire project, even though such work may be included as related requirements specified in other divisions or sections.

3. And agrees to enter into and execute Contract with Owner, if awarded on basis of this bid, and to:

- A. Furnish Bonds and Insurance required by the Bidding & Contract Documents.
- B. Accomplish work in accord with Contract.
- C. Complete work within specified Contract time.

4. **CONTRACT TIME:** Contractor agrees to Substantially Complete ALL WORK as required by the Contract Documents per the Supplementary General Conditions and Supplementary Instructions to Bidders.

5. **BASE BIDS:**

A. Base Bid:

Bidder agrees to perform all building and site work, as set forth in the Project Manual and Drawings for the sum of:

\_\_\_\_\_ Dollars (\$ \_\_\_\_\_ . \_\_\_\_\_)

6. **ALTERNATES:**

Bidder agrees to perform all building and/or site work items as set forth below. The prices submitted may be accepted either at the time of Base Bid approval or up to no later than ninety (90) days after award of the Bid; however, if not approved at the time of the award of the Base Bid, the contract times as set forth in the Project Manual and Drawings will be adjusted to compensate for the additional time taken in award of the Alternate:

Bid From: \_\_\_\_\_

PROJECT NO. 24-027  
BID FOR: IRRIGATION IMPROVEMENT  
LOCATION: NEWMAN GOLF COURSE

A. Add Alternate #1:

Alternate scope of work shall include; Irrigation mainlines, laterals, irrigation controls, and irrigation components for holes #7 and #8 as outlined in the Newman Golf Course Drawings.

\_\_\_\_\_ Dollars (\$ \_\_\_\_\_ . \_\_\_\_\_)

B. Add Alternate #2:

Alternate scope of work shall include; Irrigation mainlines, laterals, irrigation controls, and irrigation components for holes #6 as outlined in the Newman Golf Course Drawings.

\_\_\_\_\_ Dollars (\$ \_\_\_\_\_ . \_\_\_\_\_)

C. Add Alternate #3:

Alternate scope of work shall include; Irrigation mainlines, laterals, irrigation controls, and irrigation components for holes #4 and #5 as outlined in the Newman Golf Course Drawings.

\_\_\_\_\_ Dollars (\$ \_\_\_\_\_ . \_\_\_\_\_)

7. UNIT PRICES:

A. Bidders submitting prices for the Base Bid shall submit Unit Prices for adding or deleting work. Unit Prices shall include all costs, including but not limited to preparation, labor, equipment, and materials necessary for a complete installation.

<u>ITEM</u>	<u>UNIT</u>	<u>UNIT PRICE</u>
Toro INF34 or equal series full circle driven rotor, 1” body w/ 1 ¼” swing joint, piping, fittings, 2-wire comm cable and all associated equipment	EA.	\$ _____
Toro INF35 or equal series full circle driven rotor, 1” body w/ 1 ¼” swing joint, piping, fittings, 2-wire comm cable and all associated equipment	EA.	\$ _____
Toro or equal 1” Quick coupler valve with swing joint & stabilizer – complete	EA.	\$ _____
3” Fusion Saddle	EA.	\$ _____
2” Fusion Saddle	EA.	\$ _____
1 1/2” Fusion Saddle	EA.	\$ _____
2” PE 360° Lateral Isolation Assembly (as specified)	EA.	\$ _____

Bid From: \_\_\_\_\_

PROJECT NO. 24-027  
BID FOR: IRRIGATION IMPROVEMENT  
LOCATION: NEWMAN GOLF COURSE

<u>3" PE 360° Lateral Isolation Assembly (as specified)</u>	<u>EA.</u>	<u>\$</u>
<u>3" Clow Resilient Wedge HDPE Stub-out Isolation Valve (as specified)</u>	<u>EA.</u>	<u>\$</u>
<u>4" Clow Resilient Wedge HDPE Stub-out Isolation Valve (as specified)</u>	<u>EA.</u>	<u>\$</u>
<u>6" Clow Resilient Wedge HDPE Stub-out Isolation Valve (as specified)</u>	<u>EA.</u>	<u>\$</u>
<u>8" Clow Resilient Wedge HDPE Stub-out Isolation Valve (as specified)</u>	<u>EA.</u>	<u>\$</u>
<u>10" Clow Resilient Wedge HDPE Stub-out Isolation Valve (as specified)</u>	<u>EA.</u>	<u>\$</u>
<u>12" Clow Resilient Wedge HDPE Stub-out Isolation Valve (as specified)</u>	<u>EA.</u>	<u>\$</u>
<u>2" HDPE DR 13.5 4710 Pipe</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>3" HDPE DR 13.5 4710 Pipe</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>4" HDPE DR 13.5 4710 Pipe</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>6" HDPE DR 13.5 4710 Pipe</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>8" HDPE DR 13.5 4710 Pipe</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>10" HDPE DR 13.5 4710 Pipe</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>12" HDPE DR 13.5 4710 Pipe</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>#4 Tray Cable Power Wire</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>#6 Tray Cable Power Wire</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>#8 Tray Cable Power Wire</u>	<u>Lin. Ft.</u>	<u>\$</u>
<u>Paige Electric 10'-0" Ground Rod Assembly w/ Grounding Gem Set</u>	<u>EA.</u>	<u>\$</u>
<u>Paige Electric 96" Ground Plate Assembly w/ Grounding Gem Set</u>	<u>EA.</u>	<u>\$</u>
<u>Paige Electric 36" Ground Plate Assembly w/ Grounding Gem Set</u>	<u>EA.</u>	<u>\$</u>
<u>Hunter Field Satellite – Complete w/ grounding (as specified and per plan)</u>	<u>EA.</u>	<u>\$</u>





Bid From: \_\_\_\_\_

PROJECT NO. 24-027  
BID FOR: IRRIGATION IMPROVEMENT  
LOCATION: NEWMAN GOLF COURSE

NAME OF BIDDER: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY, STATE, ZIP: \_\_\_\_\_

TELEPHONE NO.: \_\_\_\_\_

BY: \_\_\_\_\_  
(Signature of Authorized Official)

TITLE: \_\_\_\_\_

BIDDER'S SEAL

WITNESS: \_\_\_\_\_

END OF BID FORM

## SUBCONTRACTORS LIST

The following tabulation of Subcontractors shall be attached and made a condition of the Bid. The Bidder expressly understands and agrees to the following provisions:

- A. If awarded a Contract as a result of this Bid, the subcontractors used in the prosecution of the work will be those listed below.
- B. The following list includes all subcontractors, known at the time of the Bid, who will perform work on this project.
- C. The subcontractors listed below are financially responsible and are qualified to perform the work required.
- D. The subcontractors listed below comply with the requirements of the Contract Documents.
- E. Any substitutions in the subcontractors listed below shall be requested in writing by the Contractor and must be approved in writing by the Owner. No sub-subcontractors will be allowed unless specifically stated on the form. All pertinent financial, performance, insurance and other applicable information shall be submitted with the request for substitution(s). Owner shall respond to such requests within 14 calendar days following the submission of all necessary information to the full satisfaction of the Owner.
- F. Failure to submit the list of Subcontractors as stated herein shall constitute a material variation from the Invitation to Bid; and any such Bid may be rejected by the Owner.

Subcontractor Name	Telephone/Email	Area of Work	Minority/Women Owned Business (Yes/No)	Dollar Amount of Contract

BIDDER: \_\_\_\_\_

END OF SUBCONTRACTORS LIST

**CERTIFICATION OF COMPLIANCE  
OF THE LISTED PROVISIONS AND LAWS**

**1) Illinois Drug Free Workplace Act of 1991**

**2) The Substance Abuse Prevention on Public Works Act Public Act 95-0635:**

Prohibits the use of drugs and alcohol while performing work on a public works project.

The Contractor/Subcontractor has signed collective bargaining agreement for all of its employees that deal with the subject matter or the Contractor/Subcontractor has a prevention program that meets or exceeds the requirements of the Public Act for all employees not covered by a collective bargaining agreement.

**3) Safety Compliance:**

Contractor/Subcontractors will comply with any and all prevailing occupational safety and health standards. Such compliance may include a training component or require a written program of compliance.

**4) Illinois Criminal Code, Illinois Compiled Statutes 720 ILCS 5/33E-3 and 5/33E-4:**

Contractor/Subcontractor has not been barred from bidding on public contract as a result of bid rigging or bid rotating.

The undersigned representative of the Contractor/Vendor hereby certifies to comply with the laws and provisions listed above.

\_\_\_\_\_  
Contractor/Subcontractor

\_\_\_\_\_  
Name of Authorized Representative (type or print)

\_\_\_\_\_  
Signature of Authorized Representative

\_\_\_\_\_  
Date

# Request for Taxpayer Identification Number and Certification

Go to [www.irs.gov/FormW9](http://www.irs.gov/FormW9) for instructions and the latest information.

**Give form to the  
requester. Do not  
send to the IRS.**

**Before you begin.** For guidance related to the purpose of Form W-9, see *Purpose of Form*, below.

<b>Print or type. See Specific Instructions on page 3.</b>	<b>1</b>	Name of entity/individual. An entry is required. (For a sole proprietor or disregarded entity, enter the owner's name on line 1, and enter the business/disregarded entity's name on line 2.)	
	<b>2</b>	Business name/disregarded entity name, if different from above.	
	<b>3a</b>	Check the appropriate box for federal tax classification of the entity/individual whose name is entered on line 1. Check only <b>one</b> of the following seven boxes.  <input type="checkbox"/> Individual/sole proprietor <input type="checkbox"/> C corporation <input type="checkbox"/> S corporation <input type="checkbox"/> Partnership <input type="checkbox"/> Trust/estate  <input type="checkbox"/> LLC. Enter the tax classification (C = C corporation, S = S corporation, P = Partnership) _____ <b>Note:</b> Check the "LLC" box above and, in the entry space, enter the appropriate code (C, S, or P) for the tax classification of the LLC, unless it is a disregarded entity. A disregarded entity should instead check the appropriate box for the tax classification of its owner.  <input type="checkbox"/> Other (see instructions) _____	<b>4</b> Exemptions (codes apply only to certain entities, not individuals; see instructions on page 3):  Exempt payee code (if any) _____  Exemption from Foreign Account Tax Compliance Act (FATCA) reporting code (if any) _____  <i>(Applies to accounts maintained outside the United States.)</i>
	<b>3b</b>	If on line 3a you checked "Partnership" or "Trust/estate," or checked "LLC" and entered "P" as its tax classification, and you are providing this form to a partnership, trust, or estate in which you have an ownership interest, check this box if you have any foreign partners, owners, or beneficiaries. See instructions . . . . . <input type="checkbox"/>	
	<b>5</b>	Address (number, street, and apt. or suite no.). See instructions.	Requester's name and address (optional)
	<b>6</b>	City, state, and ZIP code	
	<b>7</b>	List account number(s) here (optional)	

## Part I Taxpayer Identification Number (TIN)

Enter your TIN in the appropriate box. The TIN provided must match the name given on line 1 to avoid backup withholding. For individuals, this is generally your social security number (SSN). However, for a resident alien, sole proprietor, or disregarded entity, see the instructions for Part I, later. For other entities, it is your employer identification number (EIN). If you do not have a number, see *How to get a TIN*, later.

<b>Social security number</b>									
<b>or</b>									
<b>Employer identification number</b>									

**Note:** If the account is in more than one name, see the instructions for line 1. See also *What Name and Number To Give the Requester* for guidelines on whose number to enter.

## Part II Certification

Under penalties of perjury, I certify that:

1. The number shown on this form is my correct taxpayer identification number (or I am waiting for a number to be issued to me); and
2. I am not subject to backup withholding because (a) I am exempt from backup withholding, or (b) I have not been notified by the Internal Revenue Service (IRS) that I am subject to backup withholding as a result of a failure to report all interest or dividends, or (c) the IRS has notified me that I am no longer subject to backup withholding; and
3. I am a U.S. citizen or other U.S. person (defined below); and
4. The FATCA code(s) entered on this form (if any) indicating that I am exempt from FATCA reporting is correct.

**Certification instructions.** You must cross out item 2 above if you have been notified by the IRS that you are currently subject to backup withholding because you have failed to report all interest and dividends on your tax return. For real estate transactions, item 2 does not apply. For mortgage interest paid, acquisition or abandonment of secured property, cancellation of debt, contributions to an individual retirement arrangement (IRA), and, generally, payments other than interest and dividends, you are not required to sign the certification, but you must provide your correct TIN. See the instructions for Part II, later.

<b>Sign Here</b>	Signature of U.S. person	Date
------------------	--------------------------	------

## General Instructions

Section references are to the Internal Revenue Code unless otherwise noted.

**Future developments.** For the latest information about developments related to Form W-9 and its instructions, such as legislation enacted after they were published, go to [www.irs.gov/FormW9](http://www.irs.gov/FormW9).

## What's New

Line 3a has been modified to clarify how a disregarded entity completes this line. An LLC that is a disregarded entity should check the appropriate box for the tax classification of its owner. Otherwise, it should check the "LLC" box and enter its appropriate tax classification.

New line 3b has been added to this form. A flow-through entity is required to complete this line to indicate that it has direct or indirect foreign partners, owners, or beneficiaries when it provides the Form W-9 to another flow-through entity in which it has an ownership interest. This change is intended to provide a flow-through entity with information regarding the status of its indirect foreign partners, owners, or beneficiaries, so that it can satisfy any applicable reporting requirements. For example, a partnership that has any indirect foreign partners may be required to complete Schedules K-2 and K-3. See the Partnership Instructions for Schedules K-2 and K-3 (Form 1065).

## Purpose of Form

An individual or entity (Form W-9 requester) who is required to file an information return with the IRS is giving you this form because they

must obtain your correct taxpayer identification number (TIN), which may be your social security number (SSN), individual taxpayer identification number (ITIN), adoption taxpayer identification number (ATIN), or employer identification number (EIN), to report on an information return the amount paid to you, or other amount reportable on an information return. Examples of information returns include, but are not limited to, the following.

- Form 1099-INT (interest earned or paid).
- Form 1099-DIV (dividends, including those from stocks or mutual funds).
- Form 1099-MISC (various types of income, prizes, awards, or gross proceeds).
- Form 1099-NEC (nonemployee compensation).
- Form 1099-B (stock or mutual fund sales and certain other transactions by brokers).
- Form 1099-S (proceeds from real estate transactions).
- Form 1099-K (merchant card and third-party network transactions).
- Form 1098 (home mortgage interest), 1098-E (student loan interest), and 1098-T (tuition).
- Form 1099-C (canceled debt).
- Form 1099-A (acquisition or abandonment of secured property).

Use Form W-9 only if you are a U.S. person (including a resident alien), to provide your correct TIN.

**Caution:** If you don't return Form W-9 to the requester with a TIN, you might be subject to backup withholding. See *What is backup withholding*, later.

**By signing the filled-out form**, you:

1. Certify that the TIN you are giving is correct (or you are waiting for a number to be issued);
2. Certify that you are not subject to backup withholding; or
3. Claim exemption from backup withholding if you are a U.S. exempt payee; and
4. Certify to your non-foreign status for purposes of withholding under chapter 3 or 4 of the Code (if applicable); and
5. Certify that FATCA code(s) entered on this form (if any) indicating that you are exempt from the FATCA reporting is correct. See *What Is FATCA Reporting*, later, for further information.

**Note:** If you are a U.S. person and a requester gives you a form other than Form W-9 to request your TIN, you must use the requester's form if it is substantially similar to this Form W-9.

**Definition of a U.S. person.** For federal tax purposes, you are considered a U.S. person if you are:

- An individual who is a U.S. citizen or U.S. resident alien;
- A partnership, corporation, company, or association created or organized in the United States or under the laws of the United States;
- An estate (other than a foreign estate); or
- A domestic trust (as defined in Regulations section 301.7701-7).

**Establishing U.S. status for purposes of chapter 3 and chapter 4 withholding.** Payments made to foreign persons, including certain distributions, allocations of income, or transfers of sales proceeds, may be subject to withholding under chapter 3 or chapter 4 of the Code (sections 1441–1474). Under those rules, if a Form W-9 or other certification of non-foreign status has not been received, a withholding agent, transferee, or partnership (payor) generally applies presumption rules that may require the payor to withhold applicable tax from the recipient, owner, transferor, or partner (payee). See Pub. 515, *Withholding of Tax on Nonresident Aliens and Foreign Entities*.

The following persons must provide Form W-9 to the payor for purposes of establishing its non-foreign status.

- In the case of a disregarded entity with a U.S. owner, the U.S. owner of the disregarded entity and not the disregarded entity.
- In the case of a grantor trust with a U.S. grantor or other U.S. owner, generally, the U.S. grantor or other U.S. owner of the grantor trust and not the grantor trust.
- In the case of a U.S. trust (other than a grantor trust), the U.S. trust and not the beneficiaries of the trust.

See Pub. 515 for more information on providing a Form W-9 or a certification of non-foreign status to avoid withholding.

**Foreign person.** If you are a foreign person or the U.S. branch of a foreign bank that has elected to be treated as a U.S. person (under Regulations section 1.1441-1(b)(2)(iv) or other applicable section for chapter 3 or 4 purposes), do not use Form W-9. Instead, use the appropriate Form W-8 or Form 8233 (see Pub. 515). If you are a qualified foreign pension fund under Regulations section 1.897(l)-1(d), or a partnership that is wholly owned by qualified foreign pension funds, that is treated as a non-foreign person for purposes of section 1445 withholding, do not use Form W-9. Instead, use Form W-8EXP (or other certification of non-foreign status).

**Nonresident alien who becomes a resident alien.** Generally, only a nonresident alien individual may use the terms of a tax treaty to reduce or eliminate U.S. tax on certain types of income. However, most tax treaties contain a provision known as a saving clause. Exceptions specified in the saving clause may permit an exemption from tax to continue for certain types of income even after the payee has otherwise become a U.S. resident alien for tax purposes.

If you are a U.S. resident alien who is relying on an exception contained in the saving clause of a tax treaty to claim an exemption from U.S. tax on certain types of income, you must attach a statement to Form W-9 that specifies the following five items.

1. The treaty country. Generally, this must be the same treaty under which you claimed exemption from tax as a nonresident alien.
2. The treaty article addressing the income.
3. The article number (or location) in the tax treaty that contains the saving clause and its exceptions.
4. The type and amount of income that qualifies for the exemption from tax.
5. Sufficient facts to justify the exemption from tax under the terms of the treaty article.

**Example.** Article 20 of the U.S.-China income tax treaty allows an exemption from tax for scholarship income received by a Chinese student temporarily present in the United States. Under U.S. law, this student will become a resident alien for tax purposes if their stay in the United States exceeds 5 calendar years. However, paragraph 2 of the first Protocol to the U.S.-China treaty (dated April 30, 1984) allows the provisions of Article 20 to continue to apply even after the Chinese student becomes a resident alien of the United States. A Chinese student who qualifies for this exception (under paragraph 2 of the first Protocol) and is relying on this exception to claim an exemption from tax on their scholarship or fellowship income would attach to Form W-9 a statement that includes the information described above to support that exemption.

If you are a nonresident alien or a foreign entity, give the requester the appropriate completed Form W-8 or Form 8233.

## Backup Withholding

**What is backup withholding?** Persons making certain payments to you must under certain conditions withhold and pay to the IRS 24% of such payments. This is called "backup withholding." Payments that may be subject to backup withholding include, but are not limited to, interest, tax-exempt interest, dividends, broker and barter exchange transactions, rents, royalties, nonemployee pay, payments made in settlement of payment card and third-party network transactions, and certain payments from fishing boat operators. Real estate transactions are not subject to backup withholding.

You will not be subject to backup withholding on payments you receive if you give the requester your correct TIN, make the proper certifications, and report all your taxable interest and dividends on your tax return.

**Payments you receive will be subject to backup withholding if:**

1. You do not furnish your TIN to the requester;
2. You do not certify your TIN when required (see the instructions for Part II for details);
3. The IRS tells the requester that you furnished an incorrect TIN;
4. The IRS tells you that you are subject to backup withholding because you did not report all your interest and dividends on your tax return (for reportable interest and dividends only); or
5. You do not certify to the requester that you are not subject to backup withholding, as described in item 4 under "*By signing the filled-out form*" above (for reportable interest and dividend accounts opened after 1983 only).

Certain payees and payments are exempt from backup withholding. See *Exempt payee code*, later, and the separate Instructions for the Requester of Form W-9 for more information.

See also *Establishing U.S. status for purposes of chapter 3 and chapter 4 withholding*, earlier.

## What Is FATCA Reporting?

The Foreign Account Tax Compliance Act (FATCA) requires a participating foreign financial institution to report all U.S. account holders that are specified U.S. persons. Certain payees are exempt from FATCA reporting. See *Exemption from FATCA reporting code*, later, and the Instructions for the Requester of Form W-9 for more information.

## Updating Your Information

You must provide updated information to any person to whom you claimed to be an exempt payee if you are no longer an exempt payee and anticipate receiving reportable payments in the future from this person. For example, you may need to provide updated information if you are a C corporation that elects to be an S corporation, or if you are no longer tax exempt. In addition, you must furnish a new Form W-9 if the name or TIN changes for the account, for example, if the grantor of a grantor trust dies.

## Penalties

**Failure to furnish TIN.** If you fail to furnish your correct TIN to a requester, you are subject to a penalty of \$50 for each such failure unless your failure is due to reasonable cause and not to willful neglect.

**Civil penalty for false information with respect to withholding.** If you make a false statement with no reasonable basis that results in no backup withholding, you are subject to a \$500 penalty.

**Criminal penalty for falsifying information.** Willfully falsifying certifications or affirmations may subject you to criminal penalties including fines and/or imprisonment.

**Misuse of TINs.** If the requester discloses or uses TINs in violation of federal law, the requester may be subject to civil and criminal penalties.

## Specific Instructions

### Line 1

You must enter one of the following on this line; **do not** leave this line blank. The name should match the name on your tax return.

If this Form W-9 is for a joint account (other than an account maintained by a foreign financial institution (FFI)), list first, and then circle, the name of the person or entity whose number you entered in Part I of Form W-9. If you are providing Form W-9 to an FFI to document a joint account, each holder of the account that is a U.S. person must provide a Form W-9.

- **Individual.** Generally, enter the name shown on your tax return. If you have changed your last name without informing the Social Security Administration (SSA) of the name change, enter your first name, the last name as shown on your social security card, and your new last name.

**Note for ITIN applicant:** Enter your individual name as it was entered on your Form W-7 application, line 1a. This should also be the same as the name you entered on the Form 1040 you filed with your application.

- **Sole proprietor.** Enter your individual name as shown on your Form 1040 on line 1. Enter your business, trade, or “doing business as” (DBA) name on line 2.

- **Partnership, C corporation, S corporation, or LLC, other than a disregarded entity.** Enter the entity’s name as shown on the entity’s tax return on line 1 and any business, trade, or DBA name on line 2.

- **Other entities.** Enter your name as shown on required U.S. federal tax documents on line 1. This name should match the name shown on the charter or other legal document creating the entity. Enter any business, trade, or DBA name on line 2.

- **Disregarded entity.** In general, a business entity that has a single owner, including an LLC, and is not a corporation, is disregarded as an entity separate from its owner (a disregarded entity). See Regulations section 301.7701-2(c)(2). A disregarded entity should check the appropriate box for the tax classification of its owner. Enter the owner’s name on line 1. The name of the owner entered on line 1 should never be a disregarded entity. The name on line 1 should be the name shown on the income tax return on which the income should be reported. For

example, if a foreign LLC that is treated as a disregarded entity for U.S. federal tax purposes has a single owner that is a U.S. person, the U.S. owner’s name is required to be provided on line 1. If the direct owner of the entity is also a disregarded entity, enter the first owner that is not disregarded for federal tax purposes. Enter the disregarded entity’s name on line 2. If the owner of the disregarded entity is a foreign person, the owner must complete an appropriate Form W-8 instead of a Form W-9. This is the case even if the foreign person has a U.S. TIN.

### Line 2

If you have a business name, trade name, DBA name, or disregarded entity name, enter it on line 2.

### Line 3a

Check the appropriate box on line 3a for the U.S. federal tax classification of the person whose name is entered on line 1. Check only one box on line 3a.

IF the entity/individual on line 1 is a(n) . . .	THEN check the box for . . .
• Corporation	Corporation.
• Individual or • Sole proprietorship	Individual/sole proprietor.
• LLC classified as a partnership for U.S. federal tax purposes or • LLC that has filed Form 8832 or 2553 electing to be taxed as a corporation	Limited liability company and enter the appropriate tax classification: P = Partnership, C = C corporation, or S = S corporation.
• Partnership	Partnership.
• Trust/estate	Trust/estate.

### Line 3b

Check this box if you are a partnership (including an LLC classified as a partnership for U.S. federal tax purposes), trust, or estate that has any foreign partners, owners, or beneficiaries, and you are providing this form to a partnership, trust, or estate, in which you have an ownership interest. You must check the box on line 3b if you receive a Form W-8 (or documentary evidence) from any partner, owner, or beneficiary establishing foreign status or if you receive a Form W-9 from any partner, owner, or beneficiary that has checked the box on line 3b.

**Note:** A partnership that provides a Form W-9 and checks box 3b may be required to complete Schedules K-2 and K-3 (Form 1065). For more information, see the Partnership Instructions for Schedules K-2 and K-3 (Form 1065).

If you are required to complete line 3b but fail to do so, you may not receive the information necessary to file a correct information return with the IRS or furnish a correct payee statement to your partners or beneficiaries. See, for example, sections 6698, 6722, and 6724 for penalties that may apply.

### Line 4 Exemptions

If you are exempt from backup withholding and/or FATCA reporting, enter in the appropriate space on line 4 any code(s) that may apply to you.

#### Exempt payee code.

- Generally, individuals (including sole proprietors) are not exempt from backup withholding.
- Except as provided below, corporations are exempt from backup withholding for certain payments, including interest and dividends.
- Corporations are not exempt from backup withholding for payments made in settlement of payment card or third-party network transactions.
- Corporations are not exempt from backup withholding with respect to attorneys’ fees or gross proceeds paid to attorneys, and corporations that provide medical or health care services are not exempt with respect to payments reportable on Form 1099-MISC.

The following codes identify payees that are exempt from backup withholding. Enter the appropriate code in the space on line 4.

1—An organization exempt from tax under section 501(a), any IRA, or a custodial account under section 403(b)(7) if the account satisfies the requirements of section 401(f)(2).

- 2—The United States or any of its agencies or instrumentalities.
- 3—A state, the District of Columbia, a U.S. commonwealth or territory, or any of their political subdivisions or instrumentalities.
- 4—A foreign government or any of its political subdivisions, agencies, or instrumentalities.
- 5—A corporation.
- 6—A dealer in securities or commodities required to register in the United States, the District of Columbia, or a U.S. commonwealth or territory.
- 7—A futures commission merchant registered with the Commodity Futures Trading Commission.
- 8—A real estate investment trust.
- 9—An entity registered at all times during the tax year under the Investment Company Act of 1940.
- 10—A common trust fund operated by a bank under section 584(a).
- 11—A financial institution as defined under section 581.
- 12—A middleman known in the investment community as a nominee or custodian.
- 13—A trust exempt from tax under section 664 or described in section 4947.

The following chart shows types of payments that may be exempt from backup withholding. The chart applies to the exempt payees listed above, 1 through 13.

IF the payment is for . . .	THEN the payment is exempt for . . .
• Interest and dividend payments	All exempt payees except for 7.
• Broker transactions	Exempt payees 1 through 4 and 6 through 11 and all C corporations. S corporations must not enter an exempt payee code because they are exempt only for sales of noncovered securities acquired prior to 2012.
• Barter exchange transactions and patronage dividends	Exempt payees 1 through 4.
• Payments over \$600 required to be reported and direct sales over \$5,000 <sup>1</sup>	Generally, exempt payees 1 through 5. <sup>2</sup>
• Payments made in settlement of payment card or third-party network transactions	Exempt payees 1 through 4.

<sup>1</sup> See Form 1099-MISC, Miscellaneous Information, and its instructions.

<sup>2</sup> However, the following payments made to a corporation and reportable on Form 1099-MISC are not exempt from backup withholding: medical and health care payments, attorneys' fees, gross proceeds paid to an attorney reportable under section 6045(f), and payments for services paid by a federal executive agency.

**Exemption from FATCA reporting code.** The following codes identify payees that are exempt from reporting under FATCA. These codes apply to persons submitting this form for accounts maintained outside of the United States by certain foreign financial institutions. Therefore, if you are only submitting this form for an account you hold in the United States, you may leave this field blank. Consult with the person requesting this form if you are uncertain if the financial institution is subject to these requirements. A requester may indicate that a code is not required by providing you with a Form W-9 with "Not Applicable" (or any similar indication) entered on the line for a FATCA exemption code.

A—An organization exempt from tax under section 501(a) or any individual retirement plan as defined in section 7701(a)(37).

B—The United States or any of its agencies or instrumentalities.

C—A state, the District of Columbia, a U.S. commonwealth or territory, or any of their political subdivisions or instrumentalities.

D—A corporation the stock of which is regularly traded on one or more established securities markets, as described in Regulations section 1.1472-1(c)(1)(i).

E—A corporation that is a member of the same expanded affiliated group as a corporation described in Regulations section 1.1472-1(c)(1)(i).

F—A dealer in securities, commodities, or derivative financial instruments (including notional principal contracts, futures, forwards, and options) that is registered as such under the laws of the United States or any state.

G—A real estate investment trust.

H—A regulated investment company as defined in section 851 or an entity registered at all times during the tax year under the Investment Company Act of 1940.

I—A common trust fund as defined in section 584(a).

J—A bank as defined in section 581.

K—A broker.

L—A trust exempt from tax under section 664 or described in section 4947(a)(1).

M—A tax-exempt trust under a section 403(b) plan or section 457(g) plan.

**Note:** You may wish to consult with the financial institution requesting this form to determine whether the FATCA code and/or exempt payee code should be completed.

**Line 5**

Enter your address (number, street, and apartment or suite number). This is where the requester of this Form W-9 will mail your information returns. If this address differs from the one the requester already has on file, enter "NEW" at the top. If a new address is provided, there is still a chance the old address will be used until the payor changes your address in their records.

**Line 6**

Enter your city, state, and ZIP code.

**Part I. Taxpayer Identification Number (TIN)**

**Enter your TIN in the appropriate box.** If you are a resident alien and you do not have, and are not eligible to get, an SSN, your TIN is your IRS ITIN. Enter it in the entry space for the Social security number. If you do not have an ITIN, see *How to get a TIN* below.

If you are a sole proprietor and you have an EIN, you may enter either your SSN or EIN.

If you are a single-member LLC that is disregarded as an entity separate from its owner, enter the owner's SSN (or EIN, if the owner has one). If the LLC is classified as a corporation or partnership, enter the entity's EIN.

**Note:** See *What Name and Number To Give the Requester*, later, for further clarification of name and TIN combinations.

**How to get a TIN.** If you do not have a TIN, apply for one immediately. To apply for an SSN, get Form SS-5, Application for a Social Security Card, from your local SSA office or get this form online at [www.SSA.gov](http://www.SSA.gov). You may also get this form by calling 800-772-1213. Use Form W-7, Application for IRS Individual Taxpayer Identification Number, to apply for an ITIN, or Form SS-4, Application for Employer Identification Number, to apply for an EIN. You can apply for an EIN online by accessing the IRS website at [www.irs.gov/EIN](http://www.irs.gov/EIN). Go to [www.irs.gov/Forms](http://www.irs.gov/Forms) to view, download, or print Form W-7 and/or Form SS-4. Or, you can go to [www.irs.gov/OrderForms](http://www.irs.gov/OrderForms) to place an order and have Form W-7 and/or Form SS-4 mailed to you within 15 business days.

If you are asked to complete Form W-9 but do not have a TIN, apply for a TIN and enter "Applied For" in the space for the TIN, sign and date the form, and give it to the requester. For interest and dividend payments, and certain payments made with respect to readily tradable instruments, you will generally have 60 days to get a TIN and give it to the requester before you are subject to backup withholding on payments. The 60-day rule does not apply to other types of payments. You will be subject to backup withholding on all such payments until you provide your TIN to the requester.

**Note:** Entering "Applied For" means that you have already applied for a TIN or that you intend to apply for one soon. See also *Establishing U.S. status for purposes of chapter 3 and chapter 4 withholding*, earlier, for when you may instead be subject to withholding under chapter 3 or 4 of the Code.

**Caution:** A disregarded U.S. entity that has a foreign owner must use the appropriate Form W-8.

## Part II. Certification

To establish to the withholding agent that you are a U.S. person, or resident alien, sign Form W-9. You may be requested to sign by the withholding agent even if item 1, 4, or 5 below indicates otherwise.

For a joint account, only the person whose TIN is shown in Part I should sign (when required). In the case of a disregarded entity, the person identified on line 1 must sign. Exempt payees, see *Exempt payee code*, earlier.

**Signature requirements.** Complete the certification as indicated in items 1 through 5 below.

**1. Interest, dividend, and barter exchange accounts opened before 1984 and broker accounts considered active during 1983.** You must give your correct TIN, but you do not have to sign the certification.

**2. Interest, dividend, broker, and barter exchange accounts opened after 1983 and broker accounts considered inactive during 1983.** You must sign the certification or backup withholding will apply. If you are subject to backup withholding and you are merely providing your correct TIN to the requester, you must cross out item 2 in the certification before signing the form.

**3. Real estate transactions.** You must sign the certification. You may cross out item 2 of the certification.

**4. Other payments.** You must give your correct TIN, but you do not have to sign the certification unless you have been notified that you have previously given an incorrect TIN. "Other payments" include payments made in the course of the requester's trade or business for rents, royalties, goods (other than bills for merchandise), medical and health care services (including payments to corporations), payments to a nonemployee for services, payments made in settlement of payment card and third-party network transactions, payments to certain fishing boat crew members and fishermen, and gross proceeds paid to attorneys (including payments to corporations).

**5. Mortgage interest paid by you, acquisition or abandonment of secured property, cancellation of debt, qualified tuition program payments (under section 529), ABLE accounts (under section 529A), IRA, Coverdell ESA, Archer MSA or HSA contributions or distributions, and pension distributions.** You must give your correct TIN, but you do not have to sign the certification.

## What Name and Number To Give the Requester

For this type of account:	Give name and SSN of:
1. Individual	The individual
2. Two or more individuals (joint account) other than an account maintained by an FFI	The actual owner of the account or, if combined funds, the first individual on the account <sup>1</sup>
3. Two or more U.S. persons (joint account maintained by an FFI)	Each holder of the account
4. Custodial account of a minor (Uniform Gift to Minors Act)	The minor <sup>2</sup>
5. a. The usual revocable savings trust (grantor is also trustee)	The grantor-trustee <sup>1</sup>
b. So-called trust account that is not a legal or valid trust under state law	The actual owner <sup>1</sup>
6. Sole proprietorship or disregarded entity owned by an individual	The owner <sup>3</sup>
7. Grantor trust filing under Optional Filing Method 1 (see Regulations section 1.671-4(b)(2)(i)(A))**	The grantor*

For this type of account:	Give name and EIN of:
8. Disregarded entity not owned by an individual	The owner
9. A valid trust, estate, or pension trust	Legal entity <sup>4</sup>
10. Corporation or LLC electing corporate status on Form 8832 or Form 2553	The corporation
11. Association, club, religious, charitable, educational, or other tax-exempt organization	The organization
12. Partnership or multi-member LLC	The partnership
13. A broker or registered nominee	The broker or nominee
14. Account with the Department of Agriculture in the name of a public entity (such as a state or local government, school district, or prison) that receives agricultural program payments	The public entity
15. Grantor trust filing Form 1041 or under the Optional Filing Method 2, requiring Form 1099 (see Regulations section 1.671-4(b)(2)(i)(B))**	The trust

<sup>1</sup> List first and circle the name of the person whose number you furnish. If only one person on a joint account has an SSN, that person's number must be furnished.

<sup>2</sup> Circle the minor's name and furnish the minor's SSN.

<sup>3</sup> You must show your individual name on line 1, and enter your business or DBA name, if any, on line 2. You may use either your SSN or EIN (if you have one), but the IRS encourages you to use your SSN.

<sup>4</sup> List first and circle the name of the trust, estate, or pension trust. (Do not furnish the TIN of the personal representative or trustee unless the legal entity itself is not designated in the account title.)

\* **Note:** The grantor must also provide a Form W-9 to the trustee of the trust.

\*\* For more information on optional filing methods for grantor trusts, see the Instructions for Form 1041.

**Note:** If no name is circled when more than one name is listed, the number will be considered to be that of the first name listed.

## Secure Your Tax Records From Identity Theft

Identity theft occurs when someone uses your personal information, such as your name, SSN, or other identifying information, without your permission to commit fraud or other crimes. An identity thief may use your SSN to get a job or may file a tax return using your SSN to receive a refund.

To reduce your risk:

- Protect your SSN,
- Ensure your employer is protecting your SSN, and
- Be careful when choosing a tax return preparer.

If your tax records are affected by identity theft and you receive a notice from the IRS, respond right away to the name and phone number printed on the IRS notice or letter.

If your tax records are not currently affected by identity theft but you think you are at risk due to a lost or stolen purse or wallet, questionable credit card activity, or a questionable credit report, contact the IRS Identity Theft Hotline at 800-908-4490 or submit Form 14039.

For more information, see Pub. 5027, Identity Theft Information for Taxpayers.

Victims of identity theft who are experiencing economic harm or a systemic problem, or are seeking help in resolving tax problems that have not been resolved through normal channels, may be eligible for Taxpayer Advocate Service (TAS) assistance. You can reach TAS by calling the TAS toll-free case intake line at 877-777-4778 or TTY/TDD 800-829-4059.

**Protect yourself from suspicious emails or phishing schemes.**

Phishing is the creation and use of email and websites designed to mimic legitimate business emails and websites. The most common act is sending an email to a user falsely claiming to be an established legitimate enterprise in an attempt to scam the user into surrendering private information that will be used for identity theft.

The IRS does not initiate contacts with taxpayers via emails. Also, the IRS does not request personal detailed information through email or ask taxpayers for the PIN numbers, passwords, or similar secret access information for their credit card, bank, or other financial accounts.

If you receive an unsolicited email claiming to be from the IRS, forward this message to [phishing@irs.gov](mailto:phishing@irs.gov). You may also report misuse of the IRS name, logo, or other IRS property to the Treasury Inspector General for Tax Administration (TIGTA) at 800-366-4484. You can forward suspicious emails to the Federal Trade Commission at [spam@uce.gov](mailto:spam@uce.gov) or report them at [www.ftc.gov/complaint](http://www.ftc.gov/complaint). You can contact the FTC at [www.ftc.gov/idtheft](http://www.ftc.gov/idtheft) or 877-IDTHEFT (877-438-4338). If you have been the victim of identity theft, see [www.IdentityTheft.gov](http://www.IdentityTheft.gov) and Pub. 5027.

Go to [www.irs.gov/IdentityTheft](http://www.irs.gov/IdentityTheft) to learn more about identity theft and how to reduce your risk.

## Privacy Act Notice

Section 6109 of the Internal Revenue Code requires you to provide your correct TIN to persons (including federal agencies) who are required to file information returns with the IRS to report interest, dividends, or certain other income paid to you; mortgage interest you paid; the acquisition or abandonment of secured property; the cancellation of debt; or contributions you made to an IRA, Archer MSA, or HSA. The person collecting this form uses the information on the form to file information returns with the IRS, reporting the above information. Routine uses of this information include giving it to the Department of Justice for civil and criminal litigation and to cities, states, the District of Columbia, and U.S. commonwealths and territories for use in administering their laws. The information may also be disclosed to other countries under a treaty, to federal and state agencies to enforce civil and criminal laws, or to federal law enforcement and intelligence agencies to combat terrorism. You must provide your TIN whether or not you are required to file a tax return. Under section 3406, payors must generally withhold a percentage of taxable interest, dividends, and certain other payments to a payee who does not give a TIN to the payor. Certain penalties may also apply for providing false or fraudulent information.

## **PLEASE BE ADVISED!**

Every party to a public contract and every party bidding on public contracts are required to have a written sexual harassment policy that contains:

- (1) a statement that sexual harassment is illegal;
- (2) a definition of sexual harassment under state law;
- (3) a description of sexual harassment utilizing examples;
- (4) an internal formalized complaint process, including penalties;
- (5) the legal recourse, investigative and complaint process available through the Department of Human Rights and the Illinois Human Rights Commission;
- (6) directions on how to contact the Illinois Department of Human Rights and Illinois Human Rights Commission – **Illinois companies. Out-of-State companies must include directions on how to contact the enforcement agency within their state.** Companies that issue a standard policy for all business locations must prepare an addendum providing directions on how to contact the appropriate enforcement agency.
- (7) a recitation that there cannot be any retaliation against employees who elect to file charges, as provided in Sections 6-101 and 6-101.5 of the Illinois Human Rights Act.

**Recommendation:** Your sexual harassment policy should be drafted in language easy to understand and any revisions should be reviewed by legal counsel. A copy of your policy should be posted in a prominent and accessible location to assure all employees will be notified of the company's position.

**In order to conduct business with the THE PEORIA PARK DISTRICT, you must have a written sexual harassment policy that conforms to the Illinois Human Rights Act and/or the laws of your jurisdiction.**

**FAILURE TO DO SO  
WILL DISQUALIFY YOU AS AN ELIGIBLE VENDOR!!!**

## SAMPLE ADDENDUM

Peoria Park District  
Planning, Design and Construction Department  
1314 N. Park Road  
Peoria, IL 61604  
Telephone: (309) 686-3386

ADDENDUM NO. \_\_\_\_\_

PROJECT TITLE: \_\_\_\_\_

ISSUANCE DATE: \_\_\_\_\_

LOCATION: \_\_\_\_\_

The proposed Contract Documents for this Work are modified as follows:

- I. **GENERAL INFORMATION:**
  
- II. **DRAWINGS:** (Delete/Change/Modify/Etc.)
  
- III. **PROJECT MANUAL/SPECIFICATIONS.:**  
(Delete/Change/Modify/Etc.)
  
- IV. **INVITATION TO BID:** (Delete/Change/Modify/Etc.)

END OF ADDENDUM NO. \_\_\_\_\_

(Addendum may be bound into Project Manual, attached to front cover, faxed, mailed, emailed or delivered to bidders.)

Addendum No. \_\_\_\_\_  
Page 1 of 1



**Pleasure Driveway and Park District of Peoria, Illinois**  
**Sample Agreement Between Owner and Contractor**

---

This **AGREEMENT** for

IRRIGATION IMPROVEMENT  
NEWMAN GOLF COURSE  
2021 W NEBRASKA AVE  
PEORIA, ILLINOIS

is made as of the \_\_\_\_\_ day of \_\_\_\_\_ in the year of Two Thousand Twenty-Five (2025)

**Between the Owner:**

PLEASURE DRIVEWAY AND PARK DISTRICT OF PEORIA, ILLINOIS  
1125 W. LAKE AVENUE  
PEORIA, IL 61614

**And the Contractor:**

PLANNING, DESIGN AND CONSTRUCTION DEPARTMENT  
1314 N. PARK ROAD  
PEORIA, IL 61604

**The Owner's Representative is:**

**The Architect or Engineer is:**

ERIK CHRISTIANSEN DESIGN GROUP, LTD.  
400 5<sup>TH</sup> STREET  
WEST DES MOINES, IOWA 50265

The Owner and Contractor agree as follows:

**I. THE CONTRACT DOCUMENTS.** The Contract Documents consist of this AGREEMENT, the Plans/Drawings for the Project dated November 18, 2025, all sections of the Project Manual dated November 18, 2025, including but not limited to the Instructions and Supplementary Instructions to Bidders, the Bid Form, the General Conditions (2017 AIA Document A201) and Supplementary General Conditions, the General Requirements, the Specifications, and other documents as enumerated in Section 10 and Attachment #1 of this AGREEMENT, and including addenda issued prior to the execution of this AGREEMENT. The Contract Documents form the CONTRACT between the Owner and the Contractor. The CONTRACT represents the entire and integrated contract for the construction of the Work of the Project between the parties hereto and supersedes prior proposals, contracts, negotiations, or representations, either written or oral.

**II. THE WORK OF THE CONTRACT.** The Contractor shall execute the entire Work described in the Contract Documents, unless modified in Section XI of this AGREEMENT.

**III. BASIS OF PAYMENT.** The Work of the CONTRACT shall be performed on a Lump Sum basis.

**IV. CONTRACT SUM.** The Owner shall pay the Contractor the sum of

(and incorporates the acceptance of bid alternates as defined in sub-paragraph "A", below) for the Contractor's performance of the Work required by the Contract Documents, subject to modifications made by Owner approved Change Orders. If this CONTRACT calls for a unit price basis of payment, the contract sum stated above shall be adjusted by Change Order based upon multiplying the unit prices submitted by the Contractor on the Bid Form (and included herein as an Attachment to this CONTRACT) times (x) the actual quantities installed.

**A. ACCEPTANCE OF ALTERNATES.** The contract sum stated above is based on the acceptance of the following alternates, which are described in the Project Manual:

<u>ITEM</u>	<u>ADD</u>	<u>DEDUCT</u>

**V. DATES OF COMMENCEMENT AND COMPLETION OF THE WORK.** The Owner's Representative will issue a written Notice to Proceed with the Work of the Project after receiving the required Performance Bond, Labor and Material Payment Bond, and Certificate of Insurance (in proper form and providing the required coverages and amounts from a company [or companies] acceptable to the Owner, and naming the Owner as an Additional Insured), and any other pre-construction submittals required by the Contract Documents. The Contractor hereby acknowledges and agrees that failure to provide such submittals in a timely manner shall not be cause to adjust the date(s) for completion of the Work.

- A. LIQUIDATED DAMAGES.** Owner and Contractor recognize that time is of the essence of this CONTRACT and that Owner will suffer financial loss if the Contractor has not achieved Substantial Completion and Final Completion of the Work within the time specified below, plus any extensions thereof allowed in accordance with Article 8 of the General Conditions. They also recognize the delays, expense and difficulties involved in proving in a legal or arbitration proceeding the actual loss suffered by Owner if the Work is not completed on time.
- B. SUBSTANTIAL COMPLETION.** Accordingly, instead of requiring any such proof, Owner and Contractor agree that as Liquidated Damages for delay (but not as a penalty), Contractor shall pay Owner two hundred and fifty dollars (\$250.00) for each calendar day that expires after three hundred and eighty six (386) calendar days from Notice of Award until Substantial Completion is attained. The work is tentatively scheduled to begin on December 11, 2025 and be at Substantial Completion by December 17, 2026.
- C. FINAL COMPLETION.** After Substantial Completion if Contractor shall neglect, refuse, or fail to complete the remaining Work necessary to achieve Final Completion within fourteen (14) calendar days or any proper extension thereof granted by Owner, Contractor shall pay Owner two hundred and fifty dollars (\$250.00) for each day that expires after the time specified.

**VI. PROGRESS PAYMENTS, REDUCTION OF RETAINAGE AND FINAL PAYMENT.**

- A.** Unless otherwise specified elsewhere in the Contract Documents, the Contractor may submit monthly applications for progress payments ("Application for Payment") to the Owner's Representative. Each Application for Payment must be certified by the Architect or Engineer (if applicable), or the Owner's Representative if an Architect or Engineer has not been engaged for construction phase services. An Application for Payment shall be for a period of no less than one calendar month ending on the last day of the month, unless otherwise approved in writing by the Owner's Representative. Application forms shall be subject to Owner's approval. Each Application for Payment shall be based upon the Schedule of Values submitted by the Contractor, in accordance with the Contract Documents. The Schedule of Values shall be approved by the Owner's Representative and the Architect or Engineer (if applicable) in advance of the Contractor's first Application for Payment and the approved schedule shall be used by the Contractor as the basis for submitting payment requests. The Owner's Representative and/or Architect/Engineer's (if applicable) approval of the Schedule of Values shall not constitute a complete check for accuracy, and shall not relieve the Contractor from responsibility for errors of any sort.

- B. An Application for Payment (certified by the Architect or Engineer, if applicable) shall be submitted to the Owner's Representative no later than the fifth (5th) day of the month following the period for which the application is being submitted. In such case, the Owner shall make the progress payment to the Contractor not later than the twentieth day of the next month. A progress payment request on an Application for Payment (certified by the Architect or Engineer, if applicable) received by the Owner's Representative after the fifth (5th) day of a month shall be made by the Owner not later than forty-five days after receipt by the Owner's Representative.
- C. Based upon its review of the certified (by the Architect or Engineer, if applicable) Application for Payment, the Owner shall make a progress payment to the Contractor in such amount as the Owner reasonably determines is properly due, subject to a retainage of ten percent (10%) of the value of the Work completed and covered by the Application for Payment, less the aggregate of previous payments in each case. In determining the amount properly due, the Owner shall consider the value of labor, materials and equipment incorporated in the Work, or properly allocable to materials and equipment suitably stored at the site or at some other location previously agreed upon in writing by the parties. The Owner's Representative shall have the sole right to determine that materials or equipment stored off-site have been properly delivered, protected, and/or secured. The Owner's Representative (or the Architect or Engineer, if applicable) may nullify or withhold a Certificate of Payment, in whole or in part, for the reasons set forth in Section 9.5 of the General Conditions. Upon Substantial Completion of the Work, the Owner shall pay the Contractor a sum sufficient to increase the total payments to ninety-five percent (95%) of the Contract Sum, less such amounts as the Owner's Representative shall determine for incomplete work and unsettled claims.

**VII. Final payment, constituting the entire unpaid balance of the Contract Sum, shall be made by the Owner when 1) the Contract has been fully performed by the Contractor except for the Contractor's responsibility to correct nonconforming Work as provided in Subparagraph 12.2.2 of the General Conditions and to satisfy other requirements, if any, which necessarily survive final payment; and 2) a final Certificate of Payment has been issued by the Architect/Engineer or Owner's Representative; such final payment shall be made by the Owner not more than forty-five (45) days after the receipt of the final Certificate of Payment by the Owner.**

**VIII. CHANGE ORDERS.** The Owner and Contractor agree that changes in the Work are sometimes required and necessary, and that timely: **a) submission of proposed changes in the Work or the scope of Work by the Owner, b) pricing by the Contractor, c) review by the Owner's Representative and/or Architect/Engineer, and d) final approval by the Owner** are necessary in order to assure that the Work of the Project is completed on schedule. The Contractor hereby acknowledges and agrees that an increase in the scope of the Work does not grant or imply an increase in the Contract Time, unless specifically so stated on the final approved Change Order. The Contractor also agrees that any and all Work which deviates from the plans and specifications and/or results in additional Work performed by Contractor's forces, including those of his sub-contractor's, will not result in additional expense to the Owner, unless finally approved both by the Owner and the Architect/Engineer (if applicable) prior to the additional Work being performed. No claim for an addition to the Contract Sum shall be valid unless approved by a written Change Order signed by the Owner and the architect/engineer (if applicable) prior to the additional Work being performed.

**IX. TERMINATION OR SUSPENSION.** The CONTRACT may be terminated by the Owner or the Contractor as provided by Article 14 of the General Conditions. The Work may be suspended by the Owner as provided in Article 14 of the General Conditions.

**X. ENUMERATION OF CONTRACT DOCUMENTS.** The Contract Documents, except for modifications issued after the execution of this Agreement, consist of:

- A. this Standard Form of Agreement Between Owner and Contractor, of the Pleasure Driveway and Park District of Peoria, Illinois.
- B. the Plans or Drawings titled NEWMAN GOLF COURSE, dated November 18, 2025, and enumerated in ATTACHMENT #1 - "LIST OF DRAWINGS".
- C. Supplementary and other Conditions of the CONTRACT, and the Specifications, are those found in the Project Manual titled "SPECIFICATIONS FOR THE IRRIGATION IMPROVEMENT – NEWMAN GOLF COURSE", and dated November 18, 2025 enumerated as follows:
  - 1) Supplementary Instructions to Bidders
  - 2) Contractor's Proposal, as accepted by the Owner
  - 3) General Conditions of the Contract for Construction, AIA Document A201, 2017 Edition
  - 4) Supplementary General Conditions
  - 5) Subcontractor List

- 6) Certification of Compliance for Listed Provisions and Laws
- 7) Company Ownership Certification
- 8) Peoria Park District Certificate of Equal Employment Opportunity Compliance for Contractors and Vendors
- 9) Workforce Profile
- 10) Minority/Women Owned Contact Sheet, if bid is over \$50,000.00
- 11) Contractor/Subcontractor Workforce Plan, if bid is over \$50,000.00
- 12) Performance Bond
- 13) Labor and Material Payment Bond
- 14) Proof of Insurance
- 15) Specifications: Division 010000, "General Requirements"; Divisions 020000-350000 as applicable
- 16) Attachment A.6 - Insurance Requirements
- 17) Attachment B – Solicitation & Hiring for Qualifying Construction Contracts & Forms
- 18) Attachment C – Directory of Minority & Women Owned Business Enterprises
- 19) Attachment D – IDOL Prevailing Wages of Peoria County
- 20) Proof of Certified Payroll Submitted to IDOL per “The Illinois Prevailing Wage Act”

**XI. MISCELLANEOUS PROVISIONS.** Other Provisions of this Agreement are as follows:

This AGREEMENT is entered into as of the day and year first written above and is executed in at least three original copies of which one is to be delivered to the Contractor, one to the Architect/Engineer (if any) for use in the administration of the CONTRACT, and one to the Owner.

**OWNER:**

**CONTRACTOR :**

\_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Signature)

ROBERT L. JOHNSON, SR., Park Board President

\_\_\_\_\_  
(Printed Name and Title)

ATTEST:

ATTEST:

## ATTACHMENT #1 - LIST OF DRAWINGS

<u>Number</u>	<u>Title</u>	<u>Date</u>
LI-0	COVER	November 18, 2025
LI-1	IMPACT COVERAGE PLAN	November 18, 2025
LI-2	HYDRAULIC PIPING PLAN	November 18, 2025
LI-3	ELECTRICAL SCHEMATIC PLAN	November 18, 2025
LI-4	SITE IRRIGATION PLAN	November 18, 2025
LI-5	IRRIGATION DETAILS	November 18, 2025
LI-6	EXISTING IRRIGATION DRAWINGS	November 18, 2025

**PERFORMANCE BOND**

**TO: PLEASURE DRIVEWAY AND PARK DISTRICT OF PEORIA  
PEORIA, ILLINOIS**

**KNOW ALL MEN BY THESE PRESENTS;**

That \_\_\_\_\_  
as Principal, and \_\_\_\_\_  
\_\_\_\_\_ as  
corporation of the State of \_\_\_\_\_, as Surety, are held and firmly bound unto the  
PLEASURE DRIVEWAY AND PARK DISTRICT OF PEORIA, PEORIA, ILLINOIS, as Obligee, in the amount of \_\_\_\_\_  
(\$ \_\_\_\_\_), for the payment whereof Principal and Surety bind themselves, their heirs, executors, administrators,  
successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, Principal has by written agreement dated \_\_\_\_\_, 20 \_\_\_\_\_ entered into a contract  
with Obligee for \_\_\_\_\_

in accordance with contract documents prepared by the Architect-Engineer, which Contract is by reference made a part hereof and  
is hereinafter referred to as "the Contract".

NOW, THEREFORE, THE CONDITION OF THIS OBLIGATION is such that if Principal shall promptly and faithfully  
perform the Contract and all changes thereof, and during the life of any guaranty or warranty required under the Contract, and, if  
Principal shall fully secure and protect the Obligee from all liability and from all loss or expense of any kind, including all court  
costs, engineering fees and attorneys' fees made necessary or arising from the failure, refusal or neglect of Principal to comply with  
all obligations assumed by Principal in connection with the performance of the Contract and all changes thereof, then this  
obligation shall be null and void; otherwise it shall remain in full force and effect.

Surety hereby waives notice of any changes in the Contract, including extensions of time for the performance thereof. Whenever  
Principal shall be and is declared to be in default under the Contract, Obligee having performed Obligee's obligations thereunder,  
Surety shall, after notice of such default, reserve all rights against all parties, take over and complete the Contract and become  
entitled to payment of the balance of any monies due or to become due to such defined Principal in accordance with the progress  
of the work.

A condition of this Bond is that the Principal shall faithfully perform in accordance with the prevailing wage clause provided in the  
bid specification or Contract pursuant to Illinois Compiled Statutes 820 ILCS 130/1 *et. seq.*

No right of action shall accrue on this Bond to or for the use of any person or corporation other than the Obligee named  
herein.

Signed and Sealed this \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_.

**CONTRACTOR**

\_\_\_\_\_  
Contractor Firm Name

By: \_\_\_\_\_  
Signature

\_\_\_\_\_  
Title

**SURETY**

\_\_\_\_\_  
Surety Name

By: \_\_\_\_\_  
Attorney-in-Fact

\_\_\_\_\_  
Resident Agent

ATTEST:

\_\_\_\_\_  
Corporate Secretary (Corporations only)

**LABOR & MATERIAL PAYMENT BOND**

**TO: PLEASURE DRIVEWAY AND PARK DISTRICT OF PEORIA  
PEORIA, ILLINOIS**

**KNOW ALL MEN BY THESE PRESENTS:**

That: \_\_\_\_\_  
\_\_\_\_\_

as Principal, and \_\_\_\_\_  
\_\_\_\_\_ a corporation of the State of \_\_\_\_\_ as Surety, are held and firmly bound unto the PLEASURE DRIVEWAY AND PARK DISTRICT OF PEORIA, PEORIA, ILLINOIS, as Obligee, for the use and benefit of claimants as hereinafter defined in the amount of \_\_\_\_\_ Dollars (\$ \_\_\_\_\_), for the payment whereof Principal and Surety bind themselves, their heirs, executors, administrators, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, Principal has by written agreement dated \_\_\_\_\_, 20 \_\_\_\_\_, entered into a Contract with Obligee for \_\_\_\_\_

\_\_\_\_\_ in accordance with contract documents prepared by the Architect-Engineer which Contract is by reference made a part hereof, and is hereinafter referred to as "the Contract".

**NOW, THEREFORE, THE CONDITION OF THIS OBLIGATION** is such that if Principal shall promptly pay for all laborers, workers and mechanics engaged in the work under the Contract, and not less than the general prevailing rate of hourly wages of a similar character in the locality in which the work is performed, as determined by the State of Illinois Department of Labor pursuant to the Illinois Compiled Statutes 820 ILCS 130/1 et. seq. and for all material used or reasonably required for use in the performance of the Contract, then this obligation shall be void; otherwise it shall remain in full force and effect.

1. A claimant is defined as any person, firm, or corporation having contracts with the Principal or with any of Principal's subcontractors for labor or materials furnished in the performance of the Contract on account of which this Bond is given.
2. Nothing in this Bond contained shall be taken to make the Obligee liable to any subcontractor, materialman or laborer, or to any other person to any greater extent than it would have been liable prior to the enactment of The Public Construction Bond Act, approved June 20, 1931, as amended; provided further, that any person having a claim for labor and materials furnished in the performance of the Contract shall have no right of action unless he shall have filed a verified notice of such claim with the Obligee within 180 days after the date of the last item of work or the furnishing of the last item of materials, which claim shall have been verified and shall contain the name and address of the claimant, the business address of the claimant within the State of Illinois, if any, or if the claimant be a foreign corporation having no place of business within the State the principal place of business of the corporation, and in all cases of partnership the names and residences of each of the partners, the name of the Contractor for the Obligee, the name of the person, firm or corporation by whom the claimant was employed or to whom such claimant furnished materials, the amount of the claim and a brief description of the public improvement for the construction or installation of which the Contract is to be performed. No defect in the notice herein provided for shall deprive the claimant of its right of action under the terms and provisions of this Bond unless it shall affirmatively appear that such defect has prejudiced the rights of an interested party asserting the same.
3. No action shall be brought on this Bond until the expiration of 120 days after the date of the last item of work or of the furnishing of the last item of material except in cases where the final settlement between the Obligee and the Contractor shall have been made prior to the expiration of the 120 day period, in which case action may be taken immediately following such final settlement; nor shall any action of any kind be brought later than 6 months after the acceptance by the Obligee of the work. Such suit shall be brought only in the circuit court of this State in the judicial district in which the Contract is to be performed.
4. Surety hereby waives notice of any changes in the Contract, including extensions of time for the performance thereof.

5. The amount of this Bond shall be reduced by and to the extent of any payment or payments made in good faith hereunder.

6. The Principal and Surety shall be liable for any attorneys fees, engineering costs, or court costs incurred by the Obligee relative to claims made against this Bond.

Signed and Sealed this \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_.

**CONTRACTOR**

**SURETY**

Contractor Firm Name:

\_\_\_\_\_

\_\_\_\_\_

By: \_\_\_\_\_  
Signature

By: \_\_\_\_\_  
Attorney-in-Fact

\_\_\_\_\_ Title

\_\_\_\_\_ Resident Agent

ATTEST:

\_\_\_\_\_  
Corporate Secretary (Corporations only)

**CONTRACTOR'S AFFIDAVIT**

STATE OF ILLINOIS )  
  ) SS  
COUNTY OF PEORIA )

TO WHOM IT MAY CONCERN:

THE undersigned, being duly sworn, deposes and says that he is \_\_\_\_\_  
\_\_\_\_\_ of the \_\_\_\_\_  
who is the contractor for the \_\_\_\_\_  
building located at \_\_\_\_\_  
owned by \_\_\_\_\_.

That the total amount of the contract including extras is \$ \_\_\_\_\_ on which he has received payment  
of \$ \_\_\_\_\_ prior to this payment. That all waivers are true, correct and genuine and delivered  
unconditionally and that there is no claim either legal or equitable to defeat the validity of said waivers. That the following are the  
names of all parties who have furnished material or labor, or both, for said work and all parties having contracts or sub-contracts  
for specific portions of said work or for material entering into the construction thereof and the amount due or to become due to  
each, and that the items mentioned include all labor and material required to complete said work according to plans and  
specifications:

NAMES	WHAT FOR	CONTRACT PRICE	AMOUNT PAID	THIS PMT.	BALANCE DUE

TOTAL ALL LABOR AND MATERIAL TO COMPLETE

There are no other contracts for said work outstanding, and that there is nothing due or to become due to any person for material,  
labor or other work of any kind done or to be done upon or in connection with said work other than above stated.

Signed this \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_.

Signature: \_\_\_\_\_

Subscribed and sworn to before me this \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_.

\_\_\_\_\_  
Notary Public

**FINAL WAIVER OF LIEN**

STATE OF ILLINOIS    )  
  ) SS  
COUNTY OF PEORIA    )

TO WHOM IT MAY CONCERN:

WHEREAS, the undersigned \_\_\_\_\_ ha \_\_\_\_\_ been employed by THE PEORIA PARK DISTRICT to furnish material and labor for the \_\_\_\_\_ at the premises commonly known as \_\_\_\_\_ located in the City of \_\_\_\_\_, County of Peoria, State of Illinois.

The undersigned, for and in consideration of \_\_\_\_\_ (\$ \_\_\_\_\_) Dollars, and other good and valuable considerations, the receipt whereof is hereby acknowledged, do \_\_\_\_\_ hereby waive and release any and all lien or claim or right of lien under the statutes of the State of Illinois relating to mechanics' liens, with respect to and on said above-described premises and improvements thereon and on the money, funds or other considerations due or become due from the owner on account of labor or services, material, fixtures, apparatus or machinery heretofore furnished or which may be furnished at any time hereafter by the undersigned for the above described premises.

Dated this \_\_\_\_\_ day of \_\_\_\_\_ 20 \_\_\_\_\_.

[Affix corporate seal here.]

\_\_\_\_\_  
(Name of sole owner, corporation or partnership)

ATTEST:

\_\_\_\_\_  
(Signature of secretary of corporation)

\_\_\_\_\_  
(Signature of sole owner or authorized representative of corporation or partnership) (SEAL)

**WAIVER OF LIEN**

**GENERAL CONTRACTOR'S PARTIAL  
TO COVER ONLY CERTAIN PAYMENTS**

STATE OF ILLINOIS    )  
                                  ) SS  
COUNTY OF PEORIA    )

TO ALL WHOM IT MAY CONCERN:

WHEREAS, the undersigned \_\_\_\_\_ has been employed  
by THE PEORIA PARK DISTRICT to furnish material and labor for the \_\_\_\_\_ at  
the premises commonly known as \_\_\_\_\_

\_\_\_\_\_ located in the City of Peoria, County of Peoria, and State of Illinois.

NOW, THEREFORE, the undersigned, for and in consideration of the sum of \_\_\_\_\_  
\_\_\_\_\_ Dollars, and other good and valuable considerations, the receipt  
whereof is hereby acknowledged by the undersigned, does hereby waive and release to the extent only of the aforesaid amount of  
\_\_\_\_\_ Dollars, paid simultaneously herewith, any and all lien or right or claim of  
lien under the statutes of the State of Illinois relating to mechanics' liens, with respect to and on said above-described premises,  
and the improvements thereon and on the money, funds, or other consideration due or to become due from the owner on account of  
labor, services, material, fixtures, apparatus or machinery, furnished by the undersigned, to or on account of the said owner, for the  
above-described premises, but only to the extent of the payment aforesaid.

Dated this \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_.

[Affix corporate seal here]

\_\_\_\_\_  
(Name of sole owner, corporation or partnership)

ATTEST:

\_\_\_\_\_  
(Signature of secretary of corporation)

\_\_\_\_\_  
(Signature of sole owner or authorized  
representative of corporation or partnership)





*A complete copy of AIA Document A201, 2017 Edition, with Supplementary General Conditions incorporated, is available for review in the Peoria Park District's Planning, Design and Construction Office.*

## **SUPPLEMENTARY GENERAL CONDITIONS**

1. A. **"GENERAL CONDITIONS OF THE CONTRACT FOR CONSTRUCTION"**, AIA Document A201, 2017 Edition, published by the American Institute of Architects, including revisions adopted before the date of the Project Manual, is hereby made part of these Specifications with same force and effect as though set forth in full.
- B. The following modifies, changes, deletes from or adds to the General Conditions of the Contract for Construction (AIA Document A201, Sixteenth Edition, 2017). Where any Article of the General Conditions is modified or any Paragraph, Subparagraph or Clause thereof is modified or deleted by these Supplementary Conditions, the unaltered provisions of that Article, Paragraph, Subparagraph or Clause shall remain in effect.
- C. Parenthesis ( ) indicates the appropriate section and Subparagraph of the General Conditions which each paragraph of the Supplementary General Conditions modifies or refers to.

### **ARTICLE 1: GENERAL PROVISIONS**

#### 1.1 - Basic Definitions

**INSERT THE FOLLOWING PHRASE TO PARAGRAPH (1.1.1) AFTER THE WORDS "The Contract Documents consist of the Agreement Between Owner and Contractor (hereinafter the Agreement) and consists of the Agreement,":**

“the Contractor's Bid, the Advertisement for Bids, the Instructions to Bidders, sample forms and addenda relating to these,”

**DELETE THE LAST SENTENCE OF PARAGRAPH (1.1.1).**

**PARAGRAPH (1.1.8) IN THE HEADING DELETE “Initial Decision Maker” SUBSTITUTE “Initial Recommendation Maker”**

**PARAGRAPH (1.1.8) DELETE “Initial Decision Maker” AND SUBSTITUTE “Initial Recommendation Maker”**

**IN PARAGRAPH (1.1.8) REPLACE “decisions” WITH “recommendations”.**

#### 1.2 - Correlations and intent of the Contract Documents

**ADD THE FOLLOWING SENTENCES TO END OF PARAGRAPH (1.2.1):**

The Contractor shall notify the Owner’s Representative immediately if discrepancies are discovered. Full-size or large-scale details or drawings shall govern small-scale drawings that the former are intended to amplify. Dimensions from drawings shall not be determined by scale or rule. Where the Drawings and Specifications conflict with each other or with themselves, the Owner’s Representative (in consultation with the Architect, if any) will decide which conflicting requirement governs. Should discrepancies or doubt occur, Contractor shall not proceed with the Work without clarification from the Owner. Contractor shall request clarification in a reasonable time to avoid delays and increases in the Contract Sum.

**ADD THE FOLLOWING PARAGRAPHS TO SECTION (1.2):**

- 1.2.4** If any item or material shown on the Drawings is omitted from the Specifications, or vice-versa (except when the Drawings and Specifications clearly exclude such omitted item), and when such item or material is clearly required to complete the detail shown or specified, the Contractor shall furnish and install such item or material of the type and quality established by the balance of the detail shown and specified at no increase to the Contract Sum.
- 1.2.5** Where a typical or representative detail is shown on the Drawings, this detail shall constitute the standard for workmanship and materials throughout those parts of the Work.
- 1.2.6** Any Summary of Work as outlined in the Specifications shall not be deemed to limit the work required by the Contract Documents. The Contractor and each Subcontractor shall be responsible for carefully examining all Drawings, including all details, plans, elevations, sections, schedules and diagrams for each particular type of work, and for coordinating the Work described in the Drawings, with the related Specifications. The Contractor shall also be responsible for determining the exact scope of work for each type of work per the Contract Documents and Contractor shall endeavor to check cross-references of work excluded from any division. The Contract Sum is deemed to be based on a complete installation. When additional details or instructions are clearly required to complete the work, the Contractor is deemed to have made an allowance in the Contract Sum for completion of such Work consistent with the local standard of care.
- 1.2.7** The Drawings are intended to show the arrangement, design and extent of the Work and are schematic in nature. They are not to be scaled for roughing-in measurements or used as shop drawings.

1.5 – Ownership and Use of Drawings, Specifications, and Other Instruments of Service

**ADD THE FOLLOWING PARAGRAPH TO SECTION (1.5):**

- 1.5.3** Neither any oral representation by or oral agreement with any officer, agent, or employee of Owner or Architect before execution of this Contract shall affect or modify any of the Contractor's rights or obligations hereunder. Contractor is not aware of any facts that make misleading or inaccurate in any material respect any information Owner or Architect has furnished to Contractor which would have a material adverse affect on the Contract Time or Contract Sum which Contractor has not advised Owner or Architect of, and if, during the course of the performance of the Work, Contractor learns of any such facts it will so advise Owner. Contractor shall not be entitled to any adjustments in the Contract Time or the Contract Sum as a consequence of Contractor's breach of the terms of this Subparagraph.

1.7 – Digital Data use and Transmission

**DELETE THE SECOND SENTENCE IN PARAGRAPH (1.7).**

1.8 – Building Information Models Use and Reliance

**DELETE PARAGRAPH (1.8) IN ITS ENTIRETY.**

ARTICLE 2: OWNER

2.3 – Information and Services Required of the Owner

**DELETE PARAGRAPH (2.3.4) IN ITS ENTIRETY.**

## 2.4 – Owner’s Right to stop the Work

### **ADD THE FOLLOWING SENTENCE AT THE END OF PARAGRAPH (2.4):**

“The Owner shall not be liable for any extra cost incurred by the Contractor by such an order.”

## 2.5 – Owner’s Right to Carry Out the Work

**IN PARAGRAPH (2.5), IN THE SECOND SENTENCE, DELETE** “Such action by the Owner and amounts charged to the Contractor are both subject to prior approval of the Architect and”.

## ARTICLE 3: CONTRACTOR

### 3.2 - Review of Contract Documents and Field Conditions by Contractor

**IN PARAGRAPH (3.2.2, 3.2.3, AND (3.2.4) AFTER THE WORD “Architect” ADD THE WORDS “and Owner”.**

### **ADD THE FOLLOWING PARAGRAPH TO SECTION (3.2):**

**3.2.5** Before starting any work, the Contractor shall examine work performed by others to which his work adjoins or is applied to and report to the Owner's Representative any conditions that will prevent the satisfactory accomplishment of his work. Failure to notify the Owner's Representative of deficiencies or faults in preceding work prior to commencing work shall constitute acceptance thereof and waiver of any claim of its unsuitability.

### 3.4 – Labor and Materials

### **ADD THE FOLLOWING PARAGRAPHS TO SECTION (3.4):**

**3.4.4** Before ordering any material or doing any Work, the Contractor shall verify all measurements at the Project site and he shall be responsible for the correctness of same. No extra charge or compensation will be allowed to the Contractor on account of any difference between actual dimensions and the measurements shown on the Project Drawings.

**3.4.5** The Contractor shall carefully inspect all materials delivered on and to the Project site and reject defective materials without waiting for the Owner's Representative or other representative of Owner to observe the materials.

### 3.5 - Warranty

### **ADD THE FOLLOWING PARAGRAPHS TO SECTION (3.5):**

**3.5.3** The Contractor agrees to assign to the Owner any and all manufacturer’s warranties relating to materials and equipment furnished as part of the Work and further agrees to perform the Work in such manner so as to preserve any and all such manufacturer’s warranties subject to installation directives and other terms of the Contract Documents. The Contractor agrees to deliver to the Owner, upon final payment, such assignments along with or as part of a reference manual, in form and detail reasonably acceptable to Owner, showing all such warranties and guarantees provided by

the Contractor and Subcontractors. Such warranties and guarantees shall commence no sooner than the date of purchase from the supplier.

**3.5.4** The warranty of Contractor provided in Paragraph 3.5 shall in no way limit or abridge the warranties of the suppliers of equipment and systems which are to comprise a portion of the Work, if they are broader, and all of such warranties shall be in form and substance as required by the Contract Documents. Contractor shall take no action or fail to act in any way which results in the termination or expiration of such third party warranties or which otherwise results in prejudice to the rights of the Owner under such warranties subject to installation directives and other terms of the Contract Documents. Contractor agrees to provide all notices required for the effectiveness of such warranties and shall include provisions in the contracts with the providers and manufacturers of such systems and equipment whereby Owner shall have a direct right of enforcement of such warranty obligations.

### 3.6 - Taxes

**IN PARAGRAPH (3.6), DELETE THE WORD "Sales".**

**ADD THE FOLLOWING AT THE END OF PARAGRAPH (3.6):**

The Peoria Park District is exempt from Federal, State and Local taxes. A certificate of exemption will be furnished upon request.

### 3.10 - Contractor's Construction and Submittal Schedules

**IN PARAGRAPH (3.10.2), IN THE FIRST SENTENCE BEFORE THE WORD "Architect's approval" ADD THE WORDS "Owner's and".**

**IN PARAGRAPH (3.10.2), IN THE SECOND SENTENCE BEFORE THE WORD "Architect's" ADD THE WORDS "Owner's and".**

**IN PARAGRAPH (3.10.2), IN THE THIRD SENTENCE BEFORE THE WORD "Architect" ADD THE WORDS "Owner's Representative and".**

**ADD THE FOLLOWING PARAGRAPHS TO SECTION (3.10):**

**3.10.4** The construction schedule shall provide for the most expeditious and practicable execution of the Work. The Contractor shall also work closely with the Owner to confirm that the construction schedule accurately reflects the status of the Project. The Contractor's construction schedule shall be updated every month by the Contractor and submitted to the Owner.

**.1** Whenever it becomes apparent from the updated construction schedule that any substantial completion previously established by the construction schedule cannot be met, the Contractor shall, at the Owner's request, take any or all of the following actions with no increase to the Contract Sum or Contract Time (unless the delay is caused by an event set forth in paragraph 8.3 of these General Conditions thereby permitting adjustment of the Contract Sum and/or Contract Time:

**.1.1** Increase construction manpower to substantially return the Project to schedule;

**.1.2** Increase the number of working hours per shift, shifts per day or the amount of construction equipment or any combination of the foregoing which will substantially return the Project to schedule;

- .1.3** Reschedule activities to concurrently accomplish activities, to the maximum degree practicable, in the time required by the Contract Documents.

If the Contractor fails to take any of these actions Owner shall have the notice and other rights set forth in Paragraph 2.5.

#### ARTICLE 4: ARCHITECT

##### 4.1 - General

**IN PARAGRAPH (4.1.1) DELETE THE FIRST SENTENCE AND SUBSTITUTE THE FOLLOWING:**

"The Architect, Owner's Representative, and Owner's Project Manager are defined in Paragraph C of "Section 014200 - General" of "Division 010000 - General Requirements".

##### 4.2 – Administration of the Contract

**IN PARAGRAPH (4.2.1) DELETE THE WORDS “and will be an Owner’s Representative”.**

**IN PARAGRAPH (4.2.5) DELETE THE WORD “Architect’s” AND “Architect”AND SUBSTITUTE THE WORDS “Owner Representative’s” AND “Owner Representative”.**

**IN PARAGRAPH (4.2.6) IN THE SECOND SENTENCE AFTER THE WORDS “will have authority” INSERT THE WORDS “upon written authorization from the Owner”.**

**IN PARAGRAPH (4.2.8) DELETE THE WORD “prepare” AND SUBSTITUTE THE WORDS “assist the Owner’s Representative in preparing”.**

**IN PARAGRAPH (4.2.9) DELETE THE WORD “Architect” AND SUBSTITUTE WORDS “Owner’s Representative, assisted by the Architect”.**

**IN PARAGRAPH (4.2.11) IN THE FIRST SENTENCE DELETE THE WORDS “and decide”.**

**IN PARAGRAPH (4.2.12) IN THE FIRST SENTENCE DELETE THE WORD “and decisions”.**

**IN PARAGRAPH (4.2.12) IN THE SECOND SENTENCE DELETE THE WORDS “and initial decisions” AND “or decisions”.**

**ADD PARAGRAPH TO SECTION (4.2):**

**4.2.15** Notwithstanding any other provision of this Agreement to the contrary, the Architect shall have no authority to order or approve any material deviation from the Contract Documents, whether or not such deviation affects the Contract Sum or other Substantial Completion Date (as defined herein). In the event any such deviation is sought, prior written approval from the Owner’s Representative and the Owner must be obtained. The Architect may decide quality issues and may approve non-material deviations from the Contract Documents.

#### ARTICLE 5: SUBCONTRACTORS

##### 5.2 – Award of Subcontracts and Other Contracts for Portions of the Work

**IN PARAGRAPH (5.2.1) DELETE THE FIRST SENTENCE AND SUBSTITUTE:**

“The subcontractors/suppliers listed by the Contractor on the Subcontractor/Supplier List (submitted with the Bid) shall not be changed without the written consent of the Owner.”

**IN PARAGRAPH (5.2.1) IN THE SECOND SENTENCE DELETE THE WORDS “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

**IN PARAGRAPH (5.2.1) IN THE LAST SENTENCE DELETE THE WORDS “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

## ARTICLE 6: CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS

### 6.2 – Mutual Responsibility

**IN PARAGRAPH (6.2.2) BEFORE THE WORD “Architect” ADD THE WORDS “Owner and”.**

### 6.3 – Owner’s Right to Clean Up

**IN PARAGRAPH (6.3) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORD “Owner”.**

## ARTICLE 7: CHANGES IN THE WORK

### 7.2 – Change Orders

**IN PARAGRAPH (7.2.1) DELETE THE WORDS “the Architect” AND SUBSTITUTE THE WORDS “the Owner’s Representative”.**

**ADD THE FOLLOWING PARAGRAPHS TO SECTION (7.2):**

**7.2.2** A Change Order shall include all of the Contractor’s costs associated therewith.

**7.2.3** The Contractor shall not accept any request for a Change Order from any person other than the Owner and may not perform any work asserted to constitute a change in the Work until the Owner has approved the Change Order in writing, unless the Owner authorizes the Contractor, in writing, to proceed with a change prior to the Owner’s final approval. Notwithstanding anything to the contrary herein, the Contractor shall not charge for overtime services in the performance of any Change Order Work, unless the Owner has specifically authorized overtime in writing. Owner may competitively bid changes in the Work and Contractor, Subcontractor and suppliers shall provide Owner with all documents Owner requests to facilitate such competitive bidding of changes in the Work.

**7.2.4** There shall be no change in the Work, whether an alteration or addition to the Contract Sum or to any amounts due under the Contract Documents or to a change in the Contract Time, unless and until such alteration or addition has been authorized by a written Change Order executed and issued in accordance and compliance with the requirements with this Article 7 or by written authorization to proceed with such change in the Work signed by the Owner or as otherwise provided pursuant to the Contract Documents. The requirements set forth in this Paragraph 7.2.4 are of the essence. No claim that the Owner has been unjustly enriched by any alteration or addition to the Work, whether or not any such unjust enrichment to the Work or to the Owner in fact exists, shall form the basis of any claim for an increase in any amount due under the Contract Documents or a change in the Contract Time, and the terms of a fully-executed Change Order shall be conclusive.

### 7.3 – Construction Change Directives

**IN PARAGRAPH (7.3.1) DELETE THE WORDS “the Architect” AND SUBSTITUTE THE WORDS “the Owner’s Representative”.**

**IN PARAGRAPH (7.3.4) DELETE THE WORD “determine” AND SUBSTITUTE THE WORD “recommend”.**

**IN PARAGRAPH (7.3.6) DELETE THE WORD “Architect” ADD SUBSTITUTE THE WORDS “Owner’s Representative”.**

**IN PARAGRAPH (7.3.8) IN THE FIRST SENTENCE AFTER THE WORD “Architect” ADD THE WORDS “and the Owner’s Representative”.**

**IN PARAGRAPH (7.3.9) DELETE THE WORDS “Architect” AND “Architect’s” AND SUBSTITUTE THE WORDS “Owner’s Representative” and “Owner’s Representative’s”.**

**IN PARAGRAPH (7.3.10) DELETE THE WORD “determination” AND SUBSTITUTE THE WORD “recommendation”.**

## ARTICLE 8: TIME

### 8.1 - Definitions

**IN PARAGRAPH (8.1.3) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

### 8.2 – Progress and Completion

**ADD THE FOLLOWING PARAGRAPHS TO SECTION (8.2) .**

**8.2.4** All work shall be "Substantially Complete" as required by the **Instructions to Bidders** and the **Agreement Between Owner and Contractor**.

**8.2.5** It is further agreed that said completion schedule is reasonable, and the Contractor shall prosecute said work regularly, diligently and continuously at such rate of progress as will insure full completion thereof within the time specified.

**8.2.6** Provided, however, the following exceptions:

- .1** Any preference, priority or allocation order duly issued by the United States Government.
- .2** Any unforeseeable cause beyond the control and without the fault or negligence of the Contractor, including acts of God, or of a public enemy, acts of the Owner, acts of another Contractor in performance of a separate contract with the Owner, fire, floods, epidemics, quarantine restrictions, strikes, freight embargoes and unusually severe weather. The criteria on which the unusually severe weather shall be based is the average precipitation/temperatures received in the project area, as recorded over a period of the last five (5) years at the local area United States Weather Station. Any extension of time due to unusually severe weather must be requested by the Contractor on the basis of documented records of the actual precipitation/temperatures during the contract time period, compared with the normal/average for the area. Also, the criteria shall include the number of excessive precipitation or extreme cold days (i.e., days in which the temperature would adversely affect the type of work being

constructed) over the same period and whether or not the Contractor's force worked on said days or stage of construction was affected.

.3 Any delays of subcontractors occasioned by any of the causes specified in this paragraph.

8.2.7 Provided further that the Contractor shall, within seven (7) days from the beginning of any such delay during the performance of the Contract, notify the Owner's Representative in writing of the alleged cause of such delay.

### 8.3 – Delays and Extensions of Time

**IN PARAGRAPH (8.3.1) DELETE THE WORDS “and binding dispute resolution”.**

**IN PARAGRAPH (8.3.1) DELETE THE WORD “determine” AND SUBSTITUTE THE WORD “recommend”.**

## ARTICLE 9: PAYMENTS AND COMPLETION

### 9.2 – Schedule of Values

**DELETE PARAGRAPH (9.2) AND SUBSTITUTE THE FOLLOWING UNDER (9.2):**

“Where the Contract is based on a stipulated sum or Guaranteed Maximum Price, the Contractor shall submit a schedule of values to the Owner’s Representative before the first Application for Payment, allocating the entire Contract Sum to the Various portions of the Work. The schedule of values shall be prepared in the form, and supported by the data to substantiate its accuracy, required by the Architect and Owner’s Representative. This schedule, unless objected to by the Architect and Owner’s Representative, shall be used as a basis for reviewing the Contractor’s Applications for Payment. Any changes to the schedule of values shall be submitted to the Architect and Owner’s Representative and supported by such data to substantiate its accuracy as the Architect and Owner’s Representative may require, and unless objected to by the Architect and Owner’s Representative, shall be used as a basis for reviewing the Contractor’s subsequent Applications for Payment.”

### 9.3 – Applications for Payments

**IN THE FIRST SENTENCE OF (9.3.1), CHANGE "ten" TO "thirty”.**

**IN PARAGRAPH (9.3.1) IN THE FIRST AND SECOND SENTENCE DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

**ADD THE FOLLOWING TO THE END OF PARAGRAPH (9.3.1):**

“Payment requests shall consist of AIA Documents #702 "Application and Certificate for Payment"; AIA #703 "Continuation Sheet"; Contractors Affidavit of Payment to Subcontractors and Suppliers; Certified Payroll Form; EEO Documents; and Waivers of Lien. (Waivers of Lien are required from the general contractor in the full amount of the current payment application, and from all subcontractors, suppliers, or workers who provide more than \$10,000 of project material/labor of the Work. The waiver shall be in the amount(s) listed in the Contractor's Affidavit.) For final payment, the general contractor shall also provide a Waiver of Lien in the full amount of the contract price.

**The Waiver of Lien and Contractor Affidavit forms used shall be the Peoria Park District's standard form(s): 1) "Final Waiver of Lien" (for general contractors), 2) "Waiver of Lien - General Contractor's Partial To Cover Only Certain Payments", 3) "Sub-Contractor's Final Waiver of Lien", 4)**

"Waiver of Lien - Sub-Contractor's Partial To Cover Only Certain Payments, and 5) "Contractor's Affidavit". (These forms are included in the Project Manual, and are the required Waiver of Lien forms for the project.)

(If the Contractor is unable to provide the required sub-contractor waiver at the time the application for payment is submitted (preferred method) alternatively, it may be provided at the time that payment is delivered by the District. If the sub-contractor waiver(s) still cannot be provided at that time, the District will provide "two-party" checks in which the Contractor and the sub-contractor are named jointly as payees.)

Format of AIA #703 shall follow that of "Schedule of Values". All payment requests shall reflect retainage in the amount of 10% of completed work."

**IN PARAGRAPH (9.3.1.1) DELETE THE WORDS "or by interim determination of the Architect, but not yet included in Change Orders".**

**ADD THE FOLLOWING SUB-PARAGRAPHS TO PARAGRAPH (9.3.1):**

**9.3.1.3** Upon Substantial Completion, the Owner will pay 95% percent of the amount due to the Contractor on account.

**9.3.1.4** Monthly progress payments will be made by the Owner on projects lasting more than sixty days (from award of the bid to the Substantial Completion date given in the Supplementary Instructions to Bidders).

**ADD THE FOLLOWING SUB-PARAGRAPHS TO PARAGRAPH (9.3.2):**

**9.3.2.1** Material stored on site will be considered for payment only when a Schedule of Stored Materials with appropriate values accompany the payment request as an attachment.

**9.3.2.2** All material and work covered by partial payments made shall thereupon become the sole property of the Owner, but this provision shall not be construed as relieving the Contractor from the sole responsibility for the care and protection of material and work upon which payments have been made or the restoration of any damaged work, or as a waiver of the contract.

#### 9.4 – Certificates for Payment

**IN PARAGRAPH (9.4.1) DELETE THE WORDS "Architect" AND "Architect's" AND SUBSTITUTE THE WORDS "Owner's Representative" AND "Owner's Representative's".**

**IN PARAGRAPH (9.4.1) DELETE THE PHRASE "with a copy to the Contractor".**

**IN THE FIRST SENTENCE OF PARAGRAPH (9.4.2) DELETE THE WORD "Architect" AND SUBSTITUTE THE WORDS "Owner's Representative".**

**IN THE FIRST SENTENCE OF PARAGRAPH (9.4.2) AFTER THE WORDS "Architect's" ADD THE WORDS "and Owner's Representative's".**

**IN THE THIRD SENTENCE OF PARAGRAPH (9.4.2) DELETE THE WORDS "Architect has" AND SUBSTITUTE THE WORDS "Owner's Representative and Architect have".**

#### 9.5 – Decisions to Withhold Certification

**IN PARAGRAPH (9.5.1) DELETE THE WORDS “Architect” AND “Architect’s” AND SUBSTITUTE THE WORDS “Owner’s Representative AND “Owner’s Representative’s”.**

**IN PARAGRAPH (9.5.2) DELETE THE WORD “Architect’s” AND SUBSTITUTE THE WORDS “Owner’s Representative’s”.**

**IN PARAGRAPH (9.5.4) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

#### 9.6 – Progress Payments

**IN PARAGRAPHS (9.6.1), (9.6.3), AND (9.6.4) DELETE THE WORDS “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

#### 9.7 – Failure of Payment

**IN PARAGRAPH (9.7) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

**IN PARAGRAPH (9.7) DELETE THE WORDS “or awarded by binding dispute resolution”.**

#### 9.8 – Substantial Completion

**IN PARAGRAPH (9.8.2) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

**IN THE FIRST SENTENCE OF PARAGRAPH (9.8.3) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative assisted by the Architect”.**

**IN THE SECOND AND THIRD SENTENCES OF PARAGRAPH (9.8.3) DELETE THE WORDS “Architect’s” and “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative’s” and “Owner’s Representative”.**

**IN PARAGRAPH (9.8.4) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

#### 9.9 – Partial Occupancy or Use

**IN PARAGRAPH (9.9.1) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

#### 9.10 – Final Completion and Final Payment

**IN PARAGRAPH (9.10.1) IN THE FIRST AND SECOND SENTENCE AFTER THE FIRST TWO APPEARANCES OF THE WORD ‘Architect’ ADD THE WORDS “and Owner’s Representative”.**

**IN PARAGRAPH (9.10.1) DELETE THE THIRD AND FOURTH APPEARANCES OF THE WORD “Architect” and “Architect’s” AND SUBSTITUTE THE WORDS “Owner’s Representative” and “Owner’s Representative’s”.**

**IN PARAGRAPH (9.10.1) AFTER THE FIFTH APPEARANCE OF THE WORD “Architect’s” ADD THE WORDS “and Owner’s Representative’s”.**

**IN THE LAST SENTENCE OF PARAGRAPH (9.10.1) DELETE THE WORD “Architect’s” AND SUBSTITUTE THE WORDS “Owner’s Representative’s”.**

**IN PARAGRAPH (9.10.2) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORD “Owner’s Representative”.**

**ADD THE FOLLOWING SUB-PARAGRAPH TO PARAGRAPH (9.10.2):**

**9.10.2.1** When all items including items noted within Division 10000 General Requirements are found to be complete and in conformance with the Contract Documents, a final payment will be issued.

**IN PARAGRAPH (9.10.3) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

## ARTICLE 11: INSURANCE AND BONDS

### 11.1 – Contractor’s Insurance and Bonds

**IN PARAGRAPH (11.1.1) IN THE FIRST SENTENCE DELETE THE WORDS “the Agreement or elsewhere in the Contract Documents” AND SUBSTITUTE THE FOLLOWING WORDS “Attachment A – Project Specific Insurance Requirements” (which is included in the last section of the Project Manual and the requirements therein shall be made part of the Contract Documents). In addition, if any of the work occurs within fifty feet of an active railroad line and the Contractor’s general liability coverages provide for exclusions of coverage when working on or near a railroad, the Contractor shall provide a separate Railroad Protective Liability Insurance Policy naming the railroad as the insured party, with the coverage limits required by that railroad.”**

**IN PARAGRAPH (11.1.1) IN THE LAST SENTENCE, DELETE THE WORDS “the Contract Documents” AND ADD THE WORDS “Attachment A”.**

**AT THE END OF PARAGRAPH (11.1.2) ADD THE FOLLOWING:**

“The Contractor shall furnish a Performance Bond and a separate Labor and Material Payment Bond, each for one hundred percent (100%) of the Contract Sum. Form of these bonds shall be as provided by the Owner in the Project Manual and no other form will be accepted. The Surety shall be authorized to do business in the State of Illinois and be acceptable to the Owner.”

**ADD THE FOLLOWING SUB-PARAGRAPHS TO PARAGRAPH (11.1)**

**11.1.5** The Contractor may, at his option, furnish Owner’s Protective Liability Insurance in lieu of naming the Owner Additional Insured on the Contractor’s policy, as required above. This insurance shall protect the Owner from claims as set forth in Paragraph 11.1.1 of the General Conditions, and to the limits required herein, as shown in “Attachment A”.

**11.1.6** The Contractor shall furnish two copies of each of the required Certificates or Endorsements for each copy of the Agreement which shall specifically set forth evidence of all coverage required by the Contract Documents. The form of the Certificate(s) or Endorsement(s) shall be those as required in “Attachment A”. The Contractor shall also furnish to the Owner copies of any endorsements which limit coverage, or are subsequently issued amending coverage or limits of coverage.

11.2 – Owner’s Insurance

**IN PARAGRAPH (11.2.1) DELETE THE FIRST AND SECOND SENTENCE.**

**ADD THE FOLLOWING TO PARAGRAPH (11.2.1) “If the work of the Project is being completed by one general or prime contractor rather than multiple prime contractors, the Contractor shall purchase and maintain property insurance upon the entire Work at the site to the full replacement value thereof. Such insurance shall be in a company or companies against which the Owner has no reasonable objection. This insurance shall include the interests of the Owner, the Contractor, Subcontractors and Sub-subcontractors in the Work.”**

**DELETE PARAGRAPHS (11.2.2) AND (11.2.3) IN THEIR ENTIRETY.**

11.3 – Waiver of Subrogation

**DELETE PARAGRAPHS (11.3.1) AND (11.3.2) IN THEIR ENTIRETY.**

11.4 – Loss of Use, Business Interruption, and Delay in Completion Insurance

**DELETE PARAGRAPH (11.4) IN ITS ENTIRETY:**

11.5 – Adjustment and Settlement of Insured Loss

**DELETE PARAGRAPHS (11.5.1) AND (11.5.2) IN THEIR ENTIRETY.**

ARTICLE 12: UNCOVERING AND CORRECTION OF WORK

12.1 – Uncovering of Work

**IN PARAGRAPH (12.1.1) DELETE THE WORD “Architect’s” AND SUBSTITUTE WORDS “Owner’s Representative’s and Architect’s”.**

**IN PARAGRAPH (12.1.1) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

**IN PARAGRAPH (12.1.2) AFTER THE WORD “Architect” ADD THE WORDS “and Owner’s Representative”.**

12.2 – Correction of Work

**IN PARAGRAPH (12.2.1) AFTER THE WORD “Architect” ADD THE WORDS “and Owner’s Representative”.**

ARTICLE 13: MISCELLANEOUS PROVISIONS

13.4 – Tests and Inspections

**IN PARAGRAPH (13.4.4) AFTER THE WORD “Architect” ADD THE WORDS “and Owner’s Representative”.**

ARTICLE 14: TERMINATION OR SUSPENSION OF THE CONTRACT

14.1 – Termination by the Contractor

**IN SUB-PARAGRAPH (14.1.1.3) DELETE THE WORD “Architect” AND SUBSTITUTE THE WORDS “Owner’s Representative”.**

14.2 – Termination by the Owner for Cause

**IN PARAGRAPH (14.2.2) DELETE THE PHRASE “, upon certification by the Architect that sufficient cause exists to justify such action,”.**

**IN PARAGRAPH (14.2.4) DELETE THE LAST SENTENCE AND ADD THE FOLLOWING “Upon application, the obligation for payment of the amount to be paid to the Contractor or Owner, as the case may be, shall survive termination of the Contract.”**

14.4 – Termination by the Owner for Convenience

**DELETE PARAGRAPH (14.4.3) IN ITS ENTIRETY AND SUBSTITUTE UNDER (14.4.3):**

“In case of such termination for the Owner’s convenience, the Contractor shall be entitled to receive payment for Work executed, and costs incurred by reason of such termination. In no event, however, will such amounts exceed the Contract Sum reduced by the amount of prior payments except for increases pursuant to the claims procedure in the Contract Documents. Subcontracts, subsubcontracts, and purchase orders will contain appropriate provisions for termination for convenience under this Paragraph 14.4.”

ARTICLE 15: CLAIMS AND DISPUTES

15.1 – Claims

**IN THE FIRST SENTENCE OF PARAGRAPH (15.1.2) DELETE “requirements of the binding dispute”.**

**IN PARAGRAPH (15.1.3.1) DELETE “Initial Decision Maker” AND SUBSTITUTE “Initial Recommendation Maker”**

**DELETE THE SECOND SENTENCE IN PARAGRAPH (15.1.3.2) IN ITS ENTIRETY.**

**DELETE PARAGRAPH (15.1.4.2) IN ITS ENTIRETY AND SUBSTITUTE THE FOLLOWING PARAGRAPH (15.1.4.2):**

“The contract Sum and Contract Time may be adjusted in accordance with the Initial Recommendation Maker’s recommendation, subject to the right of either party to proceed in accordance with this Article 15. The Owner’s Representative will issue Certificates for Payment.”

**DELETE (15.1.7) IN ITS ENTIRETY.**

15.2 – Initial Decision

**IN PARAGRAPH (15.2) DELETE IN THE HEADING “Initial Decision” AND SUBSTITUTE “Initial Recommendation”.**

**DELETE PARAGRAPH (15.2.1) IN ITS ENTIRETY AND SUBSTITUTE THE FOLLOWING PARAGRAPH (15.2.1):**

“Claims, excluding those where the condition giving rise to the Claim is first discovered after expiration of the period for correction of the Work set forth in Section 12.2.2 or arising under Sections 10.3 10.4, and 11.5, shall be referred to the Initial Recommendation Maker for initial recommendation. The Architect

will serve as the Initial Recommendation Maker, unless otherwise indicated in the Agreement. Except for those Claims excluded by this Section 15.2.1, an initial recommendation shall be required as a condition precedent to mediation of any Claim. If an initial recommendation has not been rendered within 30 days after the Claim has been referred to the Initial Recommendation Maker, the party asserting the Claim may demand mediation without a decision having been rendered. “

**DELETE PARAGRAPH (15.2.2) IN ITS ENTIRETY AND SUBSTITUTE THE FOLLOWING PARAGRAPH (15.2.2):**

“The Initial Recommendation Maker will review Claims and within ten days of the receipt of a Claim take one or more of the following actions: (1) request additional supporting data from the claimant or a response with supporting data from the other party, (2) recommend rejecting the Claim in whole or in part, (3) recommend approving the Claim, (4) suggest a compromise, or (5) advise the parties that the Initial Recommendation Maker is unable to recommend a resolution of the Claim if the Initial Recommendation Maker lacks sufficient information to evaluate the merits of the Claim or if the Initial Recommendation Maker concludes that, in the Initial Recommendation Maker’s sole discretion, it would be inappropriate for the Initial Recommendation Maker to make recommendation on the Claim.”

**IN PARAGRAPH (15.2.3) DELETE “Initial Decision Maker” AND SUBSTITUTE “Initial Recommendation Maker”.**

**IN PARAGRAPH (15.2.3) IN THE FIRST SENTENCE, DELETE “rendering a decision” AND SUBSTITUTE “rendering a recommendation”.**

**IN PARAGRAPH (15.2.4) DELETE “Initial Decision Maker” AND SUBSTITUTE “Initial Recommendation Maker”.**

**IN PARAGRAPH (15.2.4) DELETE THE LAST SENTENCE AND SUBSTITUTE THE FOLLOWING “Upon receipt of the response or supporting data, if any, the Initial Recommendation Maker will provide a recommendation regarding the Claim in accordance with Paragraph 15.2.2.”**

**DELETE PARAGRAPH (15.2.5) IN ITS ENTIRETY.**

**DELETE PARAGRAPH (15.2.6.1) IN ITS ENTIRETY.**

### 15.3 – Mediation

**IN PARAGRAPH (15.3.1) DELETE “as a condition precedent to binding dispute resolution”.**

**IN PARAGRAPH (15.3.2) DELETE THE THIRD SENTENCE IN ITS ENTIRETY AND SUBSTITUTE THE FOLLOWING SENTENCE “The request may be made concurrently with the filing of legal or equitable proceedings but, in such event, mediation shall proceed in advance of legal or equitable proceedings which shall be stayed pending mediation for a period of 60 days from the date of filing, unless stayed for a longer period by agreement of the parties or court order.”**

**IN PARAGRAPH (15.3.2) DELETE THE LAST SENTENCE IN ITS ENTIRETY.**

**DELETE PARAGRAPH (15.3.3) IN ITS ENTIRETY.**

**IN PARAGRAPH (15.3.4) DELETE THE FIRST SENTENCE IN ITS ENTIRETY.**

### 15.4 – Arbitration

**DELETE PARAGRAPHS (15.4.1), (15.4.1.1), (15.4.2), (15.4.3), (15.4.4.1), (15.4.4.2), AND (15.4.4.3) IN THEIR ENTIRETY.**

**ADD THE FOLLOWING ARTICLE 16: LABOR, SAFETY AND WAGE STANDARDS TO THE GENERAL CONDITIONS OF THE CONTRACT:**

**ARTICLE 16  
LABOR, WAGE, SAFETY, AND OTHER STANDARDS**

**16.1 LABOR STANDARDS.** All employers shall comply with the Employment of Illinois Workers on Public Works Act [30 ILCS 570/1 to 570/7].

**16.2 WAGE STANDARDS.**

**16.2.1 PREVAILING WAGE ACT:** Wages and benefits to employees shall comply with all Federal and State of Illinois statutes pertaining to public works projects and specifically: Wages of Employees on Public Works [820 ILCS 130/1 - 12].

**16.2.2** Not less than the prevailing rate of wages plus benefits as determined by the Department of Labor shall be paid to all laborers, workers and mechanics performing work under this contract. All contractor's bonds shall include a provision as will guarantee the faithful performance of such prevailing wage clause as provided by this bid specification or contract.

**16.2.3** The terms "general prevailing rate of hourly wages", "general prevailing rate of wages" or "prevailing rate of wages" when used in this Act mean the hourly cash wages plus fringe benefits for training and apprenticeship programs approved by the U.S. Department of Labor, Bureau of Apprenticeship and Training, health and welfare, insurance, vacations and pensions paid generally, in the locality in which the work is being performed, to employees engaged in work of a similar character on public works.

**16.2.4 PREVAILING WAGE ACT/FOIA**  
Contractors and subcontractors shall submit proof to the Park District of certified payroll submission to the Illinois Department of Labor on a monthly basis in compliance with the Illinois Prevailing Wage Act. These records will be kept by the Park District for three years and may be reviewed by others through the Freedom of Information Act (FOIA). The Park District will exclude employee's address, telephone number, and social security number from public inspection.

**16.3 SAFETY STANDARDS.**

**16.3.1 PROTECTION OF PERSONS AND PROPERTY:** The Contractor and his subcontractors shall, at all times, comply with applicable provisions of Federal, State and Local laws.

**16.3.1.1** The Contractor and his sub-contractors shall have written programs complying with Occupational Safety and Health Administration standards and/or Illinois Department of Labor requirements including, but not limited to the following: hazardous communications, hearing conservation, respirator use, confined space entry, scaffolding, ladders, ventilation, flammable and combustible liquids, and lockout/tagout. The Contractor shall submit documentation of their programs at the request of the Owner's Representative, or Occupational Safety and Health Administration and/or Illinois Department of Labor officials.

## **16.4 EQUAL EMPLOYMENT OPPORTUNITY/AFFIRMATIVE ACTION/SEXUAL HARASSMENT**

**16.4.1** During the performance of the contract, the contractor agrees to the following:

**16.4.1.1** That it will not discriminate against any employee or applicant for employment because of race, color, religion, sex, marital status, national origin or ancestry, age, physical or mental handicap unrelated to ability, or an unfavorable discharge from military service; and further that it will examine all job classifications to determine if minority persons or women are under-utilized and will take appropriate affirmative action to rectify any such under-utilization.

**16.4.1.2** That, if it hires additional employees in order to perform his contract or any portion thereof, it will determine the availability (in accordance with the Rules and Regulations of the Illinois Department of Human Rights) of minorities and women in the area(s) from which it may reasonably recruit and it will hire for each job classification for which employees are hired in such a way that minorities and women are not under-utilized.

**16.4.1.3** That, in all solicitations or advertisements for employees placed by it or on its behalf, it will state that all applicants will be afforded equal opportunity without discrimination because of race, color, religion, sex, marital status, national origin or ancestry, age, physical or mental handicap unrelated to ability or an unfavorable discharge from military service.

**16.4.1.4** That it will have a written sexual harassment policy to include at the minimum, the following:

**16.4.1.4.1** a definition of sexual harassment under the law;

**16.4.1.4.2** a description of sexual harassment utilizing examples;

**16.4.1.4.3** a formalized complaint procedure;

**16.4.1.4.4** a statement of victim's rights;

**16.4.1.4.5** directions on how to contact the Illinois Department of Human Rights. Out-of-state companies must provide directions for filing with the enforcement agency within their state. Companies that issue a standard policy for all business locations must prepare an addendum providing directions on how to contact the appropriate enforcement agency; and

**16.4.1.4.6** A recitation that there cannot be any retaliation against employees who elect to file charges.

**16.4.1.4.7** In addition, it is recommended that the employer post a copy of the sexual harassment policy in a prominent and accessible location and distribute it in a manner to assure notice to all employees on an annual basis.

**16.4.1.4.8** The Illinois Human Rights Act specifically provides that all documents may meet, but cannot exceed, the sixth-grade literacy level. Therefore, the employer's sexual harassment policy must be stated in plain language and in "laymen's terms".

- 16.4.1.5** That it will send to each labor organization or representative of workers with which it has or is bound by a collective bargaining or other agreement or understanding, a notice advising such labor organization or representative of the contractor's obligations under the Illinois Human Rights Act and the Department's Rules and Regulations. If any such labor organization or representative fails or refuses to cooperate with the contractor in its efforts to comply with such Act and Rules and Regulations, the contractor will promptly so notify the Department and the contracting agency and will recruit employees from other sources when necessary to fulfill its obligations thereunder.
- 16.4.1.6.** That it will submit reports as required by the Department's Rules and Regulations, furnish all relevant information as may from time to time be requested by the Department or the contracting agency, and in all respects comply with the Illinois Human Rights Act and the Department's Rules and Regulations.
- 16.4.1.7.** That it will permit access to all relevant books, records, accounts and work sites by personnel of the contracting agency and the Department for purposes of investigation to ascertain compliance with the Illinois Human Rights Act and the Department's Rules and Regulations.
- 16.4.1.8.** That it will include verbatim or by reference the provisions of this clause in every subcontract it awards under which any portion of the contract obligations are undertaken or assumed, so that such provisions will be binding upon such subcontractor. In the same manner as with other provisions of this contract, the contractor will be liable for compliance with applicable provisions of this clause by such subcontractors; and further it will promptly notify the contracting agency and the Department in the event any subcontractor fails or refuses to comply therewith. In addition, the contractor will not utilize any subcontractor declared by the Illinois Human Rights Commission to be ineligible for contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations.
- 16.4.2** In the event of the contractor's non-compliance with the provisions of the Illinois Human Rights Act, the contractor may be declared ineligible for future contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporation, and the contract may be cancelled or voided in whole or in part, and such other sanctions or penalties may be imposed or remedies invoked as provided by statute or regulations.

END OF SUPPLEMENTARY GENERAL CONDITIONS

## DIVISION 010000 GENERAL REQUIREMENTS

### SECTION 010000 - GENERAL

#### A. SUMMARY OF THE WORK

1. The Work covered under this Contract consists of that work described by the Invitation to Bid, the Instructions/Supplemental Instructions to Bidders, the Bid/Proposal Form, the General/Supplemental Conditions of the Contract, these General Requirements, the Plans, and the Technical Specifications.
2. The Contractor shall be responsible for all items incidental to the scope of the Work intended by the bidding documents as per A.1 above, including but not limited to, expenses incurred by the requirements of various Sections of Division 010000, unless specifically stated otherwise herein.
3. Changes to the Work as required by approved Change Orders shall be at the expense of the Owner, however, requests for additional payments made after the fact will not be considered.

#### B. OCCUPANCY BY OWNER.

1. The Owner reserves the right to occupy any portion of the project before it has been entirely completed, with the understanding that such occupancy shall in no way constitute acceptance of the work, in whole or in part, or of any work performed under the Contract, provided that such occupancy does not substantially interfere with completion of the work by the Contractor.

### SECTION 012300 – ALTERNATES

#### A. Alternates to the Bid are set forth in the Supplementary Instructions to Bidders and are listed in the Bid Form.

1. Accepted Alternates have been incorporated into the Agreement.

#### B. Bid Alternate pricing, as set forth in the Supplementary Instructions to Bidders and the Bid Form, shall be good for a minimum of 90 calendar days after the date of the Bid opening, and the Owner reserves the right to accept Alternates up to that time.

### SECTION 012600 - CHANGE ORDERS

#### A. OWNER'S REPRESENTATIVE'S FIELD ORDERS

1. From time to time during progress of the Work the Owner's Representative may issue an "Owner's Representative's Field Order" which interprets the Contract Documents or orders minor changes in the Work without change in Contract Sum or Contract Time.
2. Should the Contractor consider that a change in Contract Sum or Contract Time is required he shall submit an itemized proposal to the Owner's Representative **immediately and before proceeding with the Work**. If the proposal is found to be satisfactory and in proper order, the Field Order will be superseded by a Change Order.

#### B. PROPOSAL REQUESTS

1. From time to time during the progress of work the Owner's Representative may issue a "Proposal Request" for an itemized quotation for changes to the Work which may result in a change to the Contract Sum or Contract Time. This document **is not a Change Order** and is not a direction to proceed with the changes described therein.

#### C. CHANGE ORDERS

1. Change Orders are written documents describing changes in the Work, in the Contract Sum, in the Contract Time of Completion, or any combination thereof. Change Orders must be signed by both the Owner and the Architect/Owner's Representative prior to proceeding with the Work subject to the Change Order. **REQUESTS FOR "EXTRA'S" OR OTHER ADDITIONAL PAYMENTS OVER AND ABOVE THE CURRENT CONTRACT SUM WILL NOT BE CONSIDERED WITHOUT THE PRIOR, WRITTEN APPROVAL OF BOTH THE OWNER AND THE OWNER'S REPRESENTATIVE.**
  - a) INITIATION. Change Orders may be initiated by a "Field Order" or "Proposal Request" per paragraphs "A" and "B" above. In addition, either the Contractor or Owner (or Owner's Representative) may initiate a Change Order through:
    - 1) Discovery of a discrepancy in the Contract Documents,
    - 2) Discovery of concealed conditions or,
    - 3) Discovery, during the course of the Work, of methods of accomplishing the Work in a better or more economical manner.
  - b) PROCESSING CHANGE ORDERS.
    - 1) Change Orders will be dated and will be numbered in sequence.
    - 2) The Change Order will describe the change or changes, or will refer to the Proposal Requests or Field Orders involved.
    - 3) The Owner's Representative will issue three copies of each Change Order to the Contractor.
    - 4) The Contractor promptly shall sign all three copies and return them to the Owner's Representative.
    - 5) The Owner and Owner's Representative will retain two signed copies in their files, and will forward one signed copy to the Contractor.
  - 6) Should the Contractor disagree with the stipulated change in Contract Sum or change in Contract Time of Completion, or both:
    - i) The Contractor promptly shall return all three of the Change Orders, unsigned by him, to the Owner's Representative with a letter signed by the Contractor stating the reason or reasons for the Contractor's disagreement.
    - ii) The Contractor's disagreement with the Change Order shall not in any way relieve the Contractor of his responsibility to proceed with the change as ordered and to seek settlement of the dispute under pertinent provisions of the Contract Documents.

### SECTION 012900 – PAYMENT PROCEDURES

#### A. SCHEDULE OF VALUES

1. Prior to the start of construction, submit a proposed Schedule of Values to the Owner's Representative which shows a detailed breakdown of the agreed Contract Sum showing values allocated to each of the various parts of the Work, as specified herein and in other provisions of the Contract Documents.
  - a) The Schedule of Values is required to be compatible (in the same format) with the Application for Payment "Continuation Sheet", AIA G703.
2. If not requested to submit additional data or to modify the submitted Schedule of Values within ten (10) days of submittal, the initially submitted Schedule shall be deemed approved.

**B. APPLICATIONS FOR PAYMENT**

1. Progress payments will be made only if specifically called for in the Agreement. In all other cases, the Contractor may submit an Application for Payment (3 copies) upon Substantial Completion (95% of the Contract Sum), with the balance of the Contract Sum to be paid at Final Completion.
  - a) **Article 9 of the Supplementary General Conditions defines the documentation required for each payment request.**
  - b) Applications for payment shall be delivered to the Owner's Project Manager at:

Department of Planning, Design, and Construction  
 Peoria Park District  
 Bradley Park Equipment Service  
 1314 N. Park Road  
 Peoria, Illinois 61604

**SECTION 013100 - PROJECT MEETINGS**

**A. PRECONSTRUCTION CONFERENCE**

1. Conduct a preconstruction conference prior to the start of the Work, at the location of the Work. Provide attendance by the designated personnel of the Contractor, including Sub-contractor's and/or suppliers of major components of the Work, if requested by the Owner's Representative.
  - a) **AGENDA.** Discuss items of significance that could affect progress including such topics as:
    - 1) Tentative construction schedule.
    - 2) Critical Work sequencing.
    - 3) Designation of responsible personnel.
    - 4) Procedures for processing field decisions and Change Orders.
    - 5) Procedures for processing Applications for Payment.
    - 6) Distribution of Contract Documents.
    - 7) Submittal of Shop Drawings, Product Data and Samples.
    - 8) Preparation of record documents.
    - 9) Use of the premises.
    - 10) Office, Work and storage areas.
    - 11) Equipment deliveries and priorities.
    - 12) Safety procedures.
    - 13) First aid.
    - 14) Security.
    - 15) Housekeeping.
    - 16) Working hours.
    - 17) Permits and Permitting Agency Requirements

**B. PROJECT MEETINGS**

1. Project Meetings will be held per the schedule determined at the Preconstruction Conference, or as needed for proper coordination and administration of the project.
  - a) **AGENDA**
    - 1) Review and correct or approve minutes of the previous progress meeting.
    - 2) Review progress of the Work since last meeting, including status of submittals for approval.
    - 3) Identify problems which impede planned progress.
    - 4) Develop corrective measures and procedures to regain planned schedule.
    - 5) Complete other current business.

**C. REPORTING**

1. Distribute copies of the minutes of each meeting to each party present, and to other parties who should have been present, no later than three business days after each meeting.

**SECTION 013300 - SUBMITTALS**

- A. Requirements for shop drawings, samples, mock-ups, product data, etc., relative to specific elements or components of the work are called out in the various sections of the Technical Specifications.
  1. Submit items to allow for Owner's Representative's review and approval, potential re-submission if full approval is not given, ordering, delivery, fabrication time, etc., so as to allow the Work to proceed in a timely manner and in conformance with the project schedule.
- B. **OTHER CONTRACTOR SUBMITTALS**
  1. Unless otherwise modified the Contractor shall also submit:
    - a) A "bar chart" type proposed construction schedule, within ten days after award of the Bid.
    - b) Other submittals as required by other section of Division 010000.
- C. Submission of the required Bonds and Certificate of Insurance are to be made prior to the Owner's issuance of a Notice to Proceed.

**SECTION 014000 – QUALITY/REGULATORY REQUIREMENTS**

- A. GENERAL: Contractors shall comply with all laws, rules and regulations governing the work.
  - 1. When Contractor observes that contract documents are at variance with specified codes, notify Owner's Representative in writing immediately. Owner's Representative will issue all changes in accord with General Conditions.
  - 2. When Contractor performs any work knowing or having reason to know that the work is contrary to such laws, rules and regulations and fails to so notify the Owner's Representative, Contractor shall pay all costs arising therefrom. However, it will not be the Contractor's primary responsibility to make certain that the contract documents are in accord with such laws, rules and regulations.
- B. SAFETY:
  - 1. Comply with all federal, state, and local laws, rules and regulations governing the installation/construction of the work.
  - 2. Develop and utilize safety program and training for workmen and sub-contractor employees.
- C. TESTING
  - 1. TESTS AND INSPECTIONS REQUIRED
    - a) Provide all tests and inspections required by governmental agencies having jurisdiction, as required by provisions of the Contract Documents and/or as specifically required by sections of the Technical Specifications.
  - 2. PAYMENT FOR TESTING
    - a) Include within the Contract Sum an amount sufficient to cover all testing, re-testing, and inspections required by the Contract documents and/or the Technical Specifications. Additionally pay for all testing and inspections required by all governmental agencies having jurisdiction.
      - 1) The Owner will pay for any testing and inspecting specifically requested by the Owner's Representative which are over and above those described in Paragraph 1.a) above.
      - 2) When initial tests (over and above those defined by 1.a) above) requested by the Owner's Representative indicate non-compliance with the Contract Documents, costs of initial tests associated with that non-compliance will be deducted by the Owner from the Contract Sum, and subsequent retesting occasioned by the non-compliance shall be performed by the same testing laboratory and the costs thereof shall be paid by the Contractor.
  - 3. WAIVER OF INSPECTION AND/OR TESTS
    - a) Specified inspections and/or tests may be waived only by the specific written approval of the Owner's Representative, and **such waivers will be expected to result in credit to the Owner equal to normal cost of such inspection and/or test.**

#### SECTION 014200 - REFERENCE STANDARDS AND DEFINITIONS

- A. Copies of Standards: Each entity engaged in construction on the Project is required to be familiar with industry standards applicable to that entity's construction activity. Copies of applicable standards are not bound with the Contract Documents.
  - 1. Where copies of standards are needed for performance of a required construction activity the Contractor shall obtain copies directly from the publication source.
  - 2. Although copies of standards needed for enforcement of requirements may be included as part of required submittals the Architect reserves the right to require the Contractor to submit additional copies as necessary for enforcement of requirements.
- B. Abbreviations and Names: Trade association names and titles of general standards are frequently abbreviated. Where such acronyms or abbreviations are used in the Specifications or other Contract Documents they mean the recognized name of the trade association standards generating organization authority having jurisdiction or other entity applicable to the context of the text provision. Refer to the Encyclopedia of Associations, published by Gale Research Co. available in most libraries.
- C. Definitions: Architect, Owner's Representative, and Owner's Project Manager
  - 1. **ARCHITECT:** The Architect shall be the person or entity designated by the Owner as the Owner's Representative and shall be identified as such in the Agreement Between Owner and Contractor, and is referred to throughout the Contract Documents as if singular in number and masculine in gender.
  - 2. **OWNER'S REPRESENTATIVE:** The duties of the Owner's Representative as listed in the Project Manual, include but are not limited to, construction phase observation and technical administration services.
    - a) **LIMITS OF AUTHORITY:** The Owner's Representative shall be authorized to provide approvals and interpretations concerning the plans, specifications and progress of the Work as bid, but is not authorized to change the scope of the Work on behalf of the Owner.
  - 3. **OWNER'S PROJECT MANAGER:** The Owner's Project Manager will represent, act on behalf of, and provide interface between the Owner and the Contractor in respect to contract administration and/or other matters which affect the scope of the Work.
    - a) Unless defined otherwise in the Project Manual, the Owner's Project Manager shall be a designated member of the Planning, Design, and Construction Division of the Peoria Park District.
    - b) The Owner's Project Manager will also be the Owner's Representative and will provide construction phase observation and technical administration services, if a consultant Architect has not been engaged to do so, by the Owner.

#### SECTION 015000 – TEMPORARY FACILITIES & CONTROLS

- A. MOBILIZATION
  - 1. Furnish all labor, tools, materials, equipment, and incidentals necessary for preparatory work.
  - 2. Provide and establish personnel, equipment, supplies, materials, offices or buildings, and other facilities necessary to work on the project.
  - 3. Demobilize all of the above and remove temporary facilities at the completion of the project.
- B. BARRIERS, PROTECTION OF SITE AND PROPERTY
  - 1. GENERAL
    - a) Owner's improvements to remain, existing utilities, as well as adjacent site improvements shall be protected from damage by barriers, guards and coverings. Damaged work shall be replaced or repaired to condition prevailing at time of signing of contract, at no additional cost to Owner.
    - b) Provide 6' high, continuous chain link or orange plastic (used materials acceptable) construction fence to prohibit unauthorized personnel or public entry from the site of the Work. (Substitutions may be considered; submit request in writing to the Owner's Representative.)
    - c) Contractor shall provide, erect and maintain additional planking, fences, protective canopies, railings, shoring, lights, warning signs, etc., as needed for the protection of adjacent property and the public.

2. LANDSCAPE PROTECTION
    - a) All live, healthy trees, shrubs, etc. on the site or on the street fronts of the site, not specified to be removed and not interfering with installation of new work required hereunder, shall be protected against injury from construction operations.
    - b) All shade trees which are to remain and which are liable to damage during the building operations, shall be properly boxed and protected from damage during the course of construction work as directed by the Park District. **No site-related work shall occur until the required tree protection (fencing, boxing, etc.) has been installed and approved by the Owner or his representative.**
      - 1) LIQUIDATED DAMAGES: The Owner reserves the right to charge the Contractor for damage to existing trees, and to deduct the charges from the amounts due the Contractor, based on the following schedule:
 

aa) Broken limbs 1" or over in diameter:	\$50 per caliper inch of limb
bb) Trenching or grading within the tree dripline or 20' from the trunk, whichever is less, of trees 4" or over in caliper diameter:	\$100 per tree/per foot within dripline, or within 20' minimum if applicable
cc) Damage to tree trunks, including "barking", nicking, gouging, etc.	\$150 per caliper inch of tree, per each injury
  3. BARRIERS/CONSTRUCTION FENCE MATERIALS
    - a) 2" open mesh chain link fence, 72" high minimum, galvanized, with appropriately sized posts; gates where indicated.
    - b) Alternate barrier fencing materials may be acceptable, however, no additional payments will be made on account of approval of alternate barrier/safety fencing materials.
    - c) Materials may be new or used, if in serviceable condition.
  4. WATCHMAN SERVICE
    - a) The Owner will not be responsible for loss due to theft or other damage which is not covered under Property Insurance. The Contractor shall make such arrangements for watchman service as he considers necessary and he shall be responsible for all loss or damage of his property, equipment, material, etc., at the site, and he shall make good such damage or loss without any additional cost to the Owner.
  5. EXISTING IMPROVEMENTS - PROTECTION
    - a) The Contractor shall be entirely responsible for all injuries to water pipes, electric conduits or cables, drains, sewers, gas mains, poles, telephones and telegraph lines, streets, pavements, sidewalks, curbs, culverts, retaining walls, building walls, foundation walls, or other structures of any kind met with during the progress of the Work, and shall be liable for damages to public or private property resulting therefrom.
- C. CONSTRUCTION ACCESS, ROADS, AND PARKING AREAS
1. CONTRACTOR'S USE OF PREMISES
    - a) The Contractor shall require that all personnel who will enter upon the Owner's property certify their awareness of and familiarity with the requirements of this Section.
  2. CONSTRUCTION ACCESS
    - a) To avoid traffic conflict with vehicles of the Owner's employees and customers, and to avoid over-loading of streets and driveways elsewhere on the Owner's property, limit the access of trucks and equipment to the route shown (IF SHOWN) on the Drawings as "Access Route". If access route is not shown on the Drawings, coordinate construction access and routes with the Owner's Project Manager.
    - b) Do not permit such vehicles to park on any street or other area of the Owner's property except in the area shown on the Drawings as "Contractor's Parking Area". If not shown on the drawings, the Contractor's Parking Area shall be as designated by the Owner's Project Manager.
    - c) Provide adequate protection for curbs and sidewalks over which trucks and equipment pass to reach the job site.
  3. SECURITY
    - a) Restrict the access of all persons entering upon the Owner's property in connection with the Work to the Access Route and to the actual site of the Work.
- D. TEMPORARY ENVIRONMENTAL CONTROLS
1. GENERAL
    - a) Provide temporary environmental controls at the site of the Work to ensure that construction operations have no harmful effects on adjacent properties and on members of the public who may come in proximity to the Work, and/or the employees of the Owner who are engaged in regular daily tasks and operations and are unable to be relocated to another work site during construction operations.
    - b) Owner reserves the right to stop the Work, at the Contractor's expense, until the Contractor provides necessary control measures for the conditions listed below; additionally, the Owner reserves the right to perform or have performed necessary control measures, should the Contractor refuse to do so at the time requested and to deduct the cost of those expenses from the amount due the Contractor.
  2. DUST CONTROL
    - a) Provide dust control materials to minimize dust from construction operations. Prevent air-borne dust from dispersing into the atmosphere.
  3. WATER CONTROL
    - a) Control surface water to prevent damage to the project, the site and adjoining properties.
      - 1) Control fill, grading, and ditching to direct surface drainage away from excavations, pits, tunnels, and other construction areas; direct drainage to proper runoff channels or storm drainage utilities.
    - b) Provide, operate and maintain hydraulic equipment of adequate capacity to control surface water.
    - c) Dispose of drainage water in a manner to prevent flooding, erosion silting, or runoff of silt or sediment or other damage to all portions of the site or to adjoining properties.
  4. RODENT CONTROL
    - a) Provide rodent control to prevent infestation of construction or storage areas.
      - 1) Use methods and materials which will not adversely affect conditions at the site or on adjoining properties.
  5. DEBRIS CONTROL
    - a) Maintain all areas free of extraneous debris, waste, and rubbish.
  6. POLLUTION CONTROL
    - a) Prevent contamination of soil, water or atmosphere by the discharge of noxious substances from construction operations.
    - b) Provide equipment and personnel, perform emergency measures to contain all spillages, and to remove contaminated soils or liquids.
      - 1) Excavate and dispose of all contaminated earth off-site. Replace with suitable compacted fill and topsoil.
    - c) Take special measures, as necessary, to prevent harmful substances from entering public waters, including lakes, streams, intermittent drainage channels, and storm or sanitary sewers.
  7. EROSION CONTROL

- a) Plan and execute construction and earthwork in a manner to control surface drainage from cuts and fills, and from borrow and waste disposal areas, to prevent erosion and sedimentation.
  - 1) Schedule the Work to minimize the areas of bare soil exposed at one time, if possible.
  - 2) Provide temporary control measures such as berms, dikes, and drains to prevent runoff of silt or sediment from the site.
  - 3) Comply with Section 015713.

**E. PROJECT IDENTIFICATION AND SIGNAGE**

- 1. GENERAL
  - a) Provide and install project identification sign, if located and/or called out on the Drawings.
- 2. SUBMITTALS
  - a) Provide shop drawing(s) of proposed sign/sign installation to Owner's Representative for approval, prior to installation
- 3. INSTALLATION
  - a) Provide project sign as detailed on Drawings
  - b) If not detailed on Drawings provide project identification sign per the following minimum requirement:
    - 1) Content
      - aa) Name of project
      - bb) Name of Owner
      - cc) Name of Architect(s) and major consultants
      - dd) Names of Contractor and major subcontractors
      - ee) Allow additional 200 characters of text explaining the project
    - 2) Construction
      - aa) Size: 4' x 8'
      - bb) Materials: Min. 5/8" AC DFPA Exterior Plywood, with (2) 4" x 4" x 12' long pressure treated post supports
      - cc) Paint: paint front and back, seal edges, provide content as approved by Owner's Representative. Conform to recognized sign painting standards in selection of paint materials. Use only professional sign painter with three years minimum experience to apply sign graphics and lettering.
    - 3) Install sign in a manner consistent with length of time of construction operations. Remove sign and fill post holes at project completion.

**F. FIELD OFFICES**

- 1. TEMPORARY FACILITIES
 

Provide and pay for temporary (new, or used if in serviceable condition) facilities and controls needed for the Work, if called out on the Drawings, which may include, but are not necessarily limited to:

  - a) Temporary utilities such as heat, water, electricity, and telephone;
  - b) Field office for the Contractor's personnel (required if shown on the Drawings; otherwise at the Contractor's option and expense).
    - 1) Conform with requirements for Engineer's Field Office Type B, as defined in Article 646.04 of the Standard Specifications for Road and Bridge Construction - Illinois Department of Transportation.
  - c) Sanitary facilities;
  - d) Enclosures such as tarpaulins, barricades, and canopies;
  - e) Temporary fencing of the construction site;
  - f) Project sign.
- 2. Comply with Federal, State, and local codes and regulations.
  - a) Maintain temporary facilities and controls in proper and safe condition throughout the progress of the work. The Contractor is responsible for conformance with all safety codes and regulations for all Work under his jurisdiction, including that of Sub-Contractors.
- 3. Locate temporary facilities as shown on the Drawings, or as approved by the Owner's Representative if not shown on the Drawings.

**SECTION 015713 – EROSION & SEDIMENT CONTROL**

**A. RELATED DOCUMENTS**

- 1. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

**B. SUMMARY**

- 1. This Section includes the following:
  - a) Site erosion and sediment control
  - b) Silt fencing
  - c) Ditch checks
  - d) Erosion control blankets
  - e) Culvert and inlet protection
  - f) Stabilized entrance
- 2. Related Sections include the following:
  - a) Division 31 – Earthwork.
  - b) Division 32 – Exterior Improvements.
- 3. Erosion and Sediment Control Statement: The Peoria Park District takes the issue of construction related erosion and sediment control extremely seriously. The Peoria Park District is a community leader in the conservation and protection of our area's natural resources. This project will be watched closely by both staff and citizens for compliance with erosion and sediment control regulations and specifications.

**C. QUALITY ASSURANCE**

- 1. Materials and methods of construction shall comply with the following standards:
  - a) Illinois Department of Transportation
  - b) City of Peoria

## D. PRODUCTS

1. Silt Fencing
  - a) Fabric for silt fencing shall consist of woven or nonwoven filaments of polypropylene, polyester, or polyethylene. Fabric shall be resistant to degradation by ultraviolet light and heat exposure. Fabric shall be rot, insect, and mildew proof, and have a high resistance to tearing.
    - 1) Fabric shall comply with the following physical properties:

aa) Grab tensile strength (lb) – ASTM D4632	200 (min)
bb) Grab elongation @ break (%) – ASTM D4632	12
cc) Burst strength (psi) – ASTM D751	250 (min)
dd) Trapezoidal tear strength (lb) – ASTM D4533	75
ee) Width (ft)	3.5 (min)
ff) Weight (oz/sq. yd) – ASTM D3776	4.0
gg) Equivalent opening size	30 (nonwoven)
hh) (EOS) sieve no. – Corps of Engrs. CS-02215	50 (woven)
2. Ditch Checks
  - a) Ditch checks will consist of silt fencing with the addition of wire reinforcement.
  - b) Wire shall be 9 gauge.
  - c) Alternate: Straw bales may be used in lieu of silt fencing
3. Posts
  - a) Posts shall be standard “T” or “U” steel posts or wood with a minimum cross section of 3 square inches. Posts shall be a minimum of 60” in length. Posts shall be driven a minimum of 24” into the ground.
4. Erosion Control Blankets
  - a) Excelsior Blanket: Excelsior blanket shall consist of a machine produced mat of wood excelsior of 80% 6” or longer fiber length. The wood from which the excelsior blanket is cut shall be properly cured to achieve adequately curled and barbed fibers.
    - 1) The blanket shall be of consistent thickness, with the fiber evenly distributed over the entire area of the blanket. The excelsior blanket shall be covered on the top side with a 90-day biodegradable extruded plastic mesh netting having an approximate minimum opening of 16 x 16 mm (5/8 x 5/8 in.) to an approximate maximum opening of 50 x 25 mm (2 x 1 in.). The netting shall be substantially adhered to the excelsior blanket by a knitting process using biodegradable thread or by an applied degradable adhesive. The netting shall be substantially adhered to the excelsior by a knitting process using biodegradable thread. The netting shall be entwined with the excelsior blanket for maximum strength and ease of handling.
    - 2) The excelsior blanket shall comply with the following:

aa) Minimum width, ± 25 mm (1 in.)	600 mm (24 in.)
bb) Minimum mass ± 10%	0.34 kg/sm (0.63 lb/sq yd)
cc) Minimum length of roll, approximately	45 m (150 ft)
    - 3) The excelsior blanket shall be smolder resistant.
5. Culvert And Inlet Protection
  - a) Culvert protection shall consist of a ditch check immediately upstream of every culvert entrance. Ditch check shall be installed to protect culvert interior from sedimentation.
  - b) Inlet protection shall consist of purpose made devices by:

Dandy Products, Inc.  
P. O. Box 1980  
Westerville, Ohio 43086-1980  
Phone: 1-800-591-2284  
Fax: 740-881-2791  
[www.dandyproducts.com](http://www.dandyproducts.com)  
[dlc@dandyproducts.com](mailto:dlc@dandyproducts.com)

or  

NILEX, Inc.  
15171 E. Fremont Drive  
Centennial, CO 80112  
Phone: 1-800-537-4241  
Fax: 303-766-1110  
[www.nilex.com](http://www.nilex.com)  
[denver@nilex.com](mailto:denver@nilex.com)
  - c) “Or Equal” substitutions may be made with prior approval of Owner’s Representative.
6. Stabilized Entrance
  - a) Stabilized entrance shall consist of coarse aggregate laid over geotextile fabric.
  - b) Dimensions: 70’ long by 14’ wide.
  - c) Geotextile Fabric: as per requirements of “silt fencing”.
  - d) Aggregate: IDOT Class CA-1, CA-2, cA-3, or CA-4.

## E. EXECUTION

1. Site Erosion And Sediment Control
  - a) Contractor is responsible for fulfilling terms of City of Peoria Erosion Control Permit and all applicable portions of the “Erosion, Sediment, and Stormwater Control Ordinance of the City of Peoria”.
  - b) Install control devices as shown on erosion control plan.
  - c) Install additional measures as needed to control erosion and sedimentation on the site.
2. Silt Fencing Installation
  - a) Install silt fencing according to details in plans. The silt fence shall be entrenched to a minimum depth of 8”.
  - b) The silt fence shall be installed on the contour, with the ends extending up-slope.
  - c) Install silt fencing before commencing site clearing work.
3. Ditch Check Installation
  - a) Install ditch checks according to details in plans.
  - b) Install ditch checks at locations shown on plans.

- c) Install additional ditch checks as needed to control erosion within drainage swales as site conditions and weather dictate.
- d) Install ditch checks immediately after swales are graded.
- 4. Erosion Control Blankets Installation
  - a) Install erosion control blankets as needed to control erosion in drainage swales and at the direction of the Owner's Representative.
  - b) Anchor stakes shall be driven at a spacing of 2 feet on center.
- 5. Culvert And Inlet Protection Installation
  - a) Install culvert protection at upstream entrances to all culverts.
  - b) Install culvert protection to intercept waterborne silt and sediment and prevent it from entering culvert pipes.
  - c) Install immediately after culvert installation.
  - d) Install inlet protection according to manufacturer's written instructions at each inlet immediately after inlet construction.
- 6. Stabilized Construction Entrance Installation
  - a) Install stabilized construction entrance and other approved measures as necessary to limit tracking of soil on to all paved surfaces.
  - b) Comply with all City of Peoria codes limiting tracking of soil on to City streets.
- 7. Maintenance
  - a) Inspect silt fences after each rainfall. Repair fencing, failures, end runs, and erosion cuts immediately.
  - b) Remove soil from silt fencing after each rainfall.
  - c) Erosion control maintenance and repair shall be considered incidental to the contract.
  - d) Tracked soil and sediment shall be removed from all paved surfaces on a daily basis.
  - e) Replace or provide new erosion and sediment control measures as needed during construction to provide protection to site and surrounding property for the entire time of construction, or until project is complete.
- 8. Close-Out
  - a) Remove silt fencing and other erosion and sediment control devices after lawn or seeding has been established.
  - b) Soil deposits remaining in place after silt fence is no longer required shall be dressed to conform to existing grade, and seeded with appropriate seed material.

## SECTION 016000 – PRODUCT REQUIREMENTS

### A. MATERIALS AND EQUIPMENT

- 1. STANDARD SPECIFICATIONS
  - a) Reference herein to known standard specifications of governmental agencies or technical societies shall refer to the latest edition of such specifications, adopted and published at date of these Specifications.
- 2. MANUFACTURED ARTICLES
  - a) All manufactured articles, materials and equipment to be incorporated in the work shall be new (unless otherwise specified) and of the quality specified and shall be used, erected, installed, connected, cleaned and conditioned as directed by and in conformity with job conditions to produce the best results obtainable.
    - 1) Field measurements for all special products and materials which requires close tolerances or fitting into other items or components of the Work shall be taken on the job by the party furnishing the materials.
- 3. QUALITY ASSURANCE
  - a) Per the Supplementary Instructions to Bidders, the Bidder by submission of a signed bid form, agrees to install products and equipment by brand and model name or names specified in the Technical Specifications, Divisions 02-35. Substitutions are allowed only in conformance to the following:
    - 1) Proprietary Specification Requirement: Where only a single product or manufacturer is named, provide the product indicated. No substitutions will be permitted.
    - 2) Semiproprietary Specification Requirement: Where two or more products or manufacturers are named, provide one of the products indicated. No substitutions will be permitted
      - aa) Where either of the two cases above prevail, and the named product is accompanied by "or approved equal" substitutions will be allowed only upon written approval of the Owner's Representative prior to submission of bids.
    - 3) Non-Proprietary Specification Requirement: When the Specifications lists products or manufacturers that are available and are accompanied by "or equal", the Contractor may propose any available product that complies with the Specifications' requirements; however, the Owner's Representative shall determine if the produced item complies with those requirements.
    - 4) Descriptive Specification Requirement: Where Specifications describe a product or assembly listing exact characteristics required, with or without use of a brand, trade, or model name, provide a product or assembly that provides the characteristics and otherwise complies with the Contract Documents.
    - 5) Performance Specification Requirement: Where Specifications require compliance with performance requirements, provide products or assembly that comply with these requirements and are recommended by the manufacturer for the application indicated.
    - 6) Compliance with Standards, Codes, and Regulations: Where the Specifications only require compliance with an imposed code, standard, or regulation, select a product that complies with the standard, code, or regulation specified.
  - b) VISUAL MATCHING AND SELECTION. Where the Specifications require matching an established sample or call for "as selected", the Owner's Representative's decision will be final on whether a proposed product matches satisfactorily.

### B. STORAGE AND PROTECTION

- 1. GENERAL
  - a) Contractor shall provide and maintain:
    - 1) Storage for materials and equipment to be installed in Project.
    - 2) Protection and security for stored materials and equipment, on and off site.
    - 3) Protection of existing on-site elements to remain.
    - 4) Protection of adjacent properties improvements
- 2. METHODS
  - a) Store off grade and cover with impervious material all moisture or water vulnerable materials.
  - b) Store finished products and equipment in an enclosed building, on or off site.
  - c) Maintain integrity of shipping cartons until ready for installation.
  - d) Provide separate storage for combustible and non-combustible products.

- e) Follow storage recommendations of product and equipment manufacturers.
- f) Other methods shall be subject to Owner's prior written approval.

3. The Contractor shall maintain an emergency phone number where a contact person can be notified at any time, Sundays and holidays included, of an emergency condition due to the work which requires immediate repair or protection.

C. SUBSTITUTIONS

- 1. See "SECTION 016000 – A. MATERIALS AND EQUIPMENT" for requirements pertaining to substitution of specified materials, products, equipment, etc.
- 2. Contractor may propose substitute materials, products, equipment, etc., after award of the Bid; however, such proposals are expected to result in a cost savings to the Owner and/or higher quality Work at no additional cost to the Owner.

D. WARRANTIES AND BONDS

1. GENERAL

- a) This Section specifies general administrative and procedural requirements for warranties and bonds required by the Contract Documents, including manufacturer's standard warranties on products and special warranties.
- b) Warranties for the Work and products and installations of each Contractor shall be one (1) year unless specified otherwise in the individual Sections of Divisions 02 through 35.
- c) Disclaimers and Limitations:
  - 1) Manufacturer's disclaimers and limitations on product warranties do not relieve the Contractor of the warranty on the Work that incorporates the products, nor does it relieve suppliers, manufacturers, and Contractors required to countersign special warranties with the Contractor.
  - 2) The responsibility of the Contractor in respect to the required warranties shall not be relieved or limited in any way by the failure of installed components, equipment, materials, etc., due to naturally occurring and/or re-occurring conditions at the site or area of the Work including, but not limited to:
    - aa) ground and soil conditions, especially as related to frost heave;
    - bb) high wind velocities (except those exceeding velocities normally used for calculating wind loading at the site of the Work);
    - cc) rain and water damage (unless caused by winds exceeding normal design limits);
    - dd) ice/snow loading on structures
    - ee) and other naturally occurring or re-occurring site conditions
  - 3) The Contractor shall notify the Owner's Representative, prior to the award of the contract, of any part or component of the Work that is, in his opinion, not designed to accommodate the existing, naturally occurring, or re-occurring conditions of the site, and whether or not a change in the proposed methods of construction, types of equipment, etc., will affect the bid price.
    - aa) Should the proposed change in construction methods, equipment type, etc., result in additional expense, the Owner reserves the right to request proposals from the other bidders and to make award the contract based on the bid amount which includes the proposed change.

2. WARRANTY REQUIREMENTS

- a) Related Damages and Losses: When correcting warranted Work that has failed, remove and replace other Work that has been damaged as a result of such failure or that must be removed and replaced to provide access for correction of warranted Work.
- b) Reinstatement of Warranty: When Work covered by a warranty has failed and been corrected by replacement or rebuilding, reinstate the warranty by written endorsement. The reinstated warranty shall be equal to the original warranty with an equitable adjustment for depreciation.
- c) Replacement cost: Upon determination that Work covered by a warranty has failed, replace or rebuild the Work to an acceptable condition complying with requirements of the Contract Documents. The Contractor is responsible for the cost of replacing or rebuilding defective Work regardless of whether the Owner has benefited from use of the Work through a portion of its anticipated useful service life.
- d) Owner's Recourse: Written warranties made to the Owner are in addition to implied warranties, and shall not limit the duties, obligations, rights and remedies otherwise available under the law, nor shall warranty periods be interpreted as limitations on time in which the Owner can enforce such other duties, obligations, rights or remedies.
  - aa) Rejection of Warranties: The Owner reserves the rights to reject warranties and to limit selections to products with warranties not in conflict with requirements of the Contract Documents.
- e) The Owner reserves the right to refuse to accept Work for the Project where a special warranty, certification, or similar commitment is required on such Work or part of the Work, until evidence is presented that entities required to countersign such commitments are willing to do so.
- f) For specific warranty requirements related to landscape materials, refer to the applicable Section.

3. SUBMITTALS

- a) Submit written warranties to the Owner's Representative prior to the date certified for Substantial Completion. If the Owner's Representative's Certificate of Substantial Completion designates a commencement date for warranties other than the date of Substantial Completion for the Work, or a designated portion of the Work, submit written warranties upon request of the Owner's Representative.
  - 1) When a designated portion of the Work is completed and occupied or used by the Owner, by separate agreement with the Contractor during the construction period, submit properly executed warranties to the Owner's Representative within fifteen days of completion of that designated portion of the Work.
- b) Form of Submittal: At Final Completion, compile two copies of each required warranty and bond properly executed by the Contractor, or by the Contractor, Subcontractor, supplier, or manufacturer. Organize the warranty documents into an orderly sequence based on the table of contents of the Project Manual.
- c) Bind warranties and bonds in heavy-duty, commercial quality, durable 3-ring vinyl covered loose-leaf binders, thickness as necessary to accommodate contents, and sized to receive 8-1/2" by 11" paper.
- d) Provide heavy paper dividers with celluloid covered tabs for each separate warranty. Mark the tab to identify the product or installation. Provide a typed description of the product or installation, including the name of the product, and the name, address and telephone number of the installer.

- e) Identify each binder on the front and the spine with the typed or printed title "WARRANTIES AND BONDS", the project title or name, and the name of the Contractor.
- f) When operating and maintenance manuals are required for warranted construction, provide additional copies of each required warranty, as necessary, for inclusion in each required manual.

## **SECTION 017300 – EXECUTION**

### **A. GEOTECHNICAL DATA**

- 1. If the Owner has caused borings or other subsurface investigations to be made, the data or report pursuant to these investigations will be included in the Project Manual, as an Appendix, and labeled as such.
- 2. The Owner and Owner's Representative do not guarantee the accuracy or validity of the data, nor do they assume any responsibility for the Contractor's interpretation of the data.
- 3. The Contractor's may, at his option, perform additional subsurface investigation, however, it shall be at the Contractor's sole expense.

### **B. FIELD ENGINEERING**

Provide such field engineering services as are required for proper completion of the Work including, but not limited to:

- 1. Establishing and maintaining lines and levels
- 2. Structural design of shores, forms, and similar items provided by the Contractor as part of his means and methods of construction.
- 3. Verify layout information shown on the Drawings, in relation to the property survey and existing benchmarks and control points. Preserve permanent reference points during construction.

### **C. COORDINATION OF TRADES AND SUB-CONTRACTORS**

- 1. The Contractor shall be responsible for the proper fitting of all work and for the coordination of the operation of all trades, sub-contractors, or materials and men engaged upon the work. He shall be prepared to guarantee to each of his subcontractors the dimensions which may be required for fitting of their work to all surrounding work and shall do, or cause his agents to do, all cutting, fitting, adjusting and patching necessary to make the several parts of the work come together properly and fit the work to receive, or be received by that of other contractors.
- 2. When two or more prime contracts are being executed at one time in such manner that the work on one contract may interfere with the work of another, the Owner's Representative shall decide which contractor shall cease work and which shall continue, or whether the work on both contracts may progress at the same time and in what manner.
  - a) The Contractor shall not cause any unnecessary hindrance or delay to any other contractors on the premises, and shall be responsible for all damages done to the work of other contractors caused by him or by his employees.

### **D. REFERENCE AND CONTROL POINTS PROVIDED BY OWNER**

In addition to layout procedures provided by the Contractor for proper performance of the Contractor's responsibilities:

- 1. Locate and protect existing control points before starting work on the site.
- 2. Preserve permanent reference points during progress of the Work.
- 3. Do not change or relocate reference points or items of the Work without specific approval from the Owner's Representative.
- 4. Promptly advise the Owner's Representative when a reference point is lost or destroyed, or requires relocation because of other changes in the Work.
- 5. Upon direction of the Owner's Representative, require the field engineer to replace reference stakes or markers.
- 6. Locate such replacement according to the original survey control.

### **E. REFERENCE AND CONTROL POINTS PROVIDED BY THE CONTRACTOR**

- 1. If not provided by the Owner (and defined as the responsibility of the Owner in the Contract Documents) establish sufficient general reference points in the form of permanent bench marks, grade stakes or other markers as will enable the Contractor to proceed with the Work.
- 2. The Contractor may lay out his own work, or cause the Work to be laid out by a qualified party such as a Registered Land Surveyor or a Professional Engineer, as necessary.
- 3. The Contractor shall establish and be responsible for all lines, elevations and measurements of the structure utilities, installations, and other Work executed by him under the contract.
  - a) Exercise proper precautions to verify the figures and dimensions shown on the drawings before laying out the work; be responsible for any error resulting from failure to exercise such precaution.

## **SECTION 017329 - CUTTING AND PATCHING**

### **A. CHASES AND OPENINGS**

- 1. The Contractor is responsible for the provision and/or coordination of all chases, openings and recesses required by work of his own forces, subcontractors or separate contractors.
  - a) Each subcontractor or separate contractor shall be responsible for furnishing advance information to the General Contractor as to exact dimensions and locations of such chases and openings, and shall provide and set in place all necessary sleeves, inserts and forms.
  - b) Openings shall be accurately located, neatly cut, and no larger than necessary. Provide all rebuilding, patching, refinishing and painting required to restore the construction to original condition.
- 2. Provide shoring, bracing, and support as required to maintain structural integrity of the project.
- 3. Provide protection from cutting and patching operations as required for other portions of the project; protect the Work and existing improvements in proximity to the cutting and patching operations from the elements.

## **SECTION 017419 – CONSTRUCTION WASTE MANAGEMENT & DISPOSAL**

### **A. PERIODIC CLEANING**

- 1. Each Contractor shall clean up after his own work as needed and/or ensure that sub-contractors clean up after their work and remove accumulations of waste, debris, and rubbish caused by construction operations.
  - a) Remove all waste, rubbish and debris on a daily basis (if needed), as they accumulate, and after completion of the Work.

### **B. PROJECT COMPLETION**

- 1. On completion of the project, the entire job shall be cleaned up and left in perfect condition, including adjacent areas.
  - a) Marred surfaces shall be patched or repaired and touched up to match adjoining surfaces.

- b) All rubbish shall be removed from the site before acceptance.
- c) New surfaces and/or exposed elements of the Work shall be protected from stain and marring. These surfaces shall be cleaned to the satisfaction of the Owner's Representative or replaced if said stains or mars are unable to be completely removed

C. GOVERNMENTAL REGULATIONS

- 1. Conduct cleaning and disposal operations in compliance with Federal, State and local ordinances and anti-pollution laws and regulations.

**SECTION 017700 - PROJECT CLOSEOUT**

A. GENERAL

Work includes:

- 1. Substantial Completion.
- 2. Final Completion
- 3. Closeout submittals.
- 4. Instruction

B. SUBSTANTIAL COMPLETION

- 1. Prepare and submit the list ("punch-list") required by the first sentence of Paragraph 9.8.2 of the General Conditions.
  - a) Within a reasonable time after receipt of the list the Owner's Representative will inspect to determine status of completion. Should the Owner's Representative determine that the Work is not Substantially Complete:
    - 1) The Owner's Representative will so notify the Contractor, in writing, giving the reasons therefore.
    - 2) Remedy the deficiencies and notify the Owner's Representative when ready for reinspection.
    - 3) The Owner's Representative will reinspect the Work.
  - b) When the Owner's Representative concurs that the Work is Substantially Complete:
    - 1) The Owner's Representative will prepare a "Certificate of Substantial Completion" on AIA form G704, accompanied by the Contractor's list of items to be completed or corrected, as verified and approved by the Owner's Representative.
    - 2) The Owner's Representative will submit the Certificate to the Owner and to the Contractor for their written acceptance of the responsibilities assigned to them in the Certificate.

C. FINAL COMPLETION

- 1. Prepare and submit the notice required by the first sentence of Paragraph 9.10.1 of the General Conditions.
  - a) Verify that the Work is complete including, but not necessarily limited to, the items mentioned in Paragraph 9.8.2 of the General Conditions. Certify that:
    - 1) the Contract Documents have been reviewed;
    - 2) the Work has been inspected for compliance with the Contract Documents;
    - 3) the Work has been completed in accordance with the Contract Documents;
    - 4) equipment and systems have been tested as required, and are operational;
    - 5) the Work is completed and ready for final inspection.
  - b) The Owner's Representative will make a final inspection to verify status of completion and if all "punch-list" items have been completed, and upon receipt of the Contractor's Final Application for Payment, issue a Certificate of Final Completion. Should the Owner's Representative determine that the Work is incomplete or defective:
    - 1) The Owner's Representative will so notify the Contractor, in writing, listing the incomplete or defective work.
    - 2) Remedy the deficiencies promptly, and notify the Owner's Representative when ready for reinspection.
  - c) FINAL APPLICATION FOR PAYMENT
    - 1) Submit a final Application for Payment to the Owner's Representative, showing all adjustments to the Contract Sum.
    - 2) If needed, the Owner's Representative will prepare a final Change Order showing adjustments to the Contract Sum which were not made previously by Change Orders.
    - 3) Include final waivers of lien from the Contractor, sub-contractors, and major suppliers.
    - 4) Final payment will not be released until all close-out submittals have been made, final cleaning has been performed, and required instruction(s) to Owner's personnel have been accomplished.

D. CLOSEOUT SUBMITTALS

- 1. When the Owner's Representative determines that the Work is acceptable under the Contract Documents, he will request the Contractor to make closeout submittals. Closeout submittals include, but are not necessarily limited to:
  - a) Project record documents described in "Section 017839".
  - b) Operation and maintenance manuals/data as described in "Section 017823".
  - c) Warranties and bonds as described in "Section 016000".
  - d) Keys and keying schedule;
  - e) Spare parts and materials extra stock;
  - f) Evidence of compliance with requirements of governmental agencies having jurisdiction including, but not necessarily limited to:
    - 1) Certificates of Inspection, as required
    - 2) Certificate(s) of Occupancy
  - g) Certificates of Insurance for products and completed operations;
  - h) Evidence of payment and release of liens.
    - 1) Consent of Surety to Final Payment
    - 2) Contractor's Final Waiver of Lien
    - 3) Separate releases or Waivers of Lien for sub-contractors, suppliers and others with lien rights against the Owner, together with a list of those parties.
  - i) List of subcontractors, service organizations, and principal vendors, including names, addresses, and telephone numbers where they can be reached for emergency service at all times including nights, weekends, and holidays.

**SECTION 017823 - OPERATING/MAINTENANCE MANUALS & INSTRUCTION**

A. GENERAL

1. Compile operating/product data and related information appropriate for Owner's maintenance and operation of products and equipment provided under the Contract.
  2. Instruct Owner's personnel in operation and maintenance of products, equipment and systems.
  3. OPERATIONS AND MAINTENANCE DATA REQUIRED:
    - a) Operating and maintenance manuals are required for each area of Work which is listed below, if that area of Work is included within the scope of Work of the project:
      - 1) HVAC
      - 2) Plumbing – including water supply, sewage and waste disposal
      - 3) Electrical
      - 4) Landscape irrigation system
      - 5) Fire sprinkler system
      - 6) Communications equipment and systems
      - 7) Materials and finishes
- B. OPERATIONS/MAINTENANCE MANUALS - FORM OF SUBMITTAL
1. Prepare operating and maintenance manuals in the form of an instructional manual, utilizing heavy-duty, durable 3-ring vinyl covered loose-leaf binders, for use by the Owner's operating personnel. Organize into suitable sets of manageable size. Where possible, assemble instructions for similar equipment into a single binder. Provide when drawings or diagrams are required as part of the manual.
  2. Provide sturdy manila or kraft envelope, accordion type file folder, or cardboard file boxes, properly labeled, of sufficient size to contain all submittals.
  3. Submit one copy of data in final form at least fifteen days before final inspection. This copy will be returned within fifteen days after final inspection, with comments. After final inspection make corrections or modifications to comply with the Owner's Representative's comments and submit three copies of each approved manual to the Owner's Representative
  4. WARRANTIES, BONDS AND SERVICE CONTRACTS
    - a) Provide a copy of each warranty, bond or service contract in the appropriate manual for the information of the Owner's operating personnel. Provide written data outlining procedures to be followed in the event of product failure. List circumstances and conditions that would affect validity of the warranty or bond. Provide list for each product containing name, address, and phone number of:
      - 1) Contractor.
      - 2) Subcontractor.
      - 3) Maintenance contractor, as appropriate.
      - 4) Local supply source for parts and replacement.
    - b) Identify area of responsibility of each contractor.
- C. MANUAL FOR MATERIALS AND FINISHES
1. Submit two (2) copies of complete manual in final form.
  2. Refer to individual Specification Sections for additional requirements on care and maintenance of materials and finishes.
  3. Content for products, applied materials and finishes:
    - a) Manufacturer's data, giving full information on products.
      - 1) Catalog number, size, composition.
      - 2) Color and texture designations.
      - 3) Information for re-ordering special-manufactured products.
  4. Instructions for care and maintenance.
    - a) Manufacturer's recommendations for types of cleaning agents and methods.
    - b) Cautions against cleaning agents and methods detrimental to product.
    - c) Recommended cleaning and maintenance schedule.
  5. Moisture-Protection and Weather-Exposed Products: Provide complete manufacturer's data with instructions on inspection, maintenance and repair of products exposed to the weather or designed for moisture-protection purposes.
  6. Manufacturer's Data: Provide manufacturer's data giving detailed information, including the following, as applicable:
    - a) Applicable standards.
    - b) Chemical composition.
    - c) Installation details.
    - d) Inspection procedures.
    - e) Maintenance information.
    - f) Repair procedures.
- D. INSTRUCTION
1. Instruct the Owner's personnel in proper operation and maintenance of systems, equipment, and similar items which were provided as part of the Work including, but not limited to;
    - a) Mechanical
    - b) Water supply
    - c) Electrical service/distribution and lighting
    - d) Other items or systems as required in individual sections of the Technical Specifications
  2. Instructions for the Owner's Personnel: For instruction of the Owner's operating and maintenance personnel, use experienced instructors thoroughly trained and experienced in the operation and maintenance of the equipment or system involved.

#### SECTION 017839 - PROJECT RECORD DOCUMENTS (AS-BUILTS)

- A. DOCUMENTS REQUIRED AT SITE
1. The Contractor shall maintain at the job site one copy of all Drawings, Specifications, Addenda, approved Shop Drawings, Change Orders, and other Contract modifications.
    - a) Each of these project record documents shall be clearly marked "**Project Record Copy**"
    - b) Shall be maintained in good condition
    - c) shall be available at all times for inspection by the Park District, and shall not be used for construction purposes.

- B. Project-record drawings shall be marked up to show significant changes made during construction progress, referenced to visible and accessible features of the structures. Project-record drawings shall be kept current and no work shall be concealed until required information has been recorded.
- C. Record-documents shall be submitted in satisfactory condition to the Park District at the completion of the project. **FINAL COMPLETION OF THE PROJECT WILL NOT BE ATTAINED, AND FINAL PAYMENT WILL BE WITHHELD, UNTIL PROJECT "AS-BUILTS" ARE SUBMITTED TO AND APPROVED BY THE OWNER'S REPRESENTATIVE.**

END OF GENERAL REQUIREMENTS

**DATE: November 18<sup>th</sup>, 2025**

**SPECIFICATIONS FOR THE  
AUTOMATIC IRRIGATION IMPROVEMENT PROJECT – Phase 1**

**AT**

**Newman Golf Course  
Peoria, IL**

*IRRIGATION CONSULTANT*



**ERIK CHRISTIANSEN DESIGN GROUP, LTD.**

---



# Table of Contents

Table of Contents .....	1
Part 1 - GENERAL IRRIGATION CONDITIONS .....	2
Part 2 - IRRIGATION SYSTEM .....	8
Part 3 - EXECUTION .....	18
Part 4 - ELECTRICAL .....	22

## **PART 1 - GENERAL IRRIGATION CONDITIONS**

### **1.1 GENERAL CONDITIONS**

1. OWNER'S REPRESENTATIVE:
    - a. Contact: David Voorhees
    - b. Project: Newman Golf Course
    - c. Address: 1314 N. Park Rd.
    - d. City, State: Peoria, IL 61604
    - e. Phone: (309) 678-0560
    - f. Email: rfredrickson@peoriaparks.org
  2. IRRIGATION CONSULTANT:
    - a. Contact: Erik Christiansen
    - b. Address: 400 5<sup>th</sup> Street
    - c. City, State: West Des Moines, Iowa 50265
    - d. Phone: (515)225-6365
    - e. Email: erik@ecdesigngroup.com
- B. The objective of these specifications is to remove the existing irrigation equipment as detailed in the drawings and replace it with a complete and operational irrigation system that integrates seamlessly with the existing infrastructure while expanding its functionality as outlined in the project's phasing plan. The scope includes removing existing components such as sprinklers, valve assemblies, and installing a new system with HDPE mains, laterals, and necessary fittings; and expanding the satellite-based control system. The project requires compliance with applicable codes and standards, coordination with the owner and irrigation consultant, and ensuring nightly irrigation functionality during construction. This system, when finished, will efficiently and effectively operate. Said system shall prove to be satisfactory in all aspects to the Owner and Owner's Representative and Irrigation Consultant. These specifications are to be followed with due perseverance in all respects.
- C. The diagrammatic Plans and Specifications contain a design build element and are intended to include everything obviously requested and necessary to do the proper installation of the work, whether each necessary item is mentioned herein or not, unless otherwise specified in writing the contractor is expected to provide for the same.
- D. Irrigation Plans with Specifications are intended to work together, and any item or feature called for in one and not the other shall be as binding as if called for in both. If a discrepancy exists between an item called for in the Plan and the Specifications, the Plan takes precedence, or the contractor can assume the more stringent as it applies to the best method of operation and installation. Furthermore any change to the scope of said work shall be documented and approved by the owner before work is commenced.
- E. All work specified herein or called for on the drawings shall comply in accordance with all governing ordinances, laws and regulations that apply to the project. The contractor to provide any and all permitting required at their expense with no additional costs to the owner. If the contractor performs any work contrary to such codes, laws or regulations, they shall assume full responsibility and bear all costs necessary to correct the work, at no additional cost to the Owner or the Owner's Representative.
- F. Bidders must study and compare the Drawings and Project Documents and shall be responsible for discovering and reporting to the Irrigation Consultant any error, omission, inconsistency or other defect that should be apparent to a reasonable prudent Contractor prior to bidding. The Irrigation Consultant will interpret, correct or otherwise clarify the Project Documents as necessary, and will make any interpretation, correction or clarification in writing and issue it an addendum to all Bidders.

- G. Any work undertaken by the Contractor containing possible errors or conflict without or before a written interpretation or instruction by the Owner's Representative and Irrigation Consultant is done so at the Bidders own risk.
- H. The successful Contractor will be required to install the irrigation system under the following requirements:
1. All open trenches and excavations must be marked and protected on a daily basis. Protection will include barriers and plywood covers over excavations and other necessary procedures to protect the public and other Contractors from the danger of construction activities.
  2. The entire site must be left in a clean and safe condition at the end of each workday. "Clean and safe" will be at the discretion of the Owner's Representative and the Irrigation Consultant. The Contractor shall appoint a supervisor who shall be responsible for all safety measures, as well as for compliance with all applicable governmental laws, ordinances, rules and regulations such as, for example, "OSHA" and "Right to Know" legislation and all city, county and state codes.
  3. The order of work will be as agreed upon with the Irrigation Consultant and Owner's Representative. The resulting agreement shall become the basis for the irrigation part of the master project schedule.
  4. Contractor shall keep the existing system up and operating each night to water the entire golf course (as required by Owner) and Contractor shall coordinate with Owner each day as to the status of the existing irrigation system. Furthermore, Contractor shall water all new and replaced turf until time of irrigation system acceptance by Owner and Irrigation Consultant.
- I. The omission of any material from this Specification is not to be interpreted to the effect that omitted material will not be furnished by the Contractor. All material and labor, unless specifically indicated as being furnished by others, must be furnished and installed by the Contractor under the signed agreement.
- J. The Irrigation Consultant shall stake or mark out the location of control cable(s) as applicable, any mainline and wire paths in the immediate area to be worked on prior to starting installation. In the event there are any discrepancies from the work shown in the plan, the Contractor shall verify the dimensions with the Irrigation Consultant before work may begin in that area. The Contractor shall have available a minimum of four persons, staking flags, four 100 ft. tapes with flags and shall produce "as staked" drawings, all for use during all current and future staking visits by the Irrigation Consultant.
- K. Routing of the pipe and cable are diagrammatic and the Contractor will be expected to make field adjustments. The Owner reserves the right to make pipe and/or cable routing changes from those shown in the plans in cases, but not limited to; where ledge, boulders or other obstacles impede the path. Minor changes, including nozzle selections, of this nature shall not affect the cost or time limits of the work.
- L. Valve boxes should be as indicated on the drawings. Communication cable shall not be run through bunkers or tees. No valve boxes shall be located within the fairway cut and shall not be installed in the walking path to or from the green.
- M. Rock, shale, stones, organic matter or trash not suitable for use as backfill shall be dug and hauled to an accessible dumpsite on the property. The Contractor shall be responsible calling in all locates and will be responsible for all damage to underground utilities of which they are aware, including, but not limited to; gas, water, electricity, cable, telephone, under-drains and drain tiles. Coordinate with the Owner's Representative and responsible utility marking firms the locations of existing underground utilities and drains.
- N. The Contractor shall not assign or subcontract any part of the work without the expressed written approval of the Owner prior to the start of said work to be subcontracted. Acceptance of a subcontractor does not relieve the Contractor of his responsibilities under the agreement.

- O. The Contractor shall maintain a minimum of one 40-foot storage trailer on site for storage of materials other than piping. Location of trailer(s) shall be at the staging area as designated by the Owner. The Contractor shall be solely responsible for meeting deliveries and they're off-loading. The Owner shall not be responsible for inventorying or off-loading any materials to be used in the irrigation system.

## 1.2 BIDDING INSTRUCTIONS

### A. GENERAL

- 1. Qualifications and Interpretation
  - a. **Construction schedules must be approved by Owner and Owner's Representative:**
    - 1. All proposals must meet the requirements in the Quality Assurance Section 4.1.C.
    - 2. Irrigation said improvements must be completed in the time frame designated by the Owner and Owners Representative.
    - 3. List all, if any, sub-contractors to be employed by the contractor on irrigation project.
    - 4. Acknowledgment of receipt of addenda.
    - 5. Completion of unit pricing, bid form, and reference sheet.
    - 6. Contract will be awarded, unless all bids are rejected, under normal circumstances, to the responsible Bidder whose bid and accepted alternative bids resulted in the lowest sum.
    - 7. Owner reserves the right to reject any and all bids when such rejection is in the interest of Owner; to reject a bid or a Bidder who has previously failed to perform properly or complete on time contracts of similar nature; to reject bid or a Bidder who is not, in the opinion of the Irrigation Consultant or Owner, in a position to satisfactorily perform the contract. Owner also reserves the right to waive any informalities and technicalities in bidding. Owner may also accept or reject any alternatives.
    - 8. All contractors must visit job site before submitting a bid.
    - 9. Contractor is to include in the base bid removal of the existing sprinklers, electric valve assemblies with valve boxes, quick coupling valves, and controllers, etc. When removing sprinklers, quick coupling valves and electric valve assemblies, remove all fittings down to the existing pipe and install PVC plug in threaded outlet. Fill holes with loam, which will be supplied on site by the Owner and transported by Contractor.
    - 10. Areas where the existing irrigation equipment was located shall have a square piece of sod cut (2-foot x 2-foot) where it exists and will be reused, be filled in with approved material and compacted to grade. Contractor shall provide sod as well as Owner supplied replacement backfill material for these areas – as needed.
    - 11. Contractor shall stockpile removed equipment on site where directed by Owner. Contractor shall also remove existing controllers and controller pads – as applicable. Owner is responsible for disposing of all removed irrigation equipment. Contractor to remove all spoils.

## 1.3 CONTRACTOR SPECIFICATIONS

- A. The detailed specifications, which follow, shall govern the materials furnished and work performed in the construction of the work covered by this contract.
- B. No attempt has been made in the specifications to segregate work to be performed by and trade, subcontract or proposal item, under any one section of the specifications. Any segregation between trade or craft jurisdiction limits, and the establishment of subcontract limits, will be solely a matter of agreement between the Contractor and his employees and his Sub-contractors. The specifications will govern the construction of the entire work and the provisions thereof all govern each item and unit of work to which such provisions apply.

## 1.4 APPLICATIONS FOR PAYMENT

- A. Each Application for Payment shall be consistent with previous applications and payments as certified by the Irrigation Consultant and Owner and paid for by the Owner.
- B. Application Preparation:

1. Payment will be based on the proportion of the total work completed during the period for which application for payment is being made. Contractor shall submit application for payment on the 9th of each month, for work completed from the 10th of the previous month.
  2. Include any contract revisions authorized by approved Change Orders issued prior to the last day of the construction period covered by the application. Payment for such authorized contract revisions will be computed based on the Unit Prices included on the Bid Form taken times the actual quantity of such materials installed as result of such change as measured by the Contractor and reviewed by Owner.
- C. Transmittal:
1. Submit three executed copies of each Application for Payment to the Owner including waivers of lien(s) from previous applicaitons and similar attachments, when required.
  2. Transmit each copy with a transmittal form listing attachments, and recording appropriate information related to the application in a manner acceptable to the Owner.
- D. Final Payment Application:
1. Submittals, which must coincide, with submittal of the final payment Application for Payment include the following on forms, and executed in a manner acceptable to the Owner
  2. Final waivers of liens from every entity involved with performance of Work.
  3. Consent of Surety of Final Payment. (If applicable)
  4. Itemized statements listing taxes, fees and similar obligations paid.
  5. All "As-Built" document and central programming 100% complete as approved by both Owner and Irrigation Consultant.

#### 1.5 TERMINATION OF CONTRACTOR

- A. Termination of contract will be written, giving 10 days' notice of contract cancellation. Cancellation can be inferred by the following but is not limited to:
1. Bankruptcy.
  2. Violation of codes, and regulations on local, state or federal levels.
  3. Inability to meet progress schedules.
  4. Progress stopped by legal order. Owner has the right to pursue to finish project and shall be reimbursed for any improvements already paid to Contractor. Owner also reserves the right to pursue any damages obtained by the fair value of the Contractor to perform said contract

#### 1.6 LIQUIDATED DAMAGES

- A. The liquidated damage provision or \$500.00 per day is intended as a reasonable estimate of the Owner's damages because of the Contractors failure to complete the Work by Completion Date and as a settlement of the actual damages that might arise because of such failure. The parties agree that these damages are reasonable, bear significant relation to the actual damages that Owner might sustain, which damages Contractor and Owner agree would be uncertain and difficult to prove, and is not a penalty for the Contractors failure to perform. The acceptance by Owner of the liquidated damages set forth above shall not be deemed permission for Contractor to continue to violate its covenant to complete the Work by the Completion Date, and shall not preclude the Owner from seeking any other remedy (other than money damages) for such violation including, without limitation, specific performance or termination of the Agreement, which Owner may pursue at any time while the violation continues. If contractor fails to complete the work after a default notice has been issued; the Owner shall be entitled to obtain substitutive performance and may seek recovery of the costs, of such substitutive performance, in addition to the liquidated damages.

#### 1.7 CONTRACTOR'S LIABILITY INSURANCE AND/OR OWNER REQUIREMENTS

- A. No construction work shall be started under this contract until the insurance requirements hereinafter stated have been satisfied and approved by all Owners' Representatives. The Contractor shall carry liability insurance, which shall hold harmless the Owner and the Irrigation Consultant, protect the public and any person from injuries sustained by reason or prosecution of the work or the handling or the storing of materials therefore.

- B. The Contractor shall furnish the Owner with proper affidavit or affidavits executed by representatives of a duly qualified insurance company, evidencing that said insurance company or companies have issued liability insurance policies effective during the life of the contract, protecting the public or any person from injury or damages sustained by reason of carrying on the work involved in the contract. The affidavit shall specifically evidence the following forms of insurance protection but not limited to:
1. Liability insurance covering all operations performed by persons directly employed by the Contractor.
  2. Public Liability insurance covering all operations performed by any subcontractors to whom a portion of the work may be assigned.
  3. Public Liability insurance covering all work on the project performed by any independent contractor working under the direction of either the principal contractor or a subcontractor.
  4. Motor vehicle, bodily injury liability insurance and property damage liability insurance on all motor vehicles employed on the Work, whether owned by the Contractor or by other persons, firms or corporations.

C. The following minimum sample protection could be as follows. **Ultimately the requirements shall be set and approved by the Owner and their Legal Representative:**

- 1) Minimum Required General Liability Clause:
 

Bodily Injury Liability	\$1,000,000	Each Occurrence
	\$1,000,000	Aggregate
Property Damage Liability	\$500,000	Each Occurrence
	\$1,000,000	Aggregate
Personal Injury Liability	\$1,000,000	Each Person
	\$1,000,000	Aggregate
  
- 2) Minimum Required Automobile Liability Limits:
 

Bodily Injury Liability	\$250,000	Each Person
	\$500,000	Aggregate
Property Damage Liability	\$100,000	Each Occurrence
Uninsured Motorist	\$25,000	Each Person
	\$50,000	Each Occurrence
  
- 3) Contract Liability:
 

Bodily Injury Liability	\$ 500,000	Each Occurrence
Property Damage Liability	\$500,000	Each Occurrence
	\$1,000,000	Annual Aggregate
  
- 4) Contractor's Excess:
 

(Umbrella) Liability	\$5,000,000	Each Occurrence
----------------------	-------------	-----------------
  
- 5) Worker's Compensation:
 

State	Statutory
Applicable Federal	
(e.g., Longshoremen's)	Statutory

Employer's Liability                      \$ 100,000      Each Accident

- D. Approval of the insurance by the Owner shall not relieve or decrease the liability of the Contractor hereunder. It is to be understood that the Owner and the Irrigation Consultant do not in any way represent that the insurance or the limits of insurance specified in these articles are sufficient or adequate to protect the Contractor's interests or liabilities but are merely sample potential minimums.

## PART 2 - IRRIGATION SYSTEM

### 2.1 GENERAL

#### A. RELATED DOCUMENTS

1. Drawings and General Provisions of Contract, including Bidding Requirements apply to work specified in this Section.

#### B. DESCRIPTION

1. Provide all labor, materials, equipment and supervision required to construct an underground irrigation system as shown and specified. The following work includes; but not limited to:
  - a. Removal of existing equipment.
  - b. Satellites, sprinklers.
  - c. Testing.
  - d. Excavation and backfilling irrigation system work.
  - e. Associated plumbing and accessories to complete the system.
  - f. Wire sleeves (as required).

#### C. QUALITY ASSURANCE

1. Installer's qualifications: Minimum of 12 years experience installing golf course irrigation systems of comparable size. A minimum of 12 similar golf courses completed within the last 3 years. Contractor to comply with all certifications required in said plans and specifications.
2. Materials, equipment, and methods of installation shall comply with, but not limited to, the following codes and standards:
3. All local and state laws and ordinances along with labor requirements, and with all the established codes applicable thereto.
4. American Society of Irrigation Consultants (ASIC)
5. National Fire Protection Association (NFPA); National Electrical Code.
6. American Society for Testing and Materials (ASTM).
7. National Sanitation Foundation (NSF).
8. The Irrigation Association (IA).
9. The Contractor shall take out all required permits, arrange for all necessary inspections and shall pay any fees and expenses in conjunction with the same as a part of the work under this Section.
10. Excavating, backfilling, and compacting operations: Comply with execution requirements and as specified.
11. **Supply Irrigation Consultant with min. of (4) people for all staking visits, flags and (4) 100' tapes. Visits must be scheduled a minimum of 14 days prior to proposed visit and have (3) or more holes prepared for staking.**
12. Obtain Irrigation Consultant's acceptance of installed and tested irrigation system prior to installing backfill materials with current scaled "As-Built" drawing.

#### D. SUBMITTALS

1. **Irrigation Contractor to provide completed station/address worksheet provided by Irrigation Consultant during staking visits and prior to final approval.**
2. Submit manufacturer's product data and installation instructions for each of the system components. NOTE: If said information is not listed on the Bill of Materials, the contractor is to provide submittal cut sheets for approval prior to ordering.
3. Submit the following material samples:
  - a. Wire, wire connectors and sealer.
4. Submit the following equipment samples to Owner:
  - a. Valves and valve access boxes.
  - b. Controller.

- E. Approved equipment samples will be returned to Contractor and may be used in the work.

- F. Upon irrigation system acceptance, submit written operating and maintenance instructions. Provide format and contents as directed by the Irrigation Consultant **as well as completed station/address worksheet provided by Irrigation Consultant.**
- G. Provide irrigation system as-built drawings (note: NO pay applications to be approved without current as-built drawings):
1. The record as-built drawings shall be the original plan of the irrigation system as constructed. The final as-built drawings shall be prepared electronically (GPS performance) at a scale of 1" = 100'. The drawings shall consist of a piping plan, a schedule plan, and a wiring plan, indicating the location, type and size of all wires, valves and other fittings. The drawing shall show all electronic controls, connections and wire splices. Measurements shall be indicated on the plan between sprinklers and valves. All pertinent materials shall be dimensioned from three fixed objects (i.e., drain valves, lateral isolation valves, mainline isolation valves, and wire splice connections). Station numbers shall be indicated on the drawings.
  2. The as-built drawings shall be made by an agent of the Contractor who shall utilize engineering skills and procedures in a manner satisfactory to the Owner's Representative in accomplishing his work. The record drawings shall be kept clean, dry and safe from damage at all times. The drawings shall be brought up-to-date at the close of each working day, and shall accurately indicate the location of all equipment placed to that time. In addition, a copy of the as-built drawing shall be mailed or electronically delivered to the Owner's Representative every two weeks during the construction period. **No monthly pay requests will be approved without a current copy of the as-built drawings. No final approval will be given until the Owner approves the as-built drawings. Final "as-builts" shall be delivered on both reproducible Mylar and electronically on 2014 AutoCAD .dwg or newer.**
  3. Identify field changes of dimension and detail and changes made by Change Order.
  4. **GPS irrigation collection by the Irrigation Consultant does not remove the obligation of the Contractor to produce all "as-built" drawings as stated above. All locations must be located and flagged by Contractor prior to collection of those points by EC Design Group Ltd.**
- H. DELIVERY, LANDS FOR STORAGE AND HANDLING
1. Deliver irrigation system components in manufacturer's original undamaged and unopened containers with labels intact and legible.
  2. Deliver plastic piping in bundles, packaged to provide adequate protection of pipe ends.
  3. Store and handle materials to prevent damage and deterioration. Store materials in locations designated and approved by the Owner.
  4. Provide secure, locked storage for wire, pump station and similar components that cannot be immediately replaced, to prevent theft and therefore avoid installation delays.
  5. Contractor has the right to a temporary construction facility for storage and protection of materials.
- I. PROJECT CONDITIONS
1. Prior to any excavation at the site, contractor shall examine any applicable drawings, if any available from the Owner and/or Irrigation Consultant and consult with Owner's personnel and utility company's representatives to determine possible utility locations and depths. No compensation will be allowed for damage to existing utilities and systems.
  2. Take precautions to insure that equipment and vehicles do not disturb or damage existing site grading, walks, curbs, pavements, utilities, plants, and other existing items and elements on public and private property.
  3. Promptly repair damages to adjacent facilities caused by irrigation system work operations. Cost of repairs at Contractor's expense.
  4. Promptly notify the Irrigation Consultant of unexpected sub-surface conditions.

5. **Irrigation system layout is diagrammatic.** Exact locations of piping, valves, wire and other components shall be established by Irrigation Consultant in the field at time of installation and approved by the Owner or the Owners Representative before installation.
    - a. Minor adjustments in system layout will be permitted to clear existing fixed obstructions.
  6. Cutting and patching (cart paths, walks, drives, walls etc):
    - a. Cut through concrete and masonry with core drills. Jackhammers are not permitted.
    - b. Materials and finishes for patching shall match existing cut surface materials and finish. Exercise special care to provide patching at openings in exterior wall watertight.
  7. Methods and materials used for cutting and patching shall be acceptable to the Owner and Irrigation Consultant.
- J. Protection of Persons and Property:
1. Barricade open excavations occurring as part of this work and post warning lights.
  2. Operate warning lights as recommended by authorities having jurisdiction.
  3. Protect structures, utilities, sidewalks, pavements, curbs and other facilities from damage caused by settlement, lateral movement, undermining, washout and other hazards created by this work.
- K. GUARANTEE
1. For a period of one (1) year from date of final acceptance of work performed under this Section, the Contractor shall promptly furnish and install any and all parts and equipment which prove defective in material, workmanship or install at no additional cost to the Owner except trench settling and any pipe/fittings failures will be guaranteed for (2) years.

## 2.2 PRODUCTS

- A. ACCEPTABLE MANUFACTURERS-OR PRE-APPROVED EQUAL
1. THE TORO COMPANY, IRRIGATION DIVISION, RIVERSIDE, CA
  2. RAINBIRD CORP., TUSCON, AZ
  3. HUNTER INDUSTRIES, SAN MARCOS, CA
- B. MATERIALS
1. General:
    - a. Provide only new materials, without flaws or defects and of the highest quality of their specified class and kind.
    - b. Comply with pipe sizes indicated. No substitution of smaller pipes will be permitted. Larger sizes may be used subject to acceptance of the Irrigation Consultant. Remove damaged and defective pipe.
    - c. Provide pipe continuously and permanently marked with manufacturer's name or trademark, size, schedule and type of pipe, working pressure at 73 ° F. and National Sanitation Foundation (NSF) approval.
    - d. **All pipe and fittings (HDPE) shall be supplied from the same manufacturer throughout the entire job and meet all certification requirements.,**
    - e. **All sprinkler equipment must be purchased by the local authorized servicing regional distributor and supplier noted in Bid Document Submittals.**
- C. HDPE Mains/Laterals – HDPE pipe, fusion fittings and connections:
1. Pipe and tubing shall be manufactured from a PE4710 resin listed with the Plastic Pipe Institute (PPI) as TR-4. The PE 4710 resin material will meet the specifications of ASTM D 3350-09 with a minimum cell classification of PE 445474C. Pipe shall be manufactured to the dimensions and requirements of ASTM F714. The pipe shall contain no recycled compounds except that generated in the manufacturer's own plant from resin of the same specification from the same raw material. All HDPE pipe shall be in straight lengths or coils.
  2. Pipe shall be supplied by stated manufacturer only. Mixing of brands is prohibited.
  3. The supplier must be capable of supplying both the pipe, fittings, site certification, equipment certification and \$1,000,000.00 insurance policy under owners name for 25 year warranty – as required.

4. The supplier must have the capability to train the contractor's employees in butt fusion, electrofusion, socket fusion, sidewall saddle fusion and compatible fusion of HDPE pipe and fittings.
5. The supplier must be capable of providing a "**Fusion Technical Hot Line**" to assist in fusion and fusion equipment questions.
6. The supplier must be capable of providing a trained representative on site upon the request of the contractor, owner or consultant to address any problems that are encountered during the installation.
7. The supplier must furnish a written warranty for approved HDPE pipe fittings and valves for all irrigation applications.
8. Main Line Isolation Valves shall be Clow (or approved equal) isolation valves. They shall be PE 4710 and have operating nut and be pipeline size or as per plan.
9. All gate valves will have stainless steel stem with HDPE stubs – see plan.
10. Mechanical taps on 2", 3", and 4" pipe for sprinkler connections can be made using saddle tee with 1½ acme thread outlet, drilling the hole prior to installing the saddle.
11. All fused taps on HDPE pipe shall be made using Electrofusion branch saddles with 2" IPS HDPE outlet or sidewall branch saddles. The pressure rating shall be equal to or greater than 100 PSI Central Plastics PE 4710 or approved equal.
12. Pipe and Fittings: Size as indicated on the plans. Install as shown in accordance with manufacturers recommendations.
13. Hauling, unloading and distributing pipe: During loading, transportation and unloading, every precaution shall be taken to prevent injury to the pipe. No pipe shall be dropped from cars or trucks, or allowed to roll down slides without proper retaining ropes. During transportation pipe shall rest on suitable pads, strips, skids or blocks securely wedged or tied in place. Any pipe damaged shall be replaced.
14. Sections of polyethylene pipe should be joined into continuous lengths on the jobsite above ground, whenever possible. The joining method shall be the butt fusion and or socket fusion method and shall be performed in strict accordance with the pipe supplier's recommendations. The butt fusion equipment used in the joining procedures should be capable of meeting all conditions recommended by the pipe supplier, including, but not limited to, temperature requirements of 425 +/- 15 degrees Fahrenheit, alignment, and an interfacial fusion pressure of 75 +/- 15 psi for hydraulic. The fusion equipment used shall be manufactured by McElroy Manufacturing, or equal. The butt fusion joining will produce a joint weld strength equal to or greater than the tensile strength of the pipe itself.
15. Electrofusion or socket fusion (500°F +/-25 may be used where the butt fusion method cannot be used. Electrofusion couplings and fittings shall be PE 4710 with a minimum cell classification of PE 445474C. Electro-fusion couplings or fittings shall have a manufacturing standard of ASTM F1055. Couplings and fittings shall have the same pressure rating as the pipe unless otherwise specified on the plans.
16. Mechanical connection to other types of pipe shall be made by one of the following methods:
17. Flange, using HDPE flange adapter with ductile iron back up ring, and zinc-plated bolt pack.
18. Mechanical joint, using HDPE Mechanical Joint (MJ) adapter kit.
19. Bell MJ adapter with kit (4"- 12)
20. Inspection: Inspect the pipe for defects before installation and fusion. Pipe shall not exhibit scratches or gouges greater than defective, damaged or unsound pipe will be rejected.
21. Testing if pressure testing is required, testing shall be done hydrostatically.
22. Prior to HDPE pipe being installed in the trench, at the beginning of the job, the contractor shall cut out the first butt fusion of each pipe size. The contractor shall prepare the sample for the test in accordance with the "Bend Back Testing" procedure in accordance with ASTM F 2620.
23. The samples shall be tested in the presence of the Owner's Representative and/or Irrigation Consultant, all in accordance with testing procedures outlined. All samples shall be labeled and saved. Testing must be done at 73 degrees F plus or minus 5 degrees. The test

temperature and sample size are critical to testing. The purpose of the test is to determine if the weld meets specified standards. A pass means no failures during the bend back test. This means a good weld. A break means a bad weld. Any failure shall require additional testing.

24. The contractor shall have successfully installed high density polyethylene pipe in a minimum of (12) golf irrigation projects. References will be required. These reference(s) must provide a satisfactory response or the experience will not be accepted.
  25. If a contractor has not previously successfully installed HDPE pipe for golf irrigation projects, he will be required to have a qualified fusion technician from the HDPE pipe manufacturer for a period of three to five days (at the expense of the contractor). The required time for HDPE pipe (fusion and mechanical) training shall be collectively agreed to by the Owners Representative and Irrigation Consultant. Training shall be provided by a qualified technician and shall include the following:
    - 1) Butt fusion
    - 2) Socket fusion
    - 3) Electrofusion
    - 4) Attachment of mechanical saddles
    - 5) If electro and/or sidewall fusion is required, this training must also be completed while the technician is on site.
    - 6) Sidewall saddle fusion (if required for project)
  - b. Compatible fusion
  26. If the contractor owns butt fusion equipment, the equipment must be serviced and certified by fusion representative prior to use for this project. The machine must be environmentally friendly and in good working order. The hydraulic system must be leak free. All fusion equipment with pressure gauges shall be properly calibrated and the heating tool is to be in proper working condition prior to use.
  27. Rented butt fusion machines must be rented from a company that has a fusion machine service center or centers certified by the butt fusion machine manufacturer. The fusion equipment supplied shall have certification that pressure gauges are properly calibrated and the heating tool is to be in proper working condition prior to use.
  28. Manufacturer warrants it will replace any section of said manufacturers HDPE pipe product that is defective in materials or workmanship, provided that Buyer, upon discovery of a defect, promptly notifies Seller of the defect and, as instructed by Seller at such time, either returns the product to Seller for inspection or allows Seller to inspect at the place of installation. If Seller determines the product to be defective, Seller will provide new product of the same specification and same quantity as the defective product and Seller will bear the expense of freight to deliver the replacement product to the jobsite for domestic projects, and to the closest USA port for foreign projects. Seller does not warrant the installation of product. Any defects introduced after the shipment of product by Seller, whether due to handling, installation or other cause, are not covered by this warranty. This warranty does not cover labor or other costs of installing products. Buyer's sole remedy for defective product shall be to receive replacement product as provided in this Limited Warranty.
  29. Swing Joints:
    - a. Specified 360° unitized swing joint assembly. Contractor is responsible for proper installation of swing joints due to actual lateral depths lay lengths (as per manufacturer recommendations).
  30. "Air Release Valves" – Qty (10) in base bid:
    - a. 2" air release valves shall be installed at high points on golf course and/or where diagrammatically noted on irrigation plan. Irrigation plan locations are diagrammatic; Contractor will be responsible for proper location as approved by Irrigation Consultant. Air release valves shall be installed in a Jumbo valve box and plumbed with a ball valve to isolate for maintenance (see detail).
- D. V-I-H sprinklers, field satellites, valves and associated equipment:

1. Products and associated equipment are to be provided by only one manufacturer for the complete project. Refer to the drawings for the quantity and diagrammatic locations of the following:
  2. Sprinkler heads with unitized swing joint assemblies – see plan and details:
    - a. TORO FLX34/35 Smart Module series V-I-H
    - b. Spacing of heads shall not exceed manufacturer's maximum recommendations. Conform to manufacturer's specifications concerning diameter of throw and gallonage at given pressures.
  3. Electric & Manual Isolation Valves:
    - a. Clow Valve Co. with HDPE DR13.5 4710 stub RW "resilient wedge" (or equal)-see plan
    - b. 360° PE ball valves for air release valves.
    - c. 360° 2" P.E. lateral isolation valve - see plan
    - d. Size isolation valves to match line size-Manual Valves only.
    - e. Installed in specified valve access box **with specified lid color.**
    - f. Each style of isolation valve shall have (2) 4'-0" tee handle keys supplied by Irrigation Contractor.
  4. Quick Coupler Valves:
    - a. 1" QCV with stabilizer and swing joint assembly.
    - b. Provide matching quick coupler keys – (10) included in base bid.
    - c. Installed as specified on detail plan.
    - d. All Q.C.V. shall be plumbed with a **1" brass insert swing joint with stabilizer.**
- E. Control Equipment:
1. Refer to the drawings for the quantity and locations of the following:
  2. Satellite Controllers: **Hunter**
- F. Primary Electrical Wire: **Tray Cable – See Plan.**
- G. Secondary Control Wire: **Paige Wire #12 white common and #14 red for hot wire, as per code.**
- H. Controller Communication Wire: Specified Paige Wire Communication Cable. To be routed with main/lateral line piping– See Electrical Plan
- ## 2.3 ADDITIONAL MATERIALS
- A. Primary Electric wire connectors: **Wire splice cable (as per manufacturer's recommendations) – Resin packs only or latest manufacturer recommendation**
1. 3M COMPANY DBR-6 splice kits Socket seal type wire connectors or resin packs and waterproof sealer, or Large 3M #4 Resin Bag UL listed for 600 volts and underground splice. All electrical connections shall apply to NEC standards and all local, state and federal codes whether listed or not – 120VAC power only.
- B. Secondary Control Cable connectors:
1. 3M COMPANY #3570G-N direct burial splice kits. All electrical connections shall apply to NEC standards and all local, state and federal codes whether listed or not.
- C. Valve Access Boxes:
1. 8" round valve box for all QCV's (see detail), owner's option. Valve box lids shall be color coded to identify components in box. Green lids shall be lateral and green isolation valves; black lids shall be main line and air relief valves; grey lids shall be splices and surge protection. Standard or Jumbo Box with extension kit-or equal; for air relief valves and isolation valves. Contractor to utilize awarding manufacturer valve boxes only – mixing will not be allowed.
- D. Thrust Blocking: **N/A (bid utilizing HDPE system)**
1. Thrust blocks are anchors placed between pipe or fittings and the solid/virgin trench wall. Specified blocking of concrete which is calculated to have a compression strength of 2,000 pounds per square inch. The mixture is one part cement, two parts washed sand and five

parts gravel. Thrust blocks must be constructed so the bearing surface is in direct line with the major force created by the pipe or fitting. See diagram. The earth bearing surface should be undisturbed (virgin wall).

2. Thrust blocking is to prevent the line from moving when the pressure load is applied, transferring the load from the pipe to a wide load bearing surface. Thrust blocks are required where fittings are used to change direction (i.e. the following but not limited to; all tees, elbows, wyes, caps, valves and reducers etc.) of the pipe line. The thrust blocking must be formed against a solid trench wall (virgin wall) and these fitting areas must be excavated by hand, mechanical equipment will damage the bearing surface of the trench wall.
3. The size and type of thrust depends on pipe size, line pressure, type of fitting, degree of bend and type of soil. Thrust block size may be calculated by the example procedures shown below.
4. It will be the responsibility of the Contractor for all change of direction thrust blocks on all size piping. Furthermore, the warranty period for pipe and/or fitting failures is for (2) years from the date of acceptance.

*Step 1 – Multiply the pressure level desired for testing by the appropriate value shown in the following table:*

Pipe Size	Dead End or Tee	90 deg Elbow	45 deg Elbow	22 ½ deg Elbow
1 ½"	2.94	4.16	2.25	1.15
2"	4.56	6.45	3.50	1.78
2 ½"	6.65	9.40	5.10	2.60
3"	9.80	13.90	7.51	3.82
3 ½"	12.80	18.10	9.81	4.99
4"	16.20	23.00	12.40	6.31
5"	24.70	35.00	18.90	9.63
6"	34.80	49.20	26.70	13.60
8"	59.00	83.50	45.20	23.00
10"	91.50	130.00	70.00	35.80
12"	129.00	182.00	98.50	50.30

*Based on pounds per psi working pressure.*

*Step 2 – Determine the bearing strength of the soil from the table below:*

**Bearing Strength of Soils**

**Soils and Safe Bearing Loads Lbs. Sq. Ft.**

Sound Shale	10,000
Cemented Gravel and *Sand-difficult to pick	4,000
Coarse & Fine *Compact Sand	3,000
Medium Clay - *Can be spaded	2,000
Soft Clay	1,000
Muck	0

*Step 3 – Divide the total thrust obtained in Step 1 by the bearing strength of the soil; this gives the square feet of area needed.*

Side Thrust on Curves – An outward pressure exists on all deflections from a straight line. Good soil, properly tamped, can be sufficient to hold side thrust – unless soil conditions are unstable. In that case, to anchor against this side thrust, the blocking should be placed against the pipe on each side of the coupling. Do not thrust block the coupling itself.

---

**Side Thrust**

<b>Pipe Size Inches</b>	<b>Side Thrust Pounds per Degree</b>
1 ½"	5.1
2"	7.9
2 ½"	11.6
3"	17.1
3 ½"	22.4
4"	28.3
5"	43.1
6"	60.8
8"	103.0
10"	160.0
12"	225.0

---

Based on side thrust per 100 lb./in<sup>2</sup> pressure per degree of deflection.

*Note: Multiply side thrust pounds by degrees of deflection times pounds of pressure divided by 100 to obtain total side thrust in pounds.*

5. 2,000-psi test minimum on thrust block meeting all ASTM specifications C-33 and C-150 or C-175 standards. **Note: Thrust blocks can differ depending on the type of fittings and soils. Contractor must review all conditions for adequate thrust. Furthermore, a joint restraint may be required to obtain and secure a fitting from movement.**
- E. Golf Grade Ductile Iron Fittings & Joint Restraints: **(for reference only - bid utilizing HDPE system)**
1. Fittings for bell and gasket pipelines shall be ductile iron, slant-bell design, and deep bell type. Fittings shall be manufactured of ductile iron, grade 65-45-12 in accordance with ASTM A-536. Fitting gaskets shall be in accordance with ASTM F-477. All ductile iron fittings shall be equipped with four 90-degree apart, outwardly extending radial lugs to accommodate for appropriate method of mechanical restraints.
  2. Fittings made from more than one piece shall utilize securely fastened bolt-on style spigot-bell links. Slip-on rings or loose rings as the method of attachment are not permissible.
  3. All tee fittings used to connect remote control valve and quick coupling assemblies to the mainline shall be ductile iron, deep bell service tees.
  4. All ductile iron bends; reducers, tees and gate valves shall be mechanically restrained. All bell and gasket joints adjacent to restrained joints shall be restrained in accordance to the manufacturers recommended design criteria and guides. **Note: Sites where ductile iron fittings without joint restraints and thrust blocks are acceptable in lieu of joint restraints and/or joint restraints that are used in cases of non-bearing soils or where joint restraints are used exclusively. See plans and details for actual site by site applications.**
  5. The mechanical joint restraint shall be capable of securing the PVC pipe directly to the ductile iron fitting without the use of bolts, links and adapters. The joint restraint shall be capable of securing PVC gasket pipe joints and gate valves without use of threaded rods. Joint restraints made for iron or steel pipe are not permissible.

6. The joint restraint shall be manufactured from ductile iron, grade 65-45-12 in accordance with ASTM A-536. Bolts and nuts used on joint restraints shall be provided as part of the restraint assembly.
7. All joint restraints shall be installed using methods recommended by the manufacturer. All bolts and must be tightened as per manufacturer’s recommended torque ratings.
8. The following table lists values for the minimum restrained length of pipe (“L”). Every joint within the distance “L” should be restrained. Bends require that all joints be restrained on both sides of the bend for the specified length. The most critical are capped pipe and gate valves installed at terminating points for future connections; these should be treated as Dead End applications.

*Table values are based on 125 psi test pressure, 2 feet cover, sand-clay type soil and safety factor of 2. For pressures other than 125 psi, multiply the “L” values by the actual pressure and divide by 100.*

**MATERIAL SPECIFICATIONS:**

Clamps and Tie Rods: Ductile Iron ASTM A-536  
 Bolts and Nuts: Low Alloy Steel standard 304 Stainless Steel (Optional)

Pipe Size (in)	Minimum Restrained Length (L), feet				Reductions (sizes down)		
	Bends (degrees)				1D	2D	DE
	11	22	45	90			
2	1	1	2	6	NA	NA	19
2.5	1	2	4	9	4	NA	23
3	2	3	5	11	8	10	30
4	2	4	9	20	14	20	45
6	3	6	13	29	30	40	63
8	4	8	15	38	33	55	83
10	5	9	19	45	31	56	100
12	5	10	21	53	54	58	118

**Notes:**

*1D reduction denotes one size down (such as 4x3, 12x10)*

*2D reduction denotes two sized down (i.e. 4x2.5, 12x8)*

*DE is a dead end (for a cap, plug or a gate valve.)*

*More detailed tables are available upon request.*

9. Butt Fusion Fittings - Fittings shall be PE 4710 with a minimum cell classification of PE 445474C. Butt Fusion molded Fittings shall have a manufacturing standard of ASTM D3261. Molded & fabricated fittings shall have the same minimum pressure rating as the pipe unless otherwise specified on the plans. Fabricated fittings are to be manufactured to meet the FM (Factory Mutual) performance standards. Fabricated fittings are to be manufactured using a Data Logger. Reference to the Data Logger quality control records should be referenced from an indented stamp in each fusion bead of each fitting. Temperature, fusion pressure and a graphic representation of the fusion cycle shall be part of the quality control records.
10. Flanged and Mechanical Joint Adapters - Flanged and Mechanical Joint Adapters shall be PE 4710 resin with a minimum cell classification of PE 445474C. Flange adapters and Mechanical Joint Adapters shall have the same pressure rating as the pipe unless otherwise specified on the plans.
11. Ductile iron joint restraints shall be installed on all fittings and gate valves for all IPS-Size, ring joint PVC pipe. The joint restraint shall be capable of securing the PVC pipe directly to the lugs on the Leemco deep bell ductile iron fittings without the use of bolts, links and adapters. The joint restraint shall be capable of securing PVC pipe to PVC pipe and PVC pipe to ring joint gate valves without the use of threaded linkages. All ductile iron fittings shall be secured to full-length pipes and on all bends and tee branches, the next joint of the pipe shall be secured. At least two full lengths of pipe must be secured when attached to

bends and tee branched 8" and larger, and at least three full lengths of pipe must be secured to dead end pipe. Pipe joints that occur in less than full-length when attached to a fitting shall also be secured.

12. All fittings shall be deep bell, manufactured specifically for IPS-Size pipe and made of Grade 65-45-12 ductile iron. Fittings 4" and larger shall have slanted bells to allow deflection of pipe in all planes. Fittings shall have four lugs at each push-on joint with ribbed and cupped gasket design, made from EDPM elastomer.
13. All quick coupling valves shall be fitted with stabilizers. Quick coupling stabilizers shall be manufactured in Grade 65-45-12 ductile iron; shall attach to the hex portion of the valve and be secured with a single bolt. Stabilizer shall have 12" span and be capable of resisting rotational and vertical motions.

## PART 3 - EXECUTION

### 3.1 INSPECTION

- A. Examine final grades and installation conditions. Do not start irrigation system work until unsatisfactory conditions are corrected and approved by Owner or Irrigation Consultant.

### 3.2 PREPARATION

- A. Layout and stake the location of each pipe run and all sprinkler heads and sprinkler valves and controllers. Obtain Irrigation Consultant's acceptance of layout prior to excavating and/or construction.
- B. Strip sod for pipe trenches with a mechanical sod stripper uniformly 1" to 1-1/2" thick with clean-cut edges (for existing turf only).
- C. Remove existing paving for sleeve installation. Saw cut existing paving to provide uniform straight transition at new to existing paving, owner to approve application.
- D. Place sleeves as indicated for installation of piping and control wire.

### 3.3 INSTALLATION

- A. Excavating and backfilling:
  - 1. Excavation shall include all materials encountered, except materials that cannot be excavated by normal mechanical means.
  - 2. Excavate trenches of sufficient depth and width to permit proper handling and installation of pipe and fittings.
  - 3. If the pulling method is used, the pipe "plow" shall be vibratory type. Starting and finishing holes for pipe pulling shall not exceed a 1'-0" by 3'-0" opening.
  - 4. Excavate to depths required to provide 4" minimum depth of amended earth fill or sand bedding, free of all rock, and debris, for piping on all sides and bottom of pipe when rock or other unsuitable bearing material is encountered.
  - 5. Fill to match adjacent grade elevations with approved earth fill material. Place and compact fill in layers not greater than 8" depth.
    - a. Provide approved earth fill or sand to a point 4" above the top of pipe - free of rock and debris
    - b. Fill to within 6" of final grade with approved excavated or borrows fill materials free of lumps or rocks larger than 2" in any dimension.
    - c. Provide clean topsoil fill free of rocks and debris for top 6" of fill.
  - 6. Except as indicated, install irrigation main lines with a minimum cover of 24" based on finished grades with a minimum depth of 30". Install irrigation lateral lines with a minimum cover of 18" based on finished grades with a minimum depth of 24". No sweeping of lateral lines.
  - 7. Excavate trenches and install piping and fill during the same working day. Do not leave open trenches or partially filled trenches open overnight.
  - 8. Replace stripped sod in sufficient time to allow for satisfactory sod recovery and growth. Water stripped and reinstalled sod until irrigation system is placed in operation (irrigation contractor to return turf to original condition or better). Existing turf conditions only.
  - 9. Replace paving of same materials, using joints and patterns to match existing adjoining paving surfaces.
  - 10. Backfill shall be compacted to 95% standard proctor density. Contractor will be responsible for the restoration of all settlement for period of (2) years from acceptance as well as all pipe and/or fitting failures.
  - 11. **Vibratory pulling method to be employed on all greens, tees and fairways where 2"-3" HDPE piping is shown on plans. Note: Contractor must shoot or lay wire cable – pulling shall not be permitted. Furthermore, no pulling when encountering rocky soils.**
- B. Plastic pipe: N/A (HDPE Base Bid)

1. Install plastic pipe in accordance with manufacturer's installation instructions. Provide for thermal expansion and contraction.
  2. Saw cut plastic pipe. Use a square-in-sawing vice, to ensure a square cut. Remove burrs and shavings at cut ends prior to installation.
  3. Make plastic to plastic joints with solvent weld joints or slip seal joints. Use only solvent and purple cleaner recommended by the pipe manufacturer's instructions. Contractor shall make arrangements with pipe manufacturer for all necessary field assistance.
  4. Make plastic to metal joints with Sch. 80 piping.
  5. Make solvent weld joints in accordance with manufacturer's recommendations.
  6. Allow joints to set at least 24 hours before pressure is applied to the system.
  7. Maintain pipe interiors free of dirt and debris. Close open ends of pipe by acceptable methods when pipe installation is not in progress.
  8. All gasketed PVC pipe shall be installed per manufacturer's recommendation using appropriate gasket lube.
  9. Pulled pipe shall be solvent welded 36 hours in advance of pulling.
  10. Contractor shall not drag PVC pipe before installation.
  11. No substitution of smaller pipe, only larger sized pipe will be permitted.
  12. All piping must be installed as per manufacturer recommendations including piping velocity rates.
- C. Sprinklers, fittings, valves and accessories:
1. Install fittings, valves, sprinkler heads, swing joints and accessories in accordance with manufacturer's instructions.
  2. Set sprinkler heads perpendicular to finished grades, except as otherwise indicated.
  3. Obtain Irrigation Consultant's review and acceptance of height for proposed sprinkler heads and valves prior to installation.
  4. Locate sprinkler heads to assure proper coverage of indicated areas. Do not exceed sprinkler head spacing distances indicated (as per manufacturer recommendations).
  5. Install pop-up gear driven sprinklers on specified swing joint assemblies. (See Detail)
  6. Install quick coupling valves on specified swing joint assemblies. (See Detail)
  7. Install decoder sprinklers as detailed.
    - a. Ground controller in accordance with manufacturer's recommendations (10 OHMS or less) with Paige Electric plate configuration to get to 10 OHMS or less; measure by a meager device. It will be the responsibility of the contractor to prove such measurement before getting released from the said system installation. (See Plan & details).
- D. Paige Electric Wire Control Cable wiring:
1. Install electric control cable in the piping trenches wherever possible. Place wire in trench adjacent to pipe. Install wire with slack to allow for thermal expansion and contraction. Expansion joints in wire may be provided at 200-foot intervals by making 5-6 turns of the wire around a piece of 1/2" pipe instead of slack. Where necessary to run wire in a separate trench, provide a minimum cover of 18" or as per local codes.
  2. Provide sufficient slack at site connections at remote control valves in control boxes, and at all wire splices to allow raising the valve bonnet or splice to the surface without disconnecting the wires when repair is required.
  3. Connect each remote control valve or sprinkler head to one address of a central controller except as otherwise indicated.
  4. Connect remote control valves or sprinkler heads to a common ground wire system independent of all others.
  5. Make secondary wire connections to sprinkler heads, remote control electric valves and splices of wire in the field; using PE listed burial splice connectors (i.e.: 3M 3570G-N), in accordance with manufacturer's recommendations.
  6. Provide tight joints to prevent leakage of water and corrosion build-up on the joint.
  7. Provide new sleeves for all locations where existing sleeves are not indicated. Install new sleeves prior to paving installation wherever possible.

8. Install pipe sleeves under existing concrete or asphalt surface by jacking, boring, or hydraulic driving of the sleeve. Remove and replace existing concrete and asphalt surfaces where cutting is necessary. Obtain Owner's permission before setting existing concrete and asphalt surfaces. Where piping is shown under paved areas that are adjacent to turf areas, install the piping in the turf areas.
  9. One approved manufacturer shall be used for the entire project, no multiple manufacturers will be allowed for all wire, pipe, cement and primer etc.
- E. Flushing, testing and adjustment:
1. After sprinkler piping and swing joints are installed and before sprinkler heads are installed, open control valves and flush out the system with full head of water. Swing joints should be extended above grade by 2-3 feet above grade by a section of pipe. This will help prevent contaminate piping during flushing.
  2. Perform system testing upon completion of each section. Make necessary repairs and re-test repaired sections as required.
  3. Adjust sprinklers after installation for proper and adequate distribution of the water over the coverage pattern. Adjust for the proper arc of coverage.
  4. Test and demonstrate the controller by operating appropriate day, hour, and station selection features as required to automatically start and shut down irrigation cycles to accommodate plant requirements and weather conditions.
- F. Roadway/Railway Pipe Crossings (see plan) HDPE:
1. Contractor shall contact and obtain permission from all governing bodies and agencies.
  2. Contractor shall install piping, sleeving and wire sleeves in accordance with said agencies.
- G. Stream Pipe Crossings (see detail) HDPE with restraints:
1. HDPE DR11 4710.
  2. Piping shall be stable and restrained to stop movement of piping.
  3. 2" minimal wire sleeve of PVC Sch. 80 conduit (gray in color) or as per local codes, shall be supported separately.
- H. Bridge Crossings (see detail) HDPE with restraints:
1. Contractor is responsible for proper support system -See Plan
  2. All piping to be hidden inside bridge trusses and exited by prefabricated "Z" piping.
  3. "Z" piping restrained and/or connected with flanges.
- I. Service:
1. When requested, return to the site during the subsequent fall season and winterize the system. Drain all water from the system and blow out the system with compressed air.
  2. When requested, return to the site during the subsequent spring season and demonstrate to the Owner the proper procedures for the system start-up, operations, and maintenance (blow out climates only).
  3. Contractor required to service said system for one year after final acceptance.
- 3.4 SPARE PARTS
- A. Provide the following:
1. Four extra sprinkler head (s) of each size and type.
  2. Two extra valve access box(s) of each size and type.
  3. Ten quick coupler valve keys and swivel elbows.
  4. Two repair coupling for each size and type of pipe.
  5. Two tee handles for both style isolation valves 4'-0" in length.
  6. Two sets of repair tools.
- 3.5 DISPOSAL OF WASTE MATERIALS
- A. Transport unsuitable excavated material, including rock or lava to designated disposal areas on Owner's property. Stockpile or spread as directed. Remove from site and legally dispose of trash and debris.

- B. Maintain disposal routes clear, clean, and free of debris.

### 3.6 ACCEPTANCE

- A. Test and demonstrate to the Irrigation Consultant and Owner the satisfactory operation of the system free of leaks before final acceptance.
- B. Instruct the Owner's designated personnel in the operation of the system, including adjustment of sprinklers, controller (s) and central, valves and pump station(s).
- C. Upon acceptance the Owner will assume operation of the system. -See application for payment

### 3.7 CLEANING

- A. Perform cleaning during installation of the work and upon completion of the work. Remove from site all excess materials, soil, debris, and equipment. Repair damage resulting from irrigation system installation.

## **PART 4 - ELECTRICAL**

### **4.1 APPLICABLE STANDARDS**

- A. All apparatus, materials and work, shall be in accordance with standards, practices and codes of the electrical industry. Particular attention is directed to requirements of ANSI/NFPA 70 and Underwriters Laboratories, Inc. as suitable for purposes specified and shown.
- B. The completed irrigation installation shall conform to all local and special laws, codes or ordinances of all Federal, State and municipal authorities with due jurisdiction.

### **4.2 PROJECT CONDITIONS**

- A. Locations of all controllers, heads and other elements of the system are to be approved by Owner or Owner's Representative before wiring is installed.
- B. Conductor sizes are based on copper.
- C. Wire and cable routing shown on the drawings are approximate. Route wire as required meeting project conditions.-See plan
- D. Take precautions to avoid damage to existing site elements and features, including wiring and piping for existing underground irrigation system. Promptly repair damage to such features, cost at Contractor's expense

### **4.3 PRIMARY CABLE – (AS APPLICABLE SATELLITE ONLY – SEE PLAN NOTES)**

- A. All power cables are Tray Cable (or approved equal); they are to be UL listed for direct burial, and rated at 600 volts. The cable shall include three conductors, which are to be colored per wire industry standard or numbered as 1, 2, and 3. The size of the "hot" and "common" conductors are to be as shown on the irrigation plans, and the size of the "equipment ground" conductor as required by the National Electrical Code, or larger. The inner copper conductors are to be covered with high dielectric PVC and Nylon. The outer jacket will be black PVC and is to be sunlight resistant. (Paige Electric Co., (or approved equal) LP specification number P7266D for 10 AWG and smaller and specification number P7267D for 8 AWG and larger.)
- B. Conduit: All branch circuit wires, for 120 volts and higher, shall be installed in electrical conduit. The wires shall be type THWN and sized according to the irrigation system plans. Paige Electric Co., LP specification number P7316. Installation shall meet all local codes and regulations as well as NEC requirements for burial conduit piping. The total cross-sectional area of the wires sleeved through the electrical conduit shall be no more than 40% of the internal cross-sectional area of the conduit.

### **4.4 SECONDARY CABLE – (24VAC WIRE)**

- A. Construction requirements for a #12 white UL Approved burial wire trunk and #14 red UL Approved burial wire (unless noted on plan) design to operate valve decoders consisting of tin coated copper conductors, insulated with PVC and having a high density polyethylene direct burial jacket. Conductors are UL approved Type UF. Soft annealed tin coated copper conforming to ASTM B-33. Polyvinyl Chloride conforming to UL Standard 493 for Type UF/TWU rated 75°C. Pressure Extruded High Density PE conforming to ICEA S-61-402 and NEMA WC5 Jacket Thickness 3/64" minimum jacket material to completely fill interstices between the two insulated conductors. Color coding of jacket shall be of one solid color. Standard colors red, blue, green, yellow, black, white. (Paige Electric Co., (or approved equal).

### **4.5 EARTH GROUNDING**

- A. It is the responsibility of the installer to connect all electronic equipment for which they are responsible to earth ground in accordance with Article 250 of the National Electrical Code (NEC). Grounding components will include the items described in the following paragraphs, at a minimum.

- B. Use grounding electrodes that are UL listed or manufactured to meet the minimum requirements of Article 250 of the NEC. At the very minimum, the grounding circuit will include a copper clad steel ground rod, a solid copper ground plate and 100 pounds of PowerSet® earth contact material, as defined. See detail.
- C. Ground rods are to have a minimum diameter of 5/8" and a minimum length of 10 feet. These are to be driven into the ground in a vertical position or an oblique angle not to exceed 45 degrees at a location 10 feet from the electronic equipment, the ground plate, or the wires and cables connected to said equipment. See detail.
- D. The rod is to be stamped with the UL logo (Paige Electric part number 182007.) A 6 AWG solid bare copper wire (about 12 feet long) shall be connected to the ground rod by the installer using a Cadweld GR1161G "One-Shot" welding kit (Paige Electric part number 1820037.) This wire shall be connected to the electronic equipment ground lug. See detail.
- E. The copper grounding plate assemblies (Paige Electric part number 182199L) will have minimum dimensions of 4" x 96" x 0.0625". A 25-foot continuous length (no splices allowed unless using exothermic welding process) of 6 AWG solid bare copper wire is to be attached to the plate by the manufacturer using an approved welding process. This wire is to be connected to the electronic equipment ground lug as shown in the detail of page 1. The ground plate is to be installed to a minimum depth of 30", or below the frost line if it is lower than 30", at a location 8 feet from the electronic equipment and underground wires and cables. Two 50-pound bags of PowerSet® with a neutral PH value (Paige Electric part number 1820058) earth contact material must be spread so that it surrounds the copper plate evenly along its length within a 6" wide trench. Salts, fertilizers, bentonite clay, cement, coke, carbon, and other chemicals are not to be used to improve soil conductivity because these materials are corrosive and will cause the copper electrodes to erode and become less effective with time.
- F. Install all grounding circuit components in straight lines. When necessary to make bends, do not make sharp turns. To prevent the electrode-discharged energy from re-entering the underground wires and cables, all electrodes shall be installed away from said wires and cables. The spacing between any two electrodes shall be as shown in the detail of page 1, so that they don't compete for the same soil.
- G. The earth-to-ground resistance of this circuit is to be measured using a Megger® or other similar instrument, and the reading is to be no more than 10 ohms. If the resistance is more than 10 ohms, additional ground plates and PowerSet® with a neutral PH value are to be installed in the direction of an irrigated area at a distance of 10', 12', 14', etc. It is required that the soil surrounding copper electrodes be kept at a minimum moisture level of 15% at all times by dedicating an irrigation station at each controller location. The irrigated area should include a circle with a 10-foot radius around the ground rod and a rectangle measuring 1-foot x 24-feet around the plate.
- H. All underground circuit connections are to be made using an exothermic welding process by utilizing products such as the Cadweld "One-Shot" kits. Solder shall not be allowed to make connections. In order to ensure proper ignition of the "One-Shot", the Cadweld T-320 igniter must be utilized (Paige Electric part number 1820040.) The 6 AWG bare copper wires are to be installed in as straight a line as possible, and if it is necessary to make a turn or a bend it shall be done in a sweeping curve with a minimum radius of 8" and a minimum included angle of 90°. Mechanical clamps shall be permitted temporarily during the resistance test process, but are to be replaced with Cadweld "One-Shot" kits immediately thereafter.

#### 4.6 BONDING

- A. Said grounding circuit is referred-to as "supplementary grounding" in the NEC. And for safety reasons, the NEC required that all supplementary grounds be "bonded" to each other and to the service entrance ground (power source) as shown. This is also "recommended practice" of IEEE Standard 1100-1999. Note that this is in addition to the equipment ground, which is commonly referred to as "the green wire." The power wires (black, white and green for 120

VAC and black, red and green for 240 VAC) must always be kept together in a trench/conduit/tray/etc. The bonding conductors are to be 6 AWG solid bare copper unless the system power conductors are larger than 1/0 AWG, in which case they are to be 4 AWG solid bare copper. All splices to the bonding conductors shall be made using a Cadweld “One-Shot” kit. See details. (Paige Electric part number 1820074)

#### 4.7 SHIELDING

- A. The bonding conductors are to be installed in such a way so that they act as shielding conductors. This becomes a network of solid bare copper wire over all the main bundles of other wires and cables, see details. The bare copper wire is to be installed as close to the surface as possible yet being sufficiently below the ground level as to prevent damage from maintenance equipment such as aerators. And it must be placed above all other valve/power/communication wires and cables, per detail, and installed in all trenches as shown on the electrical plan drawings. It is not necessary to install this conductor over short wire runs (less than 150 feet) away from the main wire bundles. The conductor is laid in as straight a line as possible, and when necessary to make bends, do so in a sweeping motion using the detail as a guideline.

#### 4.8 EXECUTION

##### A. General

1. Installation of wiring shall be in accordance with Section IV Irrigation System and in accordance to irrigation system manufacturer’s instructions.
2. Any wire or cable that is stressed or damaged in any way shall be replaced at the Contractor’s expense.
3. Make splices with approved connector assembly as specified in Section IV Irrigation System.
4. Inspect wire and cable for physical damage and proper connection. Verify continuity of each control circuit.
5. Wire and Cable Installation: Wire and cable burial depth is dictated by the National Electrical Code®. Temperature changes cause wires and cables to expand and contract as much as 1% of the length. And high voltage power lines create large electro-magnetic fields that cause interference and corrupt signals in communication lines. It is therefore necessary to take certain precautions when installing these products.
6. The contractor shall install all wires and cables carrying up to 30 volts at a minimum burial depth of 6”. If mechanical equipment, such as aerifiers and shovels, are expected to disturb the area, then the wires and cables shall be installed at a 12” depth. For wires and cables carrying more than 30 volts and less than 600 volts, the minimum burial depth shall be 24”. When installing wires and cables in a trench, they must be “snaked” so that some slack is created. At points along the trench where there are sharp bends, a loop of 12” to 24” shall be created to allow for shrinkage. When communication cables are in the same trench as power wires, there shall be a minimum separation between them of 12”.
7. Wire and Cable Splices: All electrical connections shall incorporate:
  - a. A solid mechanical connection of the copper conductors.
  - b. Electrical insulation of the mechanical connection.
  - c. A means to waterproof the insulated connection.
  - d. “Strain-relief” to prevent the connection from coming apart when wires/cables are pulled-upon.

End of Specifications

**ATTACHMENT A –  
INSURANCE REQUIREMENTS**

**ATTACHMENT A.6**  
**INSURANCE REQUIREMENTS**  
**ROUTINE CONSTRUCTION, MAINTENANCE AND REPAIR PROJECTS**

Contractor shall obtain insurance of the types and in the amounts listed below.

**A. COMMERCIAL GENERAL AND UMBRELLA LIABILITY INSURANCE**

Contractor shall maintain commercial general liability (CGL) and, if necessary, commercial umbrella insurance with a limit of not less than \$1,000,000 each occurrence. If such CGL insurance contains a general aggregate limit, it shall apply separately to this project/location.

CGL insurance shall be written on Insurance Services Office (ISO) occurrence form CG 00 01 10 93, or a substitute form providing equivalent coverage, and shall cover liability arising from premises, operations, independent contractors, products-completed operations, personal injury and advertising injury, and liability assumed under an insured contract (including the tort liability of another assumed in a business contract).

Owner shall be included as an insured under the CGL, using ISO additional insured endorsement CG 20 10 or a substitute providing equivalent coverage, and under the commercial umbrella, if any. This insurance shall apply as primary insurance with respect to any other insurance or self-insurance afforded to Owner.

There shall be no endorsement or modification of the CGL limiting the scope of coverage for liability arising from pollution, explosion, collapse, or underground property damage.

**B. CONTINUING COMPLETED OPERATIONS LIABILITY INSURANCE**

Contractor shall maintain commercial general liability (CGL) and, if necessary, commercial umbrella liability insurance with a limit of not less than \$1,000,000 each occurrence for at least one (1) year following substantial completion of the work.

Continuing CGL insurance shall be written on ISO occurrence form CG 00 01 10 93, or substitute form providing equivalent coverage, and shall, at minimum, cover liability arising from products-completed operations and liability assumed under an insured contract.

Continuing CGL insurance shall have a products-completed operations aggregate of at least two times its each occurrence limit.

Continuing commercial umbrella coverage, if any, shall include liability coverage for damage to the insured's completed work equivalent to that provided under ISO form CG 00 01.

**C. BUSINESS AUTO AND UMBRELLA LIABILITY INSURANCE**

Contractor shall maintain business auto liability and, if necessary, commercial umbrella liability insurance with a limit of not less than \$1,000,000 each accident. Such insurance shall cover liability arising out of any auto including owned, hired and non-owned autos.

Business auto insurance shall be written on Insurance Services Office (ISO) form CA 00 01, CA 00 05, CA 00 12, CA 00 20, or a substitute form providing equivalent liability coverage. If necessary, the policy shall be endorsed to provide contractual liability coverage equivalent to that provided in the 1990 and later editions of CA 00 01.

**D. WORKERS COMPENSATION INSURANCE**

Contractor shall maintain workers compensation as required by statute and employers liability insurance. The commercial umbrella and/or employers liability limits shall not be less than \$1,000,000 each accident for bodily injury by accident or \$1,000,000 each employee for bodily injury by disease.

If Owner has not been included as an insured under the CGL using ISO additional insured endorsement CG 20 10 under the Commercial General and Umbrella Liability Insurance required in this Contract, the Contractor waives all rights against Owner and its officers, officials, employees, volunteers and agents for recovery of damages arising out of or incident to the Contractor's work.

## **E. GENERAL INSURANCE PROVISIONS**

- 1. Evidence of Insurance.** Prior to beginning work, Contractor shall furnish Owner with a certificate(s) of insurance and applicable policy endorsement(s), executed by a duly authorized representative of each insurer, showing compliance with the insurance requirements set forth above.

All certificates shall provide for 30 days written notice to Owner prior to the cancellation or material change of any insurance referred to therein. Written notice to Owner shall be by certified mail, return receipt requested.

Failure of Owner to demand such certificate, endorsement or other evidence of full compliance with these insurance requirements or failure of Owner to identify a deficiency from evidence that is provided shall not be construed as a waiver of Contractor's obligation to maintain such insurance.

Owner shall have the right, but not the obligation, of prohibiting Contractor or any subcontractor from entering the project site until such certificates or other evidence that insurance has been placed in complete compliance with these requirements is received and approved by Owner.

Failure to maintain the required insurance may result in termination of this Contract at Owner's option.

With respect to insurance maintained after final payment in compliance with a requirement above, an additional certificate(s) evidencing such coverage shall be promptly provided to Owner whenever requested.

Contractor shall provide certified copies of all insurance policies required above within 10 days of Owner's written request for said copies.

- 2. Acceptability of Insurers.** For insurance companies which obtain a rating from A.M. Best, that rating should be no less than A VII using the most recent edition of the A.M. Best's Key Rating Guide. If the Best's rating is less than A VII or a Best's rating is not obtained, the Owner has the right to reject insurance written by an insurer it deems unacceptable.
- 3. Cross-Liability Coverage.** If Contractor's liability policies do not contain the standard ISO separation of insureds provision, or a substantially similar clause, they shall be endorsed to provide cross-liability coverage.
- 4. Deductibles and Self-Insured Retentions.** Any deductibles or self-insured retentions must be declared to the Owner. At the option of the Owner, the Contractor may be asked to eliminate such deductibles or self insured retentions as respects the Owner, its officers, officials, employees, volunteers and agents or required to procure a bond guaranteeing payment of losses and other related costs including but not limited to investigations, claim administration and defense expenses.
- 5. Subcontractors.** Contractor shall cause each subcontractor employed by Contractor to purchase and maintain insurance of the type specified above. When requested by the Owner, Contractor shall furnish copies of certificates of insurance evidencing coverage for each subcontractor.

## **F. INDEMNIFICATION**

To the fullest extent permitted by law, the Contractor shall indemnify and hold harmless the Owner and the Architect and their officers, officials, employees, volunteers and agents from and against all claims, damages, losses and expenses including but not limited legal fees (attorney's and paralegal's fees and court costs), arising

out of or resulting from the performance of the Contractor's work, provided that any such claim, damage, loss or expense (1) is attributable to bodily injury, sickness, disease or death, or injury to or destruction of tangible property, other than the work itself, including the loss of use resulting therefrom and (2) is caused in whole or in part by any wrongful or negligent act or omission of the Contractor, any Subcontractor, anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable, except to the extent it is caused in part by a party indemnified hereunder. Such obligation shall not be construed to negate, abridge, or otherwise reduce any other right or obligation of indemnity which would otherwise exist as to any party or person described in this Paragraph. Contractor shall similarly protect, indemnify and hold and save harmless the Owner, its officers, officials, employees, volunteers and agents against and from any and all claims, costs, causes, actions and expenses including but not limited to legal fees, incurred by reason of Contractor's breach of any of its obligations under, or Contractor's default of, any provision of the Contract.

## SAMPLE LIABILITY INSURANCE ENDORSEMENT

**The following spaces preceded by an asterisk (\*) need not be completed if this endorsement and policy have the same inception date.**

ATTACHED TO AND FORMING PART OF POLICY NUMBER	*EFFECTIVE DATE OF ENDORSEMENT	*ISSUED TO
--	-----------------------------------	------------

This endorsement changes the policy. Please read it carefully.

### AUTOMATIC ADDITIONAL INSUREDS

The following provision is added to (SECTION II), Who Is An Insured.

5. Any entity you are required in a written contract (hereinafter called Additional Insured) to name as an insured is an insured but only with respect to liability arising out of your premises, “your work” for the Additional Insured, or acts or omissions of the Additional Insured in connection with the general supervision of “your work” to the extent set forth below.
  - a. The Limits of Insurance provided on behalf of the Additional Insured are not greater than those required by such contract.
  - b. The coverage provided to the Additional Insured(s) is not greater than that customarily provided by the policy forms specified in and required by the contract.
  - c. All insuring agreements, exclusions and conditions of this policy apply.
  - d. In no event shall the coverages or Limits of Insurance in this Coverage Form be increased by such contract.

Except when required otherwise by contract, this insurance does not apply to:

- 1) “Bodily injury” or “property damage” occurring after
  - a) All work on the project (other than service, maintenance or repairs) to be performed by or on behalf of the Additional Insured(s) at the site of the covered operations has been completed; or
  - b) That portion of “your work” out of which the injury or damage arises has been put to its intended use by any person or organization other than another contractor or subcontractor engaged in performing operations for a principal as a part of the same project.
- 2) “Bodily injury” or “property damage” arising out of any act or omission of the Additional Insured(s) or any of their employees, other than the general supervision of work performed for the Additional Insured(s) by you.
- 3) “Property damage” to
  - a) Property owned, used or occupied by or rented to the Additional Insured(s);
  - b) Property in the care, custody or control of the Additional Insured(s) or over which the Additional Insured(s) is for any purpose exercising physical control; or

- c) “Your work” for the Additional Insured(s).

With respect to Additional Insureds who are architects, engineers or surveyors, this insurance does not apply “bodily injury”, “property damage”, “personal injury” or “advertising injury” arising out of the rendering of or the failure to render any professional services by or for you, including:

- a) The preparing, approving, or failing to prepare or approve maps, drawings, opinions, reports, surveys, change orders, designs or specifications; and
- b) Supervisory, inspection or engineering services.

Any coverages provided hereunder shall be excess over any other valid and collectible insurance available to the Additional Insured(s) whether primary, excess, contingent or on any other basis unless a contract specifically requires that this insurance be primary or you request that it apply on a primary basis.

No person or organization is an Additional Insured with respect to the conduct of any current or past partnership or joint venture that is not shown as a Named Insured in the Declarations.

END OF ATTACHMENT A.6

**ATTACHMENT B –  
SOLICITATION AND HIRING FOR QUALIFYING CONSTRUCTION CONTRACTS & FORMS**

- QUALIFYING CONSTRUCTION CONTRACTS POLICY
- SUMMARY SHEET
- CERTIFICATE OF EQUAL EMPLOYMENT OPPORTUNITY COMPLIANCE FOR CONTRACTORS & VENDORS
- WORKFORCE PROFILE AND INSTRUCTIONS
- COMPANY OWNERSHIP CERTIFICATION
- MINORITY/WOMEN OWNED CONTACT SHEET
- CONTRACTOR/SUBCONTRACTOR WORKFORCE PLAN
- APPENDIX A OF 44 ILL ADMIN CODE 750

## SECTION III BUSINESS

### 5.00 SOLICITATION AND HIRING FOR QUALIFYING CONSTRUCTION CONTRACTS

#### .01 OBJECTIVE

The Peoria Park District Staff and Board believe that diversity and equity are central to our mission. Diversity of race, color, gender, disability, age, and culture in our employees and those we work with is important to fairly represent the same diversity in our community. The differing perspectives available from a diverse workforce are important to solving the complex problems of our community.

As one of the four pillars of the **Peoria Park District's 4-Pronged Approach to Equity** document, **Pillar #3** is to **Actively Promote and Encourage the Diversity, Equity and Inclusiveness of Peoria Park District funded Contractors and Suppliers.**

The Peoria Park District actively promotes and encourages maximum participation of minorities and women on Peoria Park District construction, procurement, and maintenance contracts to ensure that those we serve and those we work with look like the residents of our community.

This goal is established with the following objectives in mind:

- (A) To ensure that construction contracts are awarded and administered in a nondiscriminatory manner;
- (B) To meet the goals and requirements of the Illinois Human Rights Act ("Act") which requires that every party to a public contract and every eligible bidder shall refrain from unlawful discrimination and undertake affirmative action to assure equality of employment opportunity and eliminate the effects of past discrimination (775 ILCS 5/2-105(A)(1) and of the Illinois Administrative Code ("Code") which requires public contractors and subcontractors to determine if minority persons or women are underutilized in any job classification and, if such underutilization exists, to take appropriate affirmative action to rectify underutilization (44 Ill Admin Code 750.110 and 750.120);
- (C) To promote the District's use of Minority-Owned and Women-Owned Businesses by removing barriers and encouraging a level playing field on which such businesses can compete fairly for construction contracts;
- (D) To strive to increase capacity and participation of minority and women labor as well as Minority-Owned and Women-Owned Businesses for Peoria Park District construction projects; and
- (E) To ensure that goals for Minority-Owned and Women-Owned Businesses are narrowly tailored in accordance with applicable law.

The Park Board recognizes that it is required to comply with applicable bidding laws, federal and state constitutions, statutes, and rules and regulations, as well as any applicable local ordinances.

## .02 DEFINITIONS

For the purpose of this Policy, the terms set forth below shall have the following definitions:

"Minority Person" shall mean a person who is a citizen or lawful permanent resident of the United States and who is any of the following: (a) American Indian or Alaska Native (a person having origins in any of the original peoples of North and South America, including Central America, and who maintains tribal affiliation or community attachment); (b) Asian (a person having origins in any of the original peoples of the Far East, Southeast Asia, or the Indian subcontinent, including, but not limited to, Cambodia, China, India, Japan, Korea, Malaysia, Pakistan, the Philippine Islands, Thailand, and Vietnam); (c) Black or African American (a person having origins in any of the black racial groups of Africa); (d) Hispanic or Latino (a person of Cuban, Mexican, Puerto Rican, South or Central American, or other Spanish culture or origin, regardless of race); and (e) Native Hawaiian or Other Pacific Islander (a person having origins in any of the original peoples of Hawaii, Guam, Samoa, or other Pacific Islands).

"Woman" shall mean a person who is a citizen or lawful permanent resident of the United States and who is of the female gender.

"Minority-Owned Business" means a business which is at least 51% owned by one or more minority persons, or in the case of a corporation, at least 51% of the stock in which is owned by one or more minority persons; and the management and daily operations of which are controlled by one or more of the minority individuals who own it.

"Women-Owned Business" means a business which is at least 51% owned by one or more women, or in the case of a corporation, at least 51% of the stock in which is owned by one or more women; and the management and daily operations of which are controlled by one or more of the women who own it.

"Qualifying Construction Contract" or "Qualifying Construction Contracts" means any any or all construction projects with an estimated total base cost of \$50,000 or more.

"Responsible Bidder" means a person who has the capability in all respects to perform fully the contract requirements and who has the integrity and reliability that will assure good faith performance. Past performance may be considered as a part of this analysis. This further requires that the bidder is in compliance with the Act and Code.

"Responsive Bidder" means a person who has submitted a bid that conforms in all material respects to the invitation for bids.

"Subcontractor" includes any sub-subcontractors or any more remote contractors on the job.

Any definition above or herein that is not consistent with existing or subsequently added or amended provisions of the Act or Code shall be deemed modified to be consistent with the Act or Code. Any term used herein but not explicitly defined shall have the same meaning as in the Act or Code.

### .03 PARTICIPATION GOALS AND AFFIRMATIVE STEPS

(A) Goals:

It is a goal of the Peoria Park District to ensure that the goals and provisions of the Act and Code are met and to encourage participation of minorities and women on Park District Qualifying Construction Projects.

Peoria Park District shall as permitted by law:

(1) endeavor to award not less than 20% of the total dollar amount of the Park District's Qualifying Construction Contracts to Minority-owned Businesses and not less than 5% of the total dollar amount of the Park District's Qualifying Construction Contracts to Women-owned Businesses ("Participation Goals"); and

(2) endeavor to ensure that a minimum of 20% of the total hours worked on any Qualifying Construction Contract are performed by Minority Persons and a minimum of 5% of the total hours worked are performed by Women ("Workforce Goals").

(B) Affirmative Steps:

Peoria Park District shall take the following affirmative steps to ensure that the aforesaid goals are met in respect to Qualifying Construction Projects:

1) Require that all contractors and subcontractors, as a part of their bid submission documents, provide information demonstrating that the contractor or subcontractor has examined all of its job classifications to determine if minority persons or women are underutilized in any classification, and if so, what affirmative action was taken to rectify that underutilization. (44 Ill Admin Code 750.110 (b) and 750.120);

2) Require that if a contractor or subcontractor hires additional employees in order to perform the contract or portion of the contract, it will determine the availability of minorities and women in the areas from which it might reasonably recruit and will hire for each job classification in a way that minorities and women are not underutilized (44 Ill Admin Code 750.110(c) and 120);

3) Include as a part of all contracts, and require as a part of all subcontracts, the Equal Opportunity Clause set forth in Appendix A of 44 Ill Admin Code 750;

4) Place qualified Minority-Owned and Women-Owned Businesses on solicitation lists;

5) Require that Minority-Owned and Women-Owned Businesses are solicited whenever they are potential sources, at varying sizes of projects;

6) Include in all advertisements for bid (legal notice in the Peoria Journal Star), "Bidders are also advised that contract documents for this project include the non-discrimination, equal opportunity and affirmative action provisions in the Human Rights Act and rules and regulations of

the Department of Human Rights. The Peoria Park District is an EEO organization and encourages participation by minority and female-owned firms.”

- 7) Notify applicable plan rooms and diverse agencies which have specific outreach and contacts with local Minority-Owned Businesses or Women-Owned Businesses of current projects out for bid to encourage the broadest notification to Minority-Owned Businesses and Women-Owned Businesses;
- 8) Include in all bid documents, a current list of Minority-Owned and Women-Owned Businesses for general contractors to be able to contact;
- 9) Provide access to a website for free download ability of bid documents for all contractors, including Minority-Owned Businesses and Women-Owned Business;
- 10) When economically feasible and legally permissible, divide construction projects into smaller tasks or quantities to permit maximum participation by Minority-Owned and Women-Owned Businesses;
- 11) Establish project and delivery schedules, when feasible, that encourage participation by Minority-Owned and Women-Owned Businesses;
- 12) Provide the following documentation in staff recommendations to the Park Board: all contractors and agencies notified of the work, all contractors known to download the bid documents, all contractors that bid on the work, which contractors and subcontractors are minority or women owned; the racial, ethnic, and gender breakdown of the contractor and subcontractor workforce on the form provided by PPD; and whether the contractor or subcontractor has violated any law or ordinance, failed to follow any PPD policies, or breached any contract with the PPD in the past;
- 13) Track final statistics of Peoria Park District construction projects for Minority-Owned Businesses and Women-Owned Businesses and workforce participation numbers quarterly and annually;
- 14) Require the general contractor on Qualifying Construction Contracts, if subcontracts are to be let, to follow the Good Faith Effort requirements defined below.

*Good Faith Effort* is defined as follows:

A good faith effort means the contractor actively and aggressively sought participation by Minority-Owned and Women-Owned Businesses and/or employment of Minority Persons and Women and to meet all requirements of the Act and Code.

Evidence of good faith effort includes, as appropriate:

- Meeting the requirements of the Act and Code as set forth above on an ongoing basis
- Based on the trades and availability of contractors required to complete the project, a

minimum of three minority/women owned firms must be contacted. The Park District's list of minority/women owned firms will be included in all bid documents.

- The bidder shall negotiate in good faith with the potential minority/women owned firms by not imposing any conditions which are not similarly imposed on all other subcontractors and suppliers, or by denying benefits ordinarily conferred on subcontractors or suppliers for the type of work for which bids were solicited. Minority and women owned businesses must be notified at least 3 business days prior to bid opening to allow adequate time to review and provide bid.
- On all Qualifying Construction Contracts, the bidder must complete and include in the bid, the **Minority/Women Owned Contact Sheet** form. This form will include name of companies contacted, the time and date companies were contacted, the method by which the companies were contacted, the response by the companies contacted, the area of work the companies were contacted about, and bid amounts received from the companies along with other comments.
- The low bidder shall provide to the Park District upon request, copies of all correspondence including without limitation, faxes, letters, text messages, and emails sent to minority/women owned firms.
- Assisting interested Minority-owned and Women-owned Businesses in obtaining bonding, lines of credit and insurance;
- Seeking services from available minority and women community organizations, contractors' groups, business assistance offices and other organizations, as appropriate, to provide assistance in recruiting Minority owned and Women-owned Businesses;
- Providing payroll records or other evidence showing the percentage of Minority Persons and Women employees;
- If a Minority-owned or Women-owned Business is rejected, providing sound reasons for rejection;
- Assisting interested Minority-owned and Women-owned Businesses in obtaining necessary equipment, supplies or materials;
- Placing qualified Minority-Owned and Women-Owned Businesses on solicitation lists;
- Ensuring that Minority-Owned and Women-Owned Businesses are solicited whenever they are potential sources, at varying sizes of projects; and
- When economically feasible and legally permissible, dividing construction projects into smaller tasks or quantities to permit maximum participation by Minority-Owned and Women-Owned Businesses

- All other good faith efforts or evidence of due diligence to meet the Park District's Workforce Goals;

#### .04 CONTRACT BID DOCUMENTS AND AWARD

The Park District shall include within the bid documents for each Qualifying Construction Contract:

- (A) A copy of this policy (Section 5.00);
- (B) An identification of what documents are required to be submitted as a part of the bid under this policy;
- (C) Such documents as will assist in determining compliance with this policy (including without limitation, Company Ownership Form, EEO Form, Workforce Profile, Minority/Women Owned Contact Sheet, Contractor/Subcontractor Workforce Plan);
- (D) A requirement that the contractor meet the Park District's Workforce Goals or provide evidence of a good faith effort toward meeting the goals;
- (E) Appendix A of 44 Ill Admin Code 750;
- (F) Notice that all subcontracts must make reference to and incorporate the provisions of this policy. To the extent a subcontract does not reference and incorporate the provisions of this policy, the contractor will be deemed in breach of contract and in violation of this policy, and shall be subject to the provisions of Section .05. below; and
- (G) Such other documents as deemed appropriate.

Contracts will be awarded to the lowest Responsible and Responsive Bidder. Bids or proposals submitted without the required documentation identified in this policy are considered unresponsive and will be rejected.

#### .05 PROGRAM ADMINISTRATION

- (A) The Executive Director or designee shall administer and enforce the provisions of this policy;
- (B) The Park District Board, prior to voting on an applicable contract award, shall be provided information showing the bidder's compliance with this policy;
- (C) The Executive Director or designee shall monitor, track, and report contractors' compliance with this policy over the contract duration to ensure compliance with this policy, including prompt reporting of potential violations to the DEIA Committee and Park District Board. The Park District Board, after five (5) days' notice to the contractor and allowing the

contractor to make a presentation to the Park District Board, shall make a final determination of whether a violation has occurred and what penalty or remedy should be imposed for such violation. Potential penalties or remedies include, but are not limited to, termination of any contract or subcontract, corrective action steps, PPD's contractual remedies, or that the PPD will not consider that contractor to be a responsible bidder, in accordance with Section 8-1(c) of the Park District Code, 70 ILCS 1205/8-1(c), until that contractor provides evidence of making a good faith effort toward meeting these goals, or any combination of penalties and remedies that the Board deems appropriate. The decision of the Park Board is final. The Park Board shall promptly report its decision to the DEIA Committee.

- (D) The Executive Director or designee shall submit a quarterly report with statistics of Peoria Park District construction projects for Minority- Owned Businesses and Women-Owned Businesses and workforce participation numbers to DEIA Committee and to the Park Board for review; and
- (E) The Executive Director or designee shall submit an annual report to the DEIA Committee and Park Board of final statistics of Peoria Park District construction projects for Minority-Owned Businesses and Women-Owned Businesses and workforce participation numbers.

## **SUMMARY SHEET**

### **SOLICITATION AND HIRING FOR QUALIFYING CONSTRUCTION CONTRACTS**

(Construction Projects of \$50,000.00 or more)

#### **1. Goals**

Bidder must meet Park District's goals stated below or provide evidence of good faith effort toward meeting the goals to be considered a Responsible and Responsive Bidder.

- Not less than 20% of the total dollar amount of the Contract awarded to go to Minority-owned Businesses
- Not less than 5% of the total dollar amount of the Contract awarded to go to Women-owned Businesses
- Not less than 20% of total hours worked on the job to be by Minority Persons
- Not less than 5% of total hours worked on the job to be by Women

Prior to award, Bidder may be asked to attend a Park Board meeting to review goals and good faith efforts.

#### **2. Required bid documents**

The following forms are required with each bid submission. Failing to submit the forms may result in the bid being non-responsive.

- Bid Form
- Subcontractors List
- Certification of Compliance of Listed Provisions and Laws
- W-9
- Bid Bond
- Company Ownership Certification
- Certificate of Equal Employment Opportunity Compliance for Contractors and Vendors
- Workforce Profile
- Minority/Women Owned Contact Sheet
- Contractor/Subcontractor Workforce Plan

#### **3. Required project administrative documents**

- Signed Agreement Between Owner & Contractor
- Labor & Material Bond and Performance Bond
- Insurance
- Proof of Certified Payroll submitted to IDOL
- Lien Waivers
- Contractor Affidavit
- Contractor/Subcontractor Workforce Plan

#### **4. Notice to Subcontractors**

All subcontracts must make reference to and incorporate the provisions of this Qualifying Construction Contracts Policy. To the extent a subcontract does not reference and incorporate the provisions of the policy, the contractor will be deemed in breach of contract and in violation of this policy, and shall be subject to penalties or remedies stated below.

#### **5. Violation & Penalties**

During construction, not meeting self-stated goals listed on "Contractor/Subcontractor Workforce Plan" or "Minority/Women Owned Contact Sheet" shall appear to be a violation. This will result in the following:

- Staff will notify contractor and request additional information and corrective action steps

- Staff will give notice to the Diversity, Equity, Inclusion, & Accessibility (DEIA) Committee and the Park District Board
- The Park District Board, after 5 days' notice to the contractor and allowing the contractor to make a presentation to the Park District Board, shall make a final determination of whether a violation has occurred and what penalty or remedy should be imposed for such violations
- Potential penalties or remedies include:
  - Corrective action steps
  - Termination of any contract or subcontract
  - PPD's contractual remedies
  - PPD will not consider that contractor to be a responsible bidder on future projects until contractor provides evidence of making a good faith effort toward meeting these goals, or any combination of penalties and remedies that the Board deems appropriate.

The decision of the Park Board is final.



## Peoria Park District

### Certificate of Equal Employment Opportunity Compliance for Contractors & Vendors

The Peoria Park District is an Equal Opportunity Employer and it agrees with each of the provisions below and requires that all suppliers, contractors, subcontractors, and vendors doing business with the Park District be Certified Equal Employment Opportunity Employers in compliance with the Illinois Human Rights Act and such regulations promulgated thereunder, and, that any and all suppliers, contractors, subcontractors or vendors who are found to be in non-compliance with the Illinois Human Rights Act or said regulations may be declared ineligible for future contracts with this Park District; and, that each and every supplier, contractor, subcontractor or vendor does at all times in connection with any dealings with this Park District agree as follows:

- 1) That it will not discriminate against any employee or applicant for employment because of race, color, religion, sex, sexual orientation, marital status, order of protection status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to ability, military status or an unfavorable discharge from military service; and,

**further, that it will examine all job classifications to determine if minority persons or women are underutilized and will take appropriate affirmative action to rectify any underutilization [44 Ill Admin Code 750.110(b)].**

- 2) That, if it hires additional employees in order to perform this contract or any portion of this contract, it will determine the availability (in accordance with the Illinois Department of Human Rights Rules and Regulations) of minorities and women in the areas from which it may reasonably recruit and it will hire for each job classification for which employees are hired in a way that minorities and women are not underutilized.
- 3) That, in all solicitations or advertisements for employees placed by it or on its behalf, it will state that all applicants will be afforded equal opportunity without discrimination because of race, color, religion, sex, sexual orientation, marital status, order of protection status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to ability, military status or an unfavorable discharge from military service.
- 4) That it will send to each labor organization or representative of workers with which it has or is bound by a collective bargaining or other agreement or understanding, a notice advising the labor organization or representative of the contractor's obligations under the Illinois Human Rights Act and the Department's Rules and Regulations. If any labor organization or representative fails or refuses to cooperate with the contractor in its efforts to comply with such Act and Rules and Regulations, the contractor will promptly notify the Peoria Park District and will recruit employees from other sources when necessary to fulfill its obligations under the contract.
- 5) That it will submit reports as required by the Department's Rules and Regulations, furnish all relevant information as may from time to time be requested by the Department or the Peoria Park District, and in all respects comply with the Illinois Human Rights Act and the Department's Rules and Regulations.
- 6) That it will permit access to all relevant books, records, accounts and work sites by personnel of the Peoria Park District and the Department for purposes of investigation to ascertain compliance with the Illinois Human Rights Act and the Department's Rules and Regulations.
- 7) That it will include verbatim or by reference the provisions of this clause in every subcontract awarded under which any portion of the contract obligations are undertaken or assumed, so that the provisions will be binding upon the subcontractor. In the same manner as with other provisions of this contract, the contractor will be liable for compliance with applicable provisions of this clause by subcontractors; and further it will promptly notify the Peoria Park District and the Department in the event any subcontractor fails or refuses to comply with the provisions. In addition, the contractor will not utilize any subcontractor declared by the Illinois Human Rights Commission to be ineligible for contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations.

Failure to properly complete and sign this form, certifying that the Company will agree to the above provisions of the Illinois Human Rights Act as well as the items below will result in it being returned unprocessed thereby resulting in a delay or denial of eligibility to be awarded work with the Peoria Park District.

The Company certifies that it has a written sexual harassment policy meeting the Illinois Human Rights Act and Illinois Department of Human Rights requirements.

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Company Address

\_\_\_\_\_  
Signature of Company Official

\_\_\_\_\_  
Name / Title

\_\_\_\_\_  
Telephone Number & Fax Number

\_\_\_\_\_  
Email Address

## WORKFORCE PROFILE

IMPORTANT: Please complete the company workforce analysis below. Employment data must include ALL full-time company employees who were employed as of the most recent payroll period.

Job Classifications	Black Employees		White Employees		Hispanic Employees		Native American Employees		Asian Employees		Other Employees		TOTAL EMPLOYEES	
	M	F	M	F	M	F	M	F	M	F	M	F	M	F
1. Officials, Managers, Supervisors														
2. Professionals														
3. Technicians														
4. Sales														
5. Office/Clerical														
6. White Collar Trainees:														
7. Skilled Crafts:														
8. Apprentices:														
9. On-the-job Trainees:														
10. Semi-skilled														
11. Service Workers														
12. Unskilled														
TOTALS														

Company Name: \_\_\_\_\_

# WORKFORCE PROFILE INSTRUCTIONS

## RACE/ETHNIC IDENTIFICATION

WHITE (not of Hispanic origin): All persons having origins in any of the original peoples of Europe, North Africa, or the Middle East.

BLACK (not of Hispanic origin): All persons having origins in any of the Black racial groups of Africa.

HISPANIC: All persons of Mexican, Puerto Rican, Cuban, Central or South American, or other Spanish culture or origin, regardless of race.

ASIAN or PACIFIC ISLANDER: All persons having origins in any of the original peoples of the Far East, Southeast Asia, the Indian Subcontinent, or the Pacific Islands. This area includes, for example, China, India, Japan, Korea, the Philippine Islands, and Samoa.

NATIVE AMERICAN or ALASKAN NATIVE: All persons having origins in any of the original peoples of North America, and who maintain cultural identification through tribal affiliation or community recognition.

## DESCRIPTION OF JOB CLASSIFICATIONS

OFFICIALS, MANAGERS, AND SUPERVISORS - Occupations requiring administrative personnel who set broad policies, and exercise over-all responsibility for the execution of these policies, and direct individual departments or special phases of a firm's operations. Includes: officials, executives, middle management, plant managers, department managers/superintendents, salaried foremen who are members of management, purchasing agents and buyers, and kindred workers.

PROFESSIONALS - Occupations requiring either college graduation or experience of such kind and amount as to provide a comparable background. Includes: accountants/auditors, airplane pilots and navigators, architects, artists, chemists, designers, dietitians, editors, engineers, lawyers, librarians, mathematicians, natural scientists, personnel and labor relations workers, physical scientists, physicians, social scientists, teachers, and kindred workers.

TECHNICIANS - Occupations requiring combination of basic scientific knowledge and manual skill which can be obtained through about 2 years of post high school education, such as is offered in many technical institutes and junior colleges, or through equivalent on-the-job training. Includes: drafters, engineering aids, junior engineers, scientific assistants, surveyors, technical illustrators, technicians (medical, dental, electronic physical sciences), and kindred workers.

SALES WORKERS - Occupations engaging wholly or primarily in direct selling. Includes: advertising agents/salespersons, insurance agents/brokers, real estate agents/brokers, stock and bond salespersons, demonstrators, salespersons and sales clerks, and kindred workers.

OFFICE AND CLERICAL WORKERS - Includes all clerical type work regardless of level of difficulty, where the activities are predominantly non-manual though some manual work not directly involved with altering or transporting the products is included. Includes: bookkeepers, cashiers, collectors (bills and accounts), messengers and office couriers, office machine operators, shipping and receiving clerks, stenographers, typist and secretaries, telegraph and telephone operators, and kindred workers.

WHITE COLLAR TRAINEES - Persons engaged in formal training for official, managerial, professional, technical, sales, office and clerical occupations.

SKILLED CRAFTS - Manual worker of relatively high skill level having a thorough and comprehensive knowledge of the processes involved in their work. Exercise considerable independent judgement and usually receive an extensive period of training. Includes: the building trades hourly paid foremen and leadmen who are not members of management, mechanics and repairmen, skilled machining occupations, compositors and typesetters, electricians, engravers, job setters (metal), motion picture projectionists, pattern and model makers, stationary engineers, tailors and tailoresses, and kindred workers.

APPRENTICES - Persons employed in a program including work training and related instruction to learn a trade or craft which is traditionally considered an apprenticeship, regardless of whether the program is registered with a Federal or State agency.

ON-THE-JOB TRAINEES - Persons engaged in formal training for craftsmen when not trained under apprentice programs; semi-skilled, unskilled and service occupations.

SEMI-SKILLED WORKERS - Workers who operate machine or processing equipment or perform other factory-type duties of intermediate skill level which can be mastered in a few weeks and require only limited training.

SERVICE WORKERS - Workers in both protective and non-protective service occupations. Includes: attendants (hospital and other institution, professional and personal service), barbers, charwomen and cleaners, cooks (except household), counter and fountain workers, elevator operators, fire fighters, guards, watchmen and doorkeepers, stewards, janitors, police officers and detectives, porters, waiters and waitresses, and kindred workers.

UNSKILLED WORKERS - Workers in manual occupations which generally require no special training. Perform elementary duties that may be learned in a few days and require the application of little or no independent judgement. Includes: garage laborers, car washers and greasers, gardeners (except farm) and groundskeepers, longshoremen and stevedores, lumbermen, craftsmen and wood choppers, laborers performing lifting, digging, mixing loading and pulling operations, and kindred workers.



# PEORIA PARK DISTRICT

## Company Ownership Certification

In compliance with Illinois Public Act 102-265, and Peoria Park District policy, disclosure of the information requested in this form is required by the Peoria Park District. Failure to properly complete and sign this form will result in it being returned unprocessed thereby resulting in a delay or denial of Company's eligibility to transact business with Peoria Park District.

Please answer all questions. Note, Company may answer "Yes" to more than one category.

- **Is the Company a Minority Owned Business?**  YES  NO

Check One:

Company holds Certification for this classification, or

Company is self-certifying

- **Is the Company a Woman Owned Business?**  YES  NO

Check One:

Company holds Certification for this classification, or

Company is self-certifying

- **Is the Company a Disability-Owned Business?**  YES  NO

Check One:

Company holds Certification for this classification, or

Company is self-certifying

- **Is the Company a Veteran Owned Business?**  YES  NO

Check One:

Company holds Certification for this classification, or

Company is self-certifying

- **Is the Company a Service Disabled Veteran Owned Business?**  YES  NO

Check One:

Company holds Certification for this classification, or

Company is self-certifying

**Does Company qualify as a small business under federal Small Business Administration?**  YES  NO

<https://www.sba.gov/document/support-table-size-standards>

**Please list the name(s) of the Company majority owner(s):** \_\_\_\_\_

**Does Company have any parent and/or subsidiary companies?**  YES  NO

**If yes, please list all companies:** \_\_\_\_\_

\_\_\_\_\_

By signing this form, the Company and the individual signing below attest that the above questions have been answered truthfully, to the best of their knowledge.

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Company Address

\_\_\_\_\_  
Signature of Company Official

\_\_\_\_\_  
Name / Title

\_\_\_\_\_  
Telephone Number & Fax Number

\_\_\_\_\_  
Email Address



# PEORIA PARK DISTRICT

## Definitions for Company Ownership Certification

- Selected Classification of Owned Business means a business which is at least 51% owned by one or more persons of the selected ownership classification (i.e. minority, women, veteran, etc.), or in the case of a corporation, at least 51% of the stock in which is owned by one or more persons of the selected ownership classification; and the management and daily operations of which are controlled by one or more of the selected ownership classification individuals who own it.
- Control means the exclusive or ultimate and sole control of the business including, but not limited to, capital investment and all other financial matters, property, acquisitions, contract negotiations, legal matters, officer-director-employee selection and comprehensive hiring, operating responsibilities, cost-control matters, income and dividend matters, financial transactions and rights of other shareholders or joint partners. Control shall be real, substantial and continuing, no pro forma. Control shall include the power to direct or cause the direction of the management and policies of the business and to make the day-to-day as well as major decisions in matters of policy, management and operations. Control shall be exemplified by possessing the requisite knowledge and expertise to run the particular business and control shall not include simple majority or absentee ownership.
- Minority person shall mean a person who is a citizen or lawful permanent resident of the United States and who is any of the following:
  - a) American Indian or Alaska Native (a person having origins in any of the original peoples of North and South America, including Central America, and who maintains tribal affiliation or community attachment).
  - b) Asian (a person having origins in any of the original peoples of the Far East, Southeast Asia, or the Indian subcontinent, including, but not limited to, Cambodia, China, India, Japan, Korea, Malaysia, Pakistan, the Philippine Islands, Thailand, and Vietnam).
  - c) Black or African American (a person having origins in any of the black racial groups of Africa).
  - d) Hispanic or Latino (a person of Cuban, Mexican, Puerto Rican, South or Central American, or other Spanish culture or origin, regardless of race).
  - e) Native Hawaiian or Other Pacific Islander (a person having origins in any of the original peoples of Hawaii, Guam, Samoa, or other Pacific Islands).
- Woman shall mean a person who is a citizen or lawful permanent resident of the United States and who is of the female gender.
- Veteran means a person who (i) has been a member of the armed forces of the United States or, while a citizen of the United States, was a member of the armed forces of allies of the United States in time of hostilities with a foreign country and (ii) has served under one or more of the following conditions: (a) the veteran served a total of at least 6 months; (b) the veteran served for the duration of hostilities regardless of the length of the engagement; (c) the veteran was discharged on the basis of hardship; or (d) the veteran was released from active duty because of a service connected disability and was discharged under honorable conditions.
- Service-Disabled Veteran means a veteran who has been found to have 10% or more service-connected disability by the United States Department of Veterans Affairs or the United States Department of Defense.
- A Person with a Disability means a person who is a citizen or lawful resident of the United States and is a person qualifying as being disabled, meaning a person with a severe physical or mental disability that:
  - a) results from: amputation, arthritis, autism, blindness, burn injury, cancer, cerebral palsy, Crohn's disease, cystic fibrosis, deafness, head injury, heart disease, hemiplegia, hemophilia, respiratory or pulmonary dysfunction, an intellectual disability, mental illness, multiple sclerosis, muscular dystrophy, musculoskeletal disorders, neurological disorders, including stroke and epilepsy, paraplegia, quadriplegia and other spinal cord conditions, sickle cell anemia, ulcerative colitis, specific learning disabilities, or end stage renal failure disease; and
  - b) substantially limits one or more of the person's major life activities.Another disability or combination of disabilities may also be considered as a severe disability for the purposes of item (a) of this subdivision if it is determined by an evaluation of the rehabilitation potential to cause a comparable degree of substantial functional limitation similar to the specific list of disabilities listed in item (a) of this subdivision.
- Certification means a determination made by the Business Enterprise Council for Minorities, Women, and Persons with Disabilities, or by one delegated authority from the Council to make certifications, or by a State agency with statutory authority to make such a certification, that a business entity is a business owned by a minority, woman, or person with a disability for whatever purpose.



## Contractor/Subcontractor Workforce Plan

Initial Bid/Estimating Date: \_\_\_\_\_ Progress Reporting Date: \_\_\_\_\_

Check appropriate status:

\_\_\_\_\_ Contractor  
 \_\_\_\_\_ Subcontractor

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

Contact Person: \_\_\_\_\_ Phone: \_\_\_\_\_

Project: \_\_\_\_\_

Date Work Started: \_\_\_\_\_ Percent Complete: \_\_\_\_\_ %

Job Categories (by Trade)	Total Est. Hrs. (Bid)	# Crew (Head Ct.)	# Minority (Head Ct.)	# Female (Head Ct.)	Planned Minority Hrs.	Planned Female Hrs.	Actual Minority Hrs. to date	Actual Female Hrs. to date
Example: Carpenter	1,000	4	1	0	250	0		
Example: Painter	300	3	1	1	100	100		
<b>Total</b>								

**Document Purpose:**

This document is a tool to estimate the number and areas of work concerning minority and female labor hours anticipated on this job.

The apparent low bidder and their subcontractors listed on the bid documents shall submit this form within one week after bid opening to the Peoria Park District.

This tool is also a means of tracking the minority and female hours on this job. This document shall be attached to each invoice to show actual minority and female hours on this job.

<i>Job Categories (by Trade)</i>	<i>List of Workers Trade Name</i>
<i>Total Est. Hrs. (Bid)</i>	<i>Total hours of each of the trade listed</i>
<i># Crew (Head Ct.)</i>	<i>Total crew head count of each of the trade listed</i>
<i># Minority (Head Ct.)</i>	<i>Total Minority head count (it is subset of Total Crew #)</i>
<i># Females (Head Ct.)</i>	<i>Total Female head count (it is subset of Total Crew #)</i>
<i>Planned Minority Hrs.</i>	<i>Planned Minority hours of each of the trade listed</i>
<i>Planned Female Hrs.</i>	<i>Planned Female hours of each of the trade listed</i>



APPENDIX A OF 44 IL ADMIN CODE 750  
EQUAL EMPLOYMENT OPPORTUNITY

In the event of the contractor's non-compliance with the provisions of this Equal Employment Opportunity Clause or the Act, the contractor may be declared ineligible for future contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations, and the contract may be cancelled or voided in whole or in part, and other sanctions or penalties may be imposed or remedies invoked as provided by statute or regulation. During the performance of this contract, the contractor agrees as follows:

- 1) That he or she will not discriminate against any employee or applicant for employment because of race, color, religion, sex, sexual orientation, marital status, order of protection status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to ability, military status or an unfavorable discharge from military service; and, further, that he or she will examine all job classifications to determine if minority persons or women are underutilized and will take appropriate affirmative action to rectify any underutilization.
- 2) That, if he or she hires additional employees in order to perform this contract or any portion of this contract, he or she will determine the availability (in accordance with this Part) of minorities and women in the areas from which he or she may reasonably recruit and he or she will hire for each job classification for which employees are hired in a way that minorities and women are not underutilized.
- 3) That, in all solicitations or advertisements for employees placed by him or her or on his or her behalf, he or she will state that all applicants will be afforded equal opportunity without discrimination because of race, color, religion, sex, sexual orientation, marital status, order of protection status, national origin or ancestry, citizenship status, age, physical or mental disability unrelated to ability, military status or an unfavorable discharge from military service.
- 4) That he or she will send to each labor organization or representative of workers with which he or she has or is bound by a collective bargaining or other agreement or understanding, a notice advising the labor organization or representative of the contractor's obligations under the Act and this Part. If any labor organization or representative fails or refuses to cooperate with the contractor in his or her efforts to comply

with the Act and this Part, the contractor will promptly notify the Department and the contracting agency and will recruit employees from other sources when necessary to fulfill its obligations under the contract.

- 5) That he or she will submit reports as required by this Part, furnish all relevant information as may from time to time be requested by the Department or the contracting agency, and in all respects comply with the Act and this Part.
- 6) That he or she will permit access to all relevant books, records, accounts and work sites by personnel of the contracting agency and the Department for purposes of investigation to ascertain compliance with the Act and the Department's Rules and Regulations.
- 7) That he or she will include verbatim or by reference the provisions of this clause in every subcontract awarded under which any portion of the contract obligations are undertaken or assumed, so that the provisions will be binding upon the subcontractor. In the same manner as with other provisions of this contract, the contractor will be liable for compliance with applicable provisions of this clause by subcontractors; and further it will promptly notify the contracting agency and the Department in the event any subcontractor fails or refuses to comply with the provisions. In addition, the contractor will not utilize any subcontractor declared by the Illinois Human Rights Commission to be ineligible for contracts or subcontracts with the State of Illinois or any of its political subdivisions or municipal corporations.

**ATTACHMENT C –  
DIRECTORY OF MINORITY & WOMEN OWNED BUSINESS ENTERPRISES**

# ATTACHMENT C

## Directory of Minority & Women Owned Business Enterprises Peoria Park District

Revised 3/2023

---

<b>3 Keys Construction</b> Tray Keys	MBE Concrete, Roadway Patching, Retaining Walls, Landscaping, Storm Sewer 2314 Lehman Rd., Peoria, IL 61604 <a href="mailto:threekeysconstruction@yahoo.com">threekeysconstruction@yahoo.com</a>	309-472-2721
<b>Absolute Risk Management Strategies</b> Kelly Peterson	MBE Construction Safety, Job Site Safety Plan Development, Job Site Risk Assessment, Construction OSHA Training 416 Main St., Suite 533, Peoria, IL 61602	309-256-8471 309-222-4050 Cell
<b>Adams Septic &amp; Sewer Services, Inc.</b> Michelle Adams	WBE Septic and Sewer Contractor 1641 N. Tiber Ridge Ct., East Peoria, IL 61611	309-691-6113
<b>Aerial Work Services Company</b>	MBE Landscaping and Seeding 13805 Wadsworth Road, Wadsworth, IL	847-662-5321 847-662-5321 Fax
<b>AFE Construction, Inc.</b> Tommy and Monica Arbuckle	WBE/MBE General Contractor P.O. Box 10331, Peoria, IL 61612	309-473-8688 866- 491-2209 Fax admin@afeconstruction.net
<b>A &amp; L Salvage, Inc.</b> Archie Brown	MBE Clean Up, Tree Cutting & Removal, Truck Salvaging 824 W. Brons Peoria, IL 61604	309-682-4412
<b>Alexander Brothers Construction Co.</b> Allester Alexander	MBE Concrete, Demolition, Excavation, Landscaping P.O. Box 1508, Peoria, IL 61605	309-673-6768 <a href="mailto:abrosconst@aol.com">abrosconst@aol.com</a>
<b>Alexander &amp; Sons Construction</b> Leonard Alexander	MBE Driveways, Curbs, Foundations, Layouts, Sidewalks, etc. 2415 N. Linn Street, Peoria, IL 61604 <a href="mailto:Leonardalexander1467@yahoo.com">Leonardalexander1467@yahoo.com</a>	309-678-3004 773-628-9064 (cell)
<b>Allworld Project Management LLC</b> Ronnie Foster Jr.	MBE Highway, Street & Bridge Construction, Water & Sewer Line and Related Construction, Landscaping, Civil Engineering 415 South Front Street, Suite 121, Memphis, TN 38103 procurement@allworldmail.com	901-881-2985
<b>A. Lucas &amp; Sons Steel</b> Margaret Hanley	WBE Structural Steel Fabrication 1328 SW Washington, Peoria, IL 61602	309-673-8547 309-673-7213 Fax Margaret@alucasiron.com
<b>Ambri Inc.</b> Robert J. Hunt. Jr.	MBE Drywall, Flooring, Painting, Cabinetry 9101 S. Nashville Ave., Oak Lawn, IL 60453	708-233-0217 Ph/ Fax
<b>A Unique Maintenance Service</b> Andrea McKnight	MBE Commercial and Industrial Construction Cleanup 1215 N. Sheridan Road, Suite A, Peoria, IL 61606	309-637-4400 309-637-1300 Fax 309-453-3393 Cell
<b>Black Squirrel Services Inc.</b> Aaron Watkins and Joshua Wessels	MBE Skid Steer, Landscaping, Blacktop, Striping, Sealcoating Crack Filling, Crack Routing & Concrete 2037 N. Aspen Road, Peoria, IL 61604	309-369-7817 <a href="mailto:blackssquirrel@yahoo.com">blackssquirrel@yahoo.com</a>
<b>BMI Contractors &amp; Assoc.</b> Sammy Hobson	MBE Excavation, Concrete 1123 MacQueen., Peoria, IL 61604 bmicontractorsandassociates@comcast.net	309-657-4469 Ph 309-713-1569 Fax
<b>BOWA Group, The</b> Lee Fantroy	MBE General 7050 S. Stony Island Ave, Chicago, IL 60649	312-238-9899 603-388-1071 Fax <a href="mailto:lfantroy@thebowagroup.com">lfantroy@thebowagroup.com</a>
<b>Braun Excavating, Inc.</b> Teresa Braun	WBE Demolition, Digging of Footings, Excavation, Pipe Laying 24 Gulf Stream, Bartonville, IL 61607	309-697-5454 309-697-6567 Fax
<b>Brown, Leo Trucking, Inc.</b> Leo Brown	MBE Trucking/Hauling P. O. Box 9057, Peoria, IL 61612	309-685-6710 309-685-0759 Fax
<b>Buddy's Landscaping</b> Dexter Davis	MBE Landscaping P. O. Box 1836, Bloomington, IL 61702	309-824-9211 309-454-3342 Fax <a href="mailto:Dexterdavis2@aol.com">Dexterdavis2@aol.com</a>

<b>Built United</b> John Sutherland	MBE General Contractor	309-699-9191
<b>Burnside Brothers Construction</b> Terry Burnside	MBE Landscaping, General Construction 3563 SW Adams, Peoria, IL 61605	309-922-9390
<b>C and G Concrete Construction Co. Inc.</b> Patricia Slusher	WBE Concrete Rodney@cngconcrete.com	309-699-0384 309-699-6922 Fax 309-208-2646 Cell
<b>CAD Construction</b>	WBE General Contractor	309-925-2092
<b>Capitol Trucking</b> Eddie Washington	MBE Trucking, Snow Removal 2803 Creston Lane, Peoria, IL 61604	309-339-5313
<b>Central IL Construction Inc.</b> Jessica Youngman	WBE Land Surveying 416 Germantown Rd., Germantown, IL 61548	309-383-3156
<b>Central IL Consulting</b> Jessica Youngman	WBE Land Surveying 416 Germantown Rd., Germantown, IL 61548	309-383-3156 youngman@mtco.com
<b>Central IL Rebar Insulators</b> Roger Fleming	MBE Structural Steel and Rebar Replacement 4719 Ridgelawn Place, Peoria, IL 61615	309-258-1379 888-387-5716 Fax 309-258-1379 Cell
<b>Central Landscaping</b> Donna Brandenburg	WBE Seeding, Landscaping 12512 Mendell Rd., Princeville, IL 61559	309-385-4832 309-385-2644 Fax
<b>CJL Landscaping, Inc.</b> Rebecca J. Kelch	WBE Landscaping 10902 W. U. S. Highway 150, Brimfield, IL 61517	309-691-9200 309-691-5131 Fax <a href="mailto:Meinders_81@yahoo.com">Meinders_81@yahoo.com</a> <a href="mailto:jrdoering@att.net">jrdoering@att.net</a>
<b>Clevenger Contractors Inc.</b> Verlee Clevenger Misty L. Daham	WBE Guardrail, Bridge Rail, Seeding, Fencing 355 Naples Rd., P.O. Box 19, Bluffs, IL 62621	217-754-3411 217-754-3537 Fax clever@irtc.net
<b>CNS Forestry &amp; Landscaping LLC</b> Christine Schilling	WBE Landscaping, Seeding, Sodding, Tree Removal 1813 1000 <sup>th</sup> St., Lincoln, IL 62656	217-792-3808 217-792-3808 Fax
<b>Concrete to Perfection</b> Elonda Whitfield	WBE/MBE Designs on Concrete concretetoperfection@gmail.com	309-681-9508
<b>Cordova Construction</b> Tina Christopher	WBE Concrete Removal, Curb & Gutter Removal, Sidewalk Removal 2424 N. Ellory Road, Peoria, IL 61615	309-674-8810 309-208-3448 Cell
<b>Cornerstone Builders &amp; Developers</b> Ron Touilly	WBE 6129 W. Southport Rd., Peoria, IL 61615	309-674-9000 309-673-7783 Fax
<b>Creative Touch Painting</b> Chris Ridge	MBE Painting Exterior/Interior 3318 N. Isabell Ave., Peoria, IL 61604	309-229-1253 309-643-7400 Cell info@creativetouchpnt.com
<b>CSS (Construction Specialties &amp; Services)</b> Dave Suzuki	MBE Building Specialties, Design, Engineering, Estimating P. O. Box 120703 Peoria, IL 61614	309-685-8453
<b>CWG Inc.</b> Teresa Gustafson	WBE Demolition, Excavation, Trucking 24635 Cooper Rd., Morton, IL 61550	309-208-5461 Cell 309-208-8899 Cell tgusdesigns@yahoo.com
<b>Davis Brothers Construction Company</b> Russell Davis	MBE Trucking/Hauling 1522 W. Kettelle St. Peoria, IL 61605	309-683-6931
<b>DECA Realty</b> Eddie J. Washington	MBE Real Estate Broker, Appraiser 417 W. Main, Peoria, IL 61606	309-637-3322 309-682-3922 Fax
<b>Design Air Inc.</b> Courtney Eston	MBE Commercial Air Duct Cleaning 3806 W. Hearthwood Dr., Dunlap, IL 61525	309-693-8632 309-243-2102 Fax
<b>Dunbar Transfer</b>	WBE Trucking P.O. Box 315, Chillicothe, IL 61523-0315	309-303-5122
<b>E &amp; D Trucking and Hauling, Inc.</b> Eddie Proctor	MBE Trucking/Hauling 1913 N. Idaho, Peoria, IL 61604	309-682-4336 309-251-6736 Cell

<b>E. Davis Trucking Company</b> Eric Davis	MBE Trucking edavistrucking@gmail.com	309-648-1450
<b>Earth Care Unlimited, Inc.</b> Monica Thornley	WBE Landscaping, Seeding, Sodding 3108 Panther Grove Rd, Ashland, IL 62612	217-452-7370 217-414-4321
<b>Fire &amp; Ice Heating and Air</b> J.T. Toombs	MBE HVAC Maintenance, Installment 922 W. Smith St., Peoria, IL 61605	309-219-3708
<b>Flessner Electric</b>	WBE Electrical 3600 S. Cameron Ln., Mapleton, IL 61547	309-697-2484
<b>Foster-Jacob Electric</b> Emily Rudesill	WBE Electrical 826 W. Main St., Peoria, IL 61606	309-674-8129 309-674-6890 Fax emilyj@fosterjacob.com
<b>Fuhrmann Engineering Inc.</b> Kathy Shelter	WBE Civil Engineers / Land Surveyors 456 Fulton St., Suite 146	309-713-3498 Ext. 5
<b>Garza Heating &amp; Cooling</b>	MBE HVAC 1304 S. Western Ave., Peoria, IL 61605	309-645-6294
<b>Get Current Electrical Serv.</b> Richard Rhodes	MBE Electrical 4210 N. Northbrook Ct. Richard_rhodes2001@yahoo.com	309-989-7931
<b>Ronald A. Givens &amp; Associates</b> Ronald A. Givens	MBE Insurance & Investments 2616 N. Lehman, Peoria, IL 61602	309-685-4588 309-676-3152 Fax
<b>GIVSCO Construction</b> Ronald Givens	MBE General Contractor 2321 Lakeshore Dr., Pekin, IL 61554	309-620-9127 info@givSCO.com
<b>Gutters &amp; More</b>	WBE 157 Thunderbird Ln., East Peoria, IL 61611	309-694-4000 309-694-3356 Fax
<b>Hancock Trucking, Inc.</b> Nancy Hancock	WBE Trucking/Hauling 30570 Hancock Road Mackinaw, IL 61755	309-447-6733
<b>Hanley Steel, Inc.</b> Jill Hanley	WBE Fabricated Structural and Miscellaneous Steel 8811 N. Industrial Rd., Peoria, IL 61615	309-692-5250 309-692-5251 Fax
<b>Heart Technologies</b> Jim Bainter, Brad Armstrong	WBE Data and Telephone, Communication and Construction 3105 N. Main Street, Peoria, IL 61611	309-427-7000 309-427-7007 Fax
<b>Hermann &amp; Associates</b> Alisha Hermann	WBE Consultant Engineering 5835 N. Galena Rd., Peoria, IL 61614	309-687-5566 309-687-0571 Fax
<b>Horan Construction, Inc.</b> Susan Arnholt	WBE Carpentry, Concrete, Demolition, General, Wrecking 1720 W. Chanute Road Peoria, IL 61615	309-691-3133 309-691-1841 Fax
<b>Illinois Mechanical Service &amp; Design</b> Beth Ward	WBE HVAC P.O. Box 10494, Peoria, IL 61612	309-713-3640 309-274-6941
<b>Infrastructure Engineering</b>	MBE Civil Engineering 456 Fulton St., Suite 104, Peoria, IL 61602	309-637-9200 309-637-9210
<b>Intech Innovations</b> John McCrary	WBE Audio/Video Design and Integration Washington, IL 61571	309-370-6676 309-745-9691 Fax
<b>Interlock Brick Paving</b> Chris Joos	WBE Hardscaping, Landscaping, Excavating P.O. Box 6, Morton, IL 61550 chris@interlockbrickpaving.com	309-696-9264
<b>JC Construction</b> Frank Coates	MBE General 1810 Stever, Peoria, IL 61605	309-303-3919 Cell
<b>JAKS Construction Inc</b> John Spencer	Disabled Vet Full Service Concrete Cutting, Drilling & Sealing 19319 Great Crane Road, Bloomington, IL 61705	800-455-9662 309-455-9662 Fax 309-846-6382 Cell jaksinc@live.com
<b>J &amp; K Construction</b> James Tillman	MBE General 4003 N. Rochelle, Peoria, IL 61615	309-685-8554 309-685-8554 Fax 309-264-3903 Cell <a href="mailto:j&amp;kconst@comcast.net">j&amp;kconst@comcast.net</a>

<b>J &amp; J Construction</b> Herman Johnson	MBE Concrete Removal, Curb & Gutter Removal, Demolition 1300 W. Aiken Avenue, Peoria, IL 61605	309-657-9228 309-676-8292 Fax 309-657-9228 Cell
<b>JM Industrial Supply</b> Ron Given	MBE Maintenance Items, Tools, Soaps 2323 Lakeshore, Pekin, IL 61554	309-346-5796 309-347-5100 Fax
<b>Jones Electrical Contractors, Inc.</b> Ronald Jones	MBE Electrical	309-339-7690 <a href="mailto:rj@joneselectricalco.com">rj@joneselectricalco.com</a>
<b>Kahbeah Contracting &amp; Trucking</b> Larry Kahbeah	MBE Trucking/Hauling 510 N. Yates, P. O. Box 56, Tallula, IL 62688	217-634-4157 217-634-4157 Fax
<b>Kelley Ironworks</b> Tania Hoerr	WBE Fencing and Ironwork 4303 N Main Street, East Peoria, IL 61611 <a href="mailto:tania@kelleyiron.com">tania@kelleyiron.com</a>	309-697-9870 309-697-9871 Fax 309-208-5207 Cell
<b>Kerry Brown Trucking</b> Leo K. Brown	MBE Tandem, Semi Dump, General Hauling Peoria, IL	309-251-6089 Cell <a href="mailto:leok.brown1957@gmail.com">leok.brown1957@gmail.com</a>
<b>Kreiling Roofing Co.</b>	WBE Slate, Wood Shakes, Tile, Thatch, Custom Fabricated Copper and Steel, Residential and Commercial 2335 W. Altorfer Dr., Peoria, IL 61615	309-673-3649 309-692-2504 Fax 309-397-7747 Cell <a href="mailto:lmoore@kreiling.com">lmoore@kreiling.com</a>
<b>Leo Brown Trucking Inc</b> Leo Brown	MBE Trucking PO Box 9057, Peoria, IL 61612	309-685-6710 309-685-0759 Fax 309-303-7111 Cell
<b>LIZZ Trucking &amp; Hauling</b> Brandon Hines	MBE Trucking/Hauling <a href="mailto:lizztrucking@yahoo.com">lizztrucking@yahoo.com</a>	309-208-5942
<b>LNR Construction &amp; Trucking</b> Demonte Davis Lavael Randle Sr.	MBE Concrete, Trucking 2200 N. Linsley St., Peoria, IL 61605	309-682-6331 309-682-6331 Fax 309-678-3314 Cell
<b>LV Enterprise</b> John L. Palmer	MBE Trucking/Hauling 303 E. Archer Avenue, Peoria, IL 61603	309-657-2420 309-682-8872 Fax
<b>M &amp; A Plumbing</b> Michael Abner	MBE Plumbing 6216 N. Devonshire Avenue, Peoria, IL 61615	309-689-0133 309-689-0133 Fax
<b>M&amp;K Heating &amp; Cooling</b> Reggie Williams	MBE HVAC 2406 W. Newman Parkway, Peoria, IL 61604	309-256-6129
<b>M &amp; L Plumbing</b> Manzell Lawson	MBE Plumbing 1309 W. Lincoln, Peoria, IL 61605	309-674-8466
<b>McGinnis Transportation</b> Beth McGinnis	WBE Trucking, Tandem, 24" Box Truck 336 Riverview Drive, Creve Coeur, IL 61610	309-369-4465 309-694-1604 Fax
<b>Michlyn Corporation</b> Fred Danage	MBE Concrete, Landscaping, Lead Based Paint Abatement P.O. Box 5895, Peoria, IL 61601	309-829-2115 309-303-1561 Cell <a href="mailto:macdanage@yahoo.com">macdanage@yahoo.com</a>
<b>Mid-Illinois Companies, Corp.</b> Debra Young	WBE Metal Framing, Insulation, Drywall, Plaster and Exterior Insulation, Acoustical Ceilings and Wall Panels, Painting and Wall Covering, Access Flooring 905 NE Adams St., Peoria, IL 61603	309-674-0717 309-674-5802 Fax <a href="mailto:dyoung@mic123.com">dyoung@mic123.com</a>
<b>Midwest Construction Services</b> Sheila Shover	M/WBE Traffic Control Products, Trucking/Hauling P. O. Box 4185, Bartonville, IL 61607	309-697-1000 309-697-1004 Fax
<b>Millennia Professional Services of IL</b> Paul Moreno	MBE Civil Engineering, Erosion Control, Landscaping, Sewer Construction, Surveying, Retaining Walls 850 N. Main St., Morton, IL 61550	309-321-8141 309-321-8142 Fax 309-303-8428 Cell <a href="mailto:pmoreno@mps-il.com">pmoreno@mps-il.com</a>
<b>Molleck Electric</b>	WBE Electrical 14926 W. Winchester Dr., Brimfield, IL 61517	309-446-3483
<b>Montefusco Heating Sheet Metal</b> Lisa Rhoades	WBE HVAC 2200 W. Altorfer Dr. D, Peoria, IL 61615	309-306-7040 <a href="mailto:lisa@montefuscohv.com">lisa@montefuscohv.com</a>

<b>N.E. Rudd Trucking</b> Nanette E Jenkins-Rudd	WBE Excavating, Hauling, Asphalt, Dirt, Gravel, Sand Milling ; Dumps and Tandems PO Box 14, Kingston Mines, IL 61539	309-389-4150 309-389-2849 Fax 309-360-7986 Cell
<b>Peoria Metro Construction</b>	WBE General Contractor	309-671-1466
<b>Porter, V. L.</b> Vincent Porter	MBE Concrete, General 500 W. North, Suite 10, Springfield, IL 62704	217-744-8050
<b>Prairie Engineers of Illinois PC</b> Colleen Ayars	WBE Civil Engineering, Surveying ,Environmental Consulting 926 SW Adams Street, Suite 120, Peoria, IL 61602 <a href="http://www.prairieengineers.com">www.prairieengineers.com</a>	309-839-2642 217-718-4764 Fax
<b>Reign Construction</b> Bridget Booker	WBE/MBE Iron Worker 801 W. Main St., Suite A118, Peoria, IL 61606 <a href="mailto:bridget@reignconstructioninc.com">bridget@reignconstructioninc.com</a>	309-495-7982 309-495-7996 Fax 309-750-4846 Cell
<b>RNS Electric Inc.</b> Regina Slonneger	WBE Electrical 28558 Irish Lane, Washington, IL 61571	309-444-5200 309-444-5201 Fax
<b>Rudd Trucking</b> Nanette Jenkins-Rudd	WBE Trucking/Hauling P.O. Box 14, 107 Washington St., Kingston Mines, IL 61539	309-389-4150 309-389-2849 Fax
<b>Rufus Construction Company</b> Rufus Nelson	MBE Painting, Roofing, Remodeling 1819 S. Idaho Street, Peoria, IL 61605	309-673-6776 309-497-9453 Cell
<b>Searle Trucking, Inc.</b> Debbie Searle	WBE Trucking/Hauling P. O. Box 1084, Peoria, IL 61653	309-686-0708 309-688-5365 Fax
<b>Serenity Electric</b>	MBE Electrical PO Box 6521, Peoria, IL 61601 <a href="mailto:jamestaylor1955@yahoo.com">jamestaylor1955@yahoo.com</a>	309-363-5067 309-363-5067 Cell
<b>Sherwin Baker &amp; Associates Inc.</b> Sherwin Baker	MBE Engineering Technical Service, Construction Management 103 E. Archer, Peoria, IL 61603	309-688-4203 309-682-4203 Fax 309-678-2897 Cell <a href="mailto:sherwin_baker@yahoo.com">sherwin_baker@yahoo.com</a>
<b>Standard Heating &amp; Cooling</b>	WBE HVAC	309-671-5417
<b>Tabitha Ventures, Inc.</b> Edward O. Taiwo	MBE Asphalt, Concrete, Demolition, Earthwork, Electrical, Excavation, General, HVAC, Landscaping, Painting, Plumbing, Resurfacing, Roofing, Trucking/Hauling 100 N. Main Street, Suite 203, East Peoria, IL 61611	309-692-1473 309-692-1564 Fax <a href="mailto:information@tabithainc.com">information@tabithainc.com</a>
<b>TEMCO Heating &amp; AC</b> Ellen Robinson	WBE Heating & AC 913 Laramie St. Peoria, IL 61605	309-637-7746
<b>The Communication Connection</b> Jennifer Stone	WBE Communication, Wire and Cable, Electrical and Telephone Prod. 604 Filmore Street Harrisburg, PA 17104	717-561-7267
<b>Third Hand Landscaping</b> Tommy Harris	MBE Landscaping 2313 W. Lincoln, Peoria, IL 61605	309-673-6702
<b>Three Cross Development</b> J. T. Donelson	MBE Concrete, General, Sidewalk 1519 W. Millman Peoria, IL 61605	309-637-1238
<b>Thompson Brothers Inc.</b> Todd Thompson	MBE General Carpentry and Construction, Interior Finish Work, Millwork 221 Court St., Pekin, IL 61554	309-613-0254
<b>Thornton Rave</b> dba Illini Concrete Co. of Illinois	MBE Precast and Prestressed Concrete, Demolition, Excavating and Grading, Drainage, Aggregate Bases and Surfaces, Pavement Patching 929 E. Grove St., Suite A, Bloomington, IL 61701	309-585-2376 309-585-2472 Fax 309-706-9213 Cell <a href="mailto:thorntonrave01@gmail.com">thorntonrave01@gmail.com</a>
<b>Tillman Electric</b> James Tillman	MBE Electrical 4003 N. Rochelle, Peoria, IL 61615	309-685-8554 309-264-3903 Cell
<b>Willie Venable Construction</b> Willie Venable	MBE Construction, Concrete Removal, Demolition 1000 E. Wilcox, Peoria, IL 61605	309-686-1429 309-360-0757 Cell
<b>Willis Electric</b> Phyllis Willis	WBE Electrical P.O. Box 545, Chillicothe, IL 61523	309-579-2926

**ATTACHMENT D –  
PREVAILING WAGES FOR PEORIA COUNTY – ILLINOIS DEPARTMENT OF LABOR**

## Peoria County Prevailing Wage Rates posted on 11/4/2025

Trade Title	Rg	Type	C	Base	Foreman	Overtime					Pension	Vac	Trng	Other Ins	Add OT 1.5x owed	Add OT 2.0x owed
						M-F	Sa	Su	Hol	H/W						
ASBESTOS ABT-GEN	All	BLD		36.00	37.50	1.5	1.5	2.0	2.0	8.90	23.58	0.00	0.80	0.00	2.51	5.02
ASBESTOS ABT-GEN	All	HWY		38.07	39.57	1.5	1.5	2.0	2.0	8.90	28.44	0.00	0.80	0.00	4.20	8.39
ASBESTOS ABT-MEC	All	BLD		35.18	38.00	1.5	1.5	2.0	2.0	16.44	14.75	0.00	0.92		2.43	4.84
BOILERMAKER	All	BLD		45.23	48.23	1.5	1.5	2.0	2.0	7.07	24.29	0.00	2.19	0.00	0.00	0.00
BRICK MASON	All	BLD		39.50	41.87	1.5	1.5	2.0	2.0	12.45	16.63	0.00	1.25		0.00	0.00
CARPENTER	All	BLD		39.06	41.81	1.5	1.5	2.0	2.0	9.95	23.19	0.00	0.81	0.00	16.57	33.14
CARPENTER	All	HWY		40.96	43.21	1.5	1.5	2.0	2.0	9.95	24.87	0.00	0.78	0.00	0.00	0.00
CEMENT MASON	All	BLD		35.96	38.71	1.5	1.5	2.0	2.0	9.00	24.00	0.00	0.86	0.00	0.00	0.00
CEMENT MASON	All	HWY		39.43	41.93	1.5	1.5	2.0	2.0	9.00	23.67	0.00	0.80	0.00	0.00	0.00
CERAMIC TILE FINISHER	All	BLD		36.21		1.5	1.5	2.0	2.0	12.45	16.63	0.00	1.24		0.00	0.00
ELECTRIC PWR EQMT OP	All	ALL		57.47	68.20	1.5	1.5	2.0	2.0	9.22	16.09	0.00	0.57		0.00	0.00
ELECTRIC PWR GRNDMAN	All	ALL		39.05	68.20	1.5	1.5	2.0	2.0	8.67	10.93	0.00	0.39	0.00	0.00	0.00
ELECTRIC PWR LINEMAN	All	ALL		63.97	68.20	1.5	1.5	2.0	2.0	9.42	17.91	0.00	0.64	0.00	0.00	0.00
ELECTRIC PWR TRK DRV	All	ALL		40.98	68.20	1.5	1.5	2.0	2.0	8.73	11.48	0.00	0.41	0.00	0.00	0.00
ELECTRICIAN	All	BLD		45.65	49.15	1.5	1.5	2.0	2.0	9.75	16.12	0.00	0.90	0.00	0.00	0.00
ELECTRONIC SYSTEM TECH	All	BLD		37.70	40.70	1.5	1.5	2.0	2.0	8.85	14.15	0.00	0.40	0.00	0.00	0.00
ELEVATOR CONSTRUCTOR	All	BLD		57.99	65.24	2.0	2.0	2.0	2.0	16.27	21.36	4.64	0.80		0.00	0.00
GLAZIER	All	BLD		41.24	43.24	1.5	1.5	1.5	2.0	15.87	11.51	0.00	1.40	0.00	0.00	0.00
HEAT/FROST INSULATOR	All	BLD		46.91	49.72	1.5	1.5	2.0	2.0	16.44	17.08	0.00	0.92		3.59	7.17
IRON WORKER	All	BLD		39.24	41.14	1.5	1.5	2.0	2.0	12.71	20.26	0.00	0.91	0.00	0.00	0.00
IRON WORKER	All	HWY		45.48	47.48	1.5	1.5	2.0	2.0	12.71	20.26	0.00	1.16	0.00	0.00	0.00
LABORER	All	BLD		34.00	35.50	1.5	1.5	2.0	2.0	8.90	23.58	0.00	0.80	0.00	2.51	5.02
LABORER	All	HWY		37.32	38.82	1.5	1.5	2.0	2.0	8.90	28.44	0.00	0.80	0.00	4.20	8.39
LABORER, SKILLED	All	BLD		34.40	35.90	1.5	1.5	2.0	2.0	8.90	23.58	0.00	0.80	0.00	2.51	5.02
LABORER, SKILLED	All	HWY		37.62	39.12	1.5	1.5	2.0	2.0	8.90	28.44	0.00	0.80	0.00	4.20	8.39
LATHER	All	BLD		39.06	41.81	1.5	1.5	2.0	2.0	9.95	23.19	0.00	0.81	0.00	16.57	33.14
MACHINERY MOVER	All	HWY		45.48	47.48	1.5	1.5	2.0	2.0	12.71	20.26	0.00	1.16	0.00	0.00	0.00

## Peoria County Prevailing Wage Rates posted on 11/4/2025

MACHINIST	All	BLD		60.39	64.39	1.5	1.5	2.0	2.0	11.43	9.95	1.85	1.47	0.00	0.00	0.00
MARBLE FINISHER	All	BLD		36.21		1.5	1.5	2.0	2.0	12.45	16.63	0.00	1.24		0.00	0.00
MARBLE MASON	All	BLD		39.92	42.32	1.5	1.5	2.0	2.0	12.45	16.63	0.00	1.26		0.00	0.00
MILLWRIGHT	All	BLD		39.10	41.85	1.5	1.5	2.0	2.0	9.95	23.53	0.00	0.81	0.00	16.74	33.48
MILLWRIGHT	All	HWY		42.00	44.25	1.5	1.5	2.0	2.0	9.95	24.50	0.00	0.78	0.00	0.00	0.00
OPERATING ENGINEER	All	BLD	1	47.79	50.79	1.5	1.5	2.0	2.0	12.85	26.97	0.00	3.60		0.00	0.00
OPERATING ENGINEER	All	BLD	2	44.09		1.5	1.5	2.0	2.0	12.85	26.97	0.00	3.60		0.00	0.00
OPERATING ENGINEER	All	BLD	3	38.03		1.5	1.5	2.0	2.0	12.85	26.97	0.00	3.60		0.00	0.00
OPERATING ENGINEER	All	HWY	1	47.79	51.29	1.5	1.5	2.0	2.0	12.85	26.97	0.00	3.60		0.00	0.00
OPERATING ENGINEER	All	HWY	2	44.09		1.5	1.5	2.0	2.0	12.85	26.97	0.00	3.60		0.00	0.00
OPERATING ENGINEER	All	HWY	3	38.03		1.5	1.5	2.0	2.0	12.85	26.97	0.00	3.60		0.00	0.00
PAINTER	All	ALL		42.40	44.40	1.5	1.5	1.5	2.0	15.13	12.32	0.00	1.50	0.00	0.00	0.00
PAINTER - SIGNS	All	BLD		46.76	52.53	1.5	1.5	2.0	2.0	8.20	16.81	0.00	0.00	0.00	0.00	0.00
PILEDRIIVER	All	BLD		41.06	43.81	1.5	1.5	2.0	2.0	9.95	23.19	0.00	0.81	0.00	16.57	33.14
PILEDRIIVER	All	HWY		41.96	44.21	1.5	1.5	2.0	2.0	9.95	24.87	0.00	0.78	0.00	0.00	0.00
PIPEFITTER	All	BLD		46.60	51.73	1.5	1.5	2.0	2.0	9.95	17.49	0.00	1.65	0.00	0.00	0.00
PLASTERER	All	BLD		34.25	36.25	1.5	1.5	2.0	2.0	9.00	25.10	0.00	0.99		0.00	0.00
PLUMBER	All	BLD		42.70	47.40	1.5	1.5	2.0	2.0	9.95	19.33	0.00	1.70	0.00	0.00	0.00
ROOFER	All	BLD		38.05	40.90	1.5	1.5	2.0	2.0	10.75	13.26	0.00	0.50	0.00	0.00	0.00
SHEETMETAL WORKER	All	BLD		40.48	42.50	1.5	1.5	2.0	2.0	12.42	20.68	0.00	1.29	0.00	0.00	0.00
SIGN HANGER	All	HWY		45.48	47.48	1.5	1.5	2.0	2.0	12.71	20.26	0.00	1.16	0.00	0.00	0.00
SPRINKLER FITTER	All	BLD		50.51	53.76	1.5	1.5	2.0	2.0	12.40	17.31	0.00	0.54	0.00	0.00	0.00
STEEL ERECTOR	All	HWY		45.48	47.48	1.5	1.5	2.0	2.0	12.71	20.26	0.00	1.16	0.00	0.00	0.00
STONE MASON	All	BLD		39.50	41.87	1.5	1.5	2.0	2.0	12.45	16.63	0.00	1.25		0.00	0.00
TERRAZZO FINISHER	All	BLD		36.21		1.5	1.5	2.0	2.0	12.45	16.63	0.00	1.24		0.00	0.00
TERRAZZO MASON	All	BLD		39.92	42.32	1.5	1.5	2.0	2.0	12.45	16.63	0.00	1.26		0.00	0.00
TILE MASON	All	BLD		39.92	42.32	1.5	1.5	2.0	2.0	12.45	16.63	0.00	1.26		0.00	0.00
TRUCK DRIVER	All	ALL	1	45.29	49.65	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00
TRUCK DRIVER	All	ALL	2	45.88	49.65	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00
TRUCK DRIVER	All	ALL	3	46.15	49.65	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00

## Peoria County Prevailing Wage Rates posted on 11/4/2025

TRUCK DRIVER	All	ALL	4	46.54	49.65	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00
TRUCK DRIVER	All	ALL	5	47.64	49.65	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00
TRUCK DRIVER	All	O&C	1	36.23	39.72	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00
TRUCK DRIVER	All	O&C	2	36.70	39.72	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00
TRUCK DRIVER	All	O&C	3	36.92	39.72	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00
TRUCK DRIVER	All	O&C	4	37.23	39.72	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00
TRUCK DRIVER	All	O&C	5	38.11	39.72	1.5	1.5	2.0	2.0	17.11	8.06	0.00	0.25	0.00	0.00	0.00
TUCK POINTER	All	BLD		39.50	41.87	1.5	1.5	2.0	2.0	12.45	16.63	0.00	1.25		0.00	0.00

### Legend

**Rg** Region

**Type** Trade Type - All,Highway,Building,Floating,Oil & Chip,Rivers

**C** Class

**Base** Base Wage Rate

**OT M-F** Unless otherwise noted, OT pay is required for any hour greater than 8 worked each day, Mon through Fri. The number listed is the multiple of the base wage.

**OT Sa** Overtime pay required for every hour worked on Saturdays

**OT Su** Overtime pay required for every hour worked on Sundays

**OT Hol** Overtime pay required for every hour worked on Holidays

**H/W** Health/Welfare benefit

**Vac** Vacation

**Trng** Training

**Other Ins** Employer hourly cost for any other type(s) of insurance provided for benefit of worker.

### Explanations PEORIA COUNTY

The following list is considered as those days for which holiday rates of wages for work performed apply: New Years Day, Memorial Day, Fourth of July, Labor Day, Thanksgiving Day, Christmas Day and Veterans Day in some classifications/counties. Generally, any of these holidays which fall on a Sunday is celebrated on the following Monday. This then makes work performed on that Monday payable at the appropriate overtime rate for holiday pay. Common practice in a given local may alter certain days of celebration. If in doubt, please check with IDOL.

Oil and chip resealing (O&C) means the application of road oils and liquid asphalt to coat an existing road surface, followed by application of aggregate chips or gravel to coated surface, and subsequent rolling of material to seal the surface.

### EXPLANATION OF CLASSES

## **Peoria County Prevailing Wage Rates posted on 11/4/2025**

ASBESTOS - GENERAL - removal of asbestos material/mold and hazardous materials from any place in a building, including mechanical systems where those mechanical systems are to be removed. This includes the removal of asbestos materials/mold and hazardous materials from ductwork or pipes in a building when the building is to be demolished at the time or at some close future date.

ASBESTOS - MECHANICAL - removal of asbestos material from mechanical systems, such as pipes, ducts, and boilers, where the mechanical systems are to remain.

### **CERAMIC TILE FINISHER, MARBLE FINISHER, TERRAZZO FINISHER**

Assisting, helping or supporting the tile, marble and terrazzo mechanic by performing their historic and traditional work assignments required to complete the proper installation of the work covered by said crafts. The term "Ceramic" is used for naming the classification only and is in no way a limitation of the product handled. Ceramic takes into consideration most hard tiles.

### **ELECTRONIC SYSTEMS TECHNICIAN**

Installation, service and maintenance of low-voltage systems which utilizes the transmission and/or transference of voice, sound, vision, or digital for commercial, education, security and entertainment purposes for the following: TV monitoring and surveillance, background/foreground music, intercom and telephone interconnect, field programming, inventory control systems, microwave transmission, multi-media, multiplex, radio page, school, intercom and sound burglar alarms and low voltage master clock systems.

Excluded from this classification are energy management systems, life safety systems, supervisory controls and data acquisition systems not intrinsic with the above listed systems, fire alarm systems, nurse call systems and raceways exceeding fifteen feet in length.

### **LABORER, SKILLED - BUILDING**

The skilled laborer building (BLD) classification shall encompass the following types of work, irrespective of the site of the work: cutting & acetylene torch, gunnite nozzlemen, gunnite pump men & pots, kettlemen & carriers of men handling hot stuff, sandblaster nozzle men, sandblasting pump men & pots, setting up and using concrete burning bars, wood block setters, underpinning & shoring of existing buildings, and the unload-ing and handling of all material coated with creosote.

### **LABORER, SKILLED - HIGHWAY**

The skilled laborer heavy & highway (HWY) classification shall encompass the following types of work,irrespective of the site of the work: jackhammer & drill operator, gunite pump & pot man, puddlers, vibrator men, wire fabric placer, sandblast pump & pot man, strike off concrete, unloading, handling & carrying of all creosoted piles, ties or timber, concrete burning bars, power wheelbarrows or buggies, asphalt raker, brickset-ters, cutting torchman (electric & acetylene), men setting lines to level forms, form setters, gunite nozzle man & sandblasting nozzle man, power man, and rip-rapping by hand.

TRUCK DRIVER - BUILDING, HEAVY AND HIGHWAY CONSTRUCTION Class 1. Drivers on 2 axle trucks hauling less than 9 ton. Air

## Peoria County Prevailing Wage Rates posted on 11/4/2025

compressor and welding machines and brooms, including those pulled by separate units, truck driver helpers, warehouse employees, mechanic helpers, greasers and tiremen, pickup trucks when hauling materials, tools, or workers to and from and on-the-job site, and fork lifts up to 6,000 lb. capacity.

Class 2. Two or three axle trucks hauling more than 9 ton but hauling less than 16 ton. A-frame winch trucks, hydrolift trucks, vactor trucks or similar equipment when used for transportation purposes. Fork lifts over 6,000 lb. capacity, winch trucks, four axle combination units, and ticket writers.

Class 3. Two, three or four axle trucks hauling 16 ton or more. Drivers on water pulls, articulated dump trucks, mechanics and working forepersons, and dispatchers. Five axle or more combination units.

Class 4. Low Boy and Oil Distributors.

Class 5. Drivers who require special protective clothing while employed on hazardous waste work.

### TRUCK DRIVER - OIL AND CHIP RESEALING ONLY.

This shall encompass laborers, workers and mechanics who drive contractor or subcontractor owned, leased, or hired pickup, dump, service, or oil distributor trucks. The work includes transporting materials and equipment (including but not limited to, oils, aggregate supplies, parts, machinery and tools) to or from the job site; distributing oil or liquid asphalt and aggregate; stock piling material when in connection with the actual oil and chip contract. The Truck Driver (Oil & Chip Resealing) wage classification does not include supplier delivered materials.

### OPERATING ENGINEERS - BUILDING

Class 1. Cranes; Overhead Cranes; Gradall; All Cherry Pickers; Mechanics; Central Concrete Mixing Plant Operator; Road Pavers (27E - Dual Drum - Tri Batchers); Blacktop Plant Operators and Plant Engineers; 3 Drum Hoist; Derricks; Hydro Cranes; Shovels; Skimmer Scoops; Koehring Scooper; Drag Lines; Backhoe; Derrick Boats; Pile Drivers and Skid Rigs; Clamshells; Locomotive Cranes; Dredge (all types) Motor Patrol; Power Blades - Dumore - Elevating and similar types; Tower Cranes (Crawler-Mobile) and Stationary; Crane-type Backfiller; Drott Yumbo and similar types considered as Cranes; Caisson Rigs; Dozer; Tournadozer; Work Boats; Ross Carrier; Helicopter; Tournapulls - all and similar types; Scoops (all sizes); Pushcats; Endloaders (all types); Asphalt Surfacing Machine; Slip Form Paver; Rock Crusher; Heavy Equipment Greaser; CMI, CMI Belt Placer, Auto Grade & 3 Track and similar types; Side Booms; Multiple Unit Earth Movers; Creter Crane; Trench Machine; Pump-crete-Belt Crete-Squeeze Cretes-Screw-type Pumps and Gypsum; Bulker & Pump - Operator will clean; Formless Finishing Machine; Flaherty Spreader or similar types; Screed Man on Laydown Machine; Wheel Tractors (industrial or Farm-type w/Dozer-Hoe-Endloader or other attachments); F.W.D. & Similar Types; Vermeer Concrete Saw.

Class 2. Dinkeys; Power Launches; PH One-pass Soil Cement Machine (and similar types); Pugmill with Pump; Backfillers; Euclid Loader; Forklifts; Jeeps w/Ditching Machine or other attachments; Tuneluger; Automatic Cement and Gravel Batching Plants; Mobile Drills (Soil Testing) and similar types; Gurries and Similar Types; (1) and (2) Drum Hoists (Buck Hoist and Similar Types); Chicago Boom; Boring Machine & Pipe Jacking Machine; Hydro Boom; Dewatering System; Straw Blower; Hydro Seeder; Assistant Heavy Equipment Greaser on Spread; Tractors (Track type) without Power Unit pulling Rollers; Rollers on Asphalt -- Brick

## Peoria County Prevailing Wage Rates posted on 11/4/2025

Macadem; Concrete Breakers; Concrete Spreaders; Mule Pulling Rollers; Center Stripper; Cement Finishing Machines & CMI Texture & Reel Curing Machines; Cement Finishing Machine; Barber Green or similar loaders; Vibro Tamper (All similar types) Self-propelled; Winch or Boom Truck; Mechanical Bull Floats; Mixers over 3 Bag to 27E; Tractor pulling Power Blade or Elevating Grader; Porter Rex Rail; Clary Screed; Truck Type Hoptoe Oilers; Fireman; Spray Machine on Paving; Curb Machines; Truck Crane Oilers; Oil Distributor; Truck-Mounted Saws.

Class 3. Air Compressor; Power Subgrader; Straight Tractor; Trac Air without attachments; Herman Nelson Heater, Dravo, Warner, Silent Glo, and similar types; Roller: Five (5) Ton and under on Earth or Gravel; Form Grader; Crawler Crane & Skid Rig Oilers; Freight Elevators - permanently installed; Pump; Light Plant; Generator; Conveyor (1) or (2) - Operator will clean; Welding Machine; Mixer (3) Bag and Under (Standard Capacity with skip); Bulk Cement Plant; Oiler on Central Concrete Mixing Plant.

### OPERATING ENGINEERS - HEAVY AND HIGHWAY CONSTRUCTION

CLASS 1. Cranes; Hydro Cranes; Shovels; Crane Type Backfiller; Tower, Mobile, Crawler, & Stationary Cranes; Derricks; Hoists (3 Drum); Draglines; Drott Yumbo & Similar Types considered as Cranes; 360 Degree Swing Excavator (Shears, Grapples, Movacs, etc.); Back Hoe; Derrick Boats; Pile Driver and Skid Rigs; Clam Shell; Locomotive - Cranes; Road Pavers - Single Drum - Dual Drum - Tri Batcher; Motor Patrols & Power Blades - Dumore - Elevating & Similar Types; Mechanics; Central Concrete Mixing Plant Operator; Asphalt Batch Plant Operators and Plant Engineers; Gradall; Caisson Rigs; Skimmer Scoop - Koering Scooper; Dredges (all types); Hoptoe; All Cherry Pickers; Work Boat; Ross Carrier; Helicopter; Dozer; Tournadozer; Tournapulls - all and similar types; Operation of Concrete and all Recycle Machines; Multiple Unit Earth Movers; Scoops (all sizes); Pushcats; Endloaders (all types); Asphalt Surfacing Machine; Slip Form Paver; Rock Crusher; Operation of Material Crusher, Screening Plants, and Tunnel Boring Machine; Heavy Equipment Greaser (top greaser on spread); CMI, Auto Grade, CMI Belt Placer & 3 Track and Similar Types; Side Booms; Asphalt Heater & Planer Combination (used to plane streets); Wheel Tractors (with Dozer, Hoe or Endloader Attachments); CAT Earthwork Compactors and Similar Types; Blaw Knox Spreader and Similar Types; Trench Machines; Pump Crete - Belt Crete - Squeeze Crete - Screw Type Pumps and Gypsum (operator will clean); Creter Crane; Operation of Concrete Pump Truck; Formless Finishing Machines; Flaherty Spreader or Similar Types; Screed Man on Laydown Machine; Vermeer Concrete Saw; Operation of Laser Screed; Span Saw; Dredge Leverman; Dredge Engineer; Lull or Similar Type; Hydro-Boom Truck; Operation of Guard Rail Machine; and Starting Engineer on Pipeline or Construction (11 or more pieces) including: Air Compressor (Trailer Mounted), All Forced Air Heaters (regardless of Size), Water Pumps (Greater than 4-1/2" or Total Discharge Over 4-1/2"), Light Plants, Generators (Trailer Mounted - Excluding Decontamination Trailer), Welding Machines (Any Size or Mode of Power), Conveyor, Mixer (any size), Stud Welder, Power Pac, etc, and Ground Heater (Trailer Mounted).

CLASS 2. Bulker & Pump; Power Launches; Boring Machine & Pipe Jacking Machine; Dinkeys; Operation of Carts, Powered Haul Unit for a Boring Machine; P & H One Pass Soil Cement Machines and Similar Types; Wheel Tractors (Industry or Farm Type - Other); Back Fillers; Euclid Loader; Fork Lifts; Jeep w/Ditching Machine or Other Attachments; Tunneluger; Automatic Cement & Gravel Batching Plants; Mobile Drills - Soil Testing and Similar Types; Pugmill with Pump; All (1) and (2) Drum Hoists; Dewatering System; Straw Blower; Hydro-Seeder; Bump Grinders (self-propelled); Assistant Heavy Equipment Greaser; Apsco Spreader; Tractors (Track-Type) without Power Units Pulling Rollers; Rollers on Asphalt - Brick or Macadam; Concrete Breakers; Concrete Spreaders; Cement Strippers; Cement Finishing Machines & CMI Texture & Reel Curing Machines; Vibro-Tampers (All Similar Types Self-Propelled); Mechanical Bull Floats; Self-Propelled Concrete Saws; Truck Mounted Power Saws; Operation of Curb Cutters; Mixers - Over Three (3) Bags; Winch and Boom Trucks; Tractor Pulling Power Blade or Elevating Grader; Porter Rex Rail;

## Peoria County Prevailing Wage Rates posted on 11/4/2025

Clary Screed; Mule Pulling Rollers; Pugmill without Pump; Barber Greene or Similar Loaders; Track Type Tractor w/Power Unit attached (minimum); Fireman; Spray Machine on Paving; Curb Machines; Paved Ditch Machine; Power Broom; Self-Propelled Sweepers; Self-Propelled Conveyors; Power Subgrader; Oil Distributor; Straight Tractor; Truck Crane Oiler; Truck Type Oilers; Directional Boring Machine; Horizontal Directional Drill; Articulating End Dump Vehicles; Starting Engineer on Pipeline or Construction (6 -10 pieces) including: Air Compressor (Trailer Mounted), All Forced Air Heaters (regardless of Size), Water Pumps (Greater than 4-1/2" or Total Discharge Over 4-1/2"), Light Plants, Generators (Trailer Mounted - Excluding Decontamination Trailer), Welding Machines (Any Size or Mode of Power), Conveyor, Mixer (any size), Stud Welder, Power Pac, etc., and Ground Heater (Trailer Mounted).

CLASS 3. Straight Framed Truck Mounted Vac Unit (separately powered); Trac Air Machine (without attachments); Rollers - Five Ton and Under on Earth and Gravel; Form Graders; Bulk Cement Plant; Oilers; and Starting Engineer on Pipeline or Construction (3 - 5 pieces) including: Air Compressor (Trailer Mounted), All Forced Air Heaters (regardless of Size), Water Pumps (Greater than 4-1/2" or Total Discharge Over 4-1/2"), Light Plants, Generators (Trailer Mounted - Excluding Decontamination Trailer), Welding Machines (Any Size or Mode of Power), Conveyor, Mixer (any size), Stud Welder, Power Pac, etc., and Ground Heater (Trailer Mounted).

### Other Classifications of Work:

For definitions of classifications not otherwise set out, the Department generally has on file such definitions which are available. If a task to be performed is not subject to one of the classifications of pay set out, the Department will upon being contacted state which neighboring county has such a classification and provide such rate, such rate being deemed to exist by reference in this document. If no neighboring county rate applies to the task, the Department shall undertake a special determination, such special determination being then deemed to have existed under this determination. If a project requires these, or any classification not listed, please contact IDOL at 217-782-1710 for wage rates or clarifications.


### LANDSCAPING

Landscaping work falls under the existing classifications for laborer, operating engineer and truck driver. The work performed by landscape plantsman and landscape laborer is covered by the existing classification of laborer. The work performed by landscape operators (regardless of equipment used or its size) is covered by the classifications of operating engineer. The work performed by landscape truck drivers (regardless of size of truck driven) is covered by the classifications of truck driver.

**Peoria County Prevailing Wage Rates posted on 11/4/2025**

# NEWMAN GOLF COURSE

<u>SHEET</u>	<u>DESCRIPTION</u>
LI-0	COVER
LI-1	IMPACT COVERAGE PLAN
LI-2	HYDRAULIC PIPING PLAN
LI-3	ELECTRICAL SCHEMATIC PLAN
LI-4	SITE IRRIGATION PLAN
LI-5	IRRIGATION DETAILS
LI-6	EXISTING IRRIGATION DRAWINGS





**BASE SCOPE OF WORK**

THE BASE BID SCOPE OF WORK TO INCLUDE; THE IRRIGATION MAINLINE, LATERALS, IRRIGATION COMPONENTS AND ADDITIONAL CONTROLS FOR HOLES #3, #2, AND #9 AS OUTLINED IN THE ABOVE DRAWING. THIS INCLUDES, BUT NOT LIMITED TO, CONNECTING TO THE EXISTING MAINLINE INFRASTRUCTURE TO ALLOW WATER TO ALL EXISTING PORTIONS OF THE COURSE. REFER TO EXISTING DRAWINGS. CONTRACTOR SHALL CONFIRM FINAL TIE IN POINTS.

**ALTERNATE #1 OF WORK**

ALTERNATE SCOPE OF WORK SHALL INCLUDE; THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #7 AND #8 AS OUTLINED IN THE ABOVE DRAWINGS.

**ALTERNATE #2 OF WORK**

ALTERNATE SCOPE OF WORK SHALL INCLUDE; THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #6 AS OUTLINED IN THE ABOVE DRAWINGS.

**ALTERNATE #3 OF WORK**

ALTERNATE SCOPE OF WORK SHALL INCLUDE; THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #4 AND #5 AS OUTLINED IN THE ABOVE DRAWINGS.


**IMPACT COVERAGE PLAN**



**IMPACT COVERAGE PLAN**  
SCALE: 1" = 100'-0"

**IMPACT COVERAGE NOTES:**

THIS IMPACT STUDY SHOWS APPROXIMATE COVERAGE OF SPRINKLER HEADS. ACTUAL COVERAGE WILL VARY DEPENDING ON MANY FACTORS SUCH AS: BUT NOT LIMITED TO: TOTAL OPERATOR OF SYSTEM, AIRFLOW, SPRINKLER COVERAGE, WIND DIRECTION, PRO OPERATOR, SOIL TYPES, AND SEASON OF OPERATION. THIS STUDY IS TO BE USED FOR INFORMATIONAL PURPOSES ONLY AND COULD BE EFFECTED BY ONE OR ALL OF THE ABOVE FACTORS.



**LEGEND**

SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
●	TORO FLX34-338-1 (85) 1IN. ACME INLET TURF SPRINKLER, FULL CIRCLE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
●	TORO FLX34-358-1 (75) 1IN. ACME INLET TURF SPRINKLER, FULL CIRCLE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
○	TORO FLX35-348-1 (85) 1IN. ACME INLET TURF SPRINKLER, PART-CIRCLE AND FULL CIRCLE IN ONE, PRESSURE REGULATION AT 80PSI, SPIKE GUARD SOLENOID
○	TORO FLX35-378-1 (75) 1IN. ACME INLET TURF SPRINKLER, PART-CIRCLE AND FULL CIRCLE IN ONE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
⊗	TORO 474-44 QUICK COUPLER VALVE
⊕	CLOW/CMF ISOLATION VALVE W/HDPE EXTENSIONS 3" TO 12" CAST IRON GATE VALVE, LINE SIZED.
⊕	AQUAFUSE 360 DEGREE PE BALL VALVE - 2"
Ⓐ	BERMAD C30 (2) AIR/VACUUM RELIEF VALVE TO BE FIELD LOCATED BY IRRIGATION CONSULTANT
Ⓓ	DRAIN VALVE 3" - CLOW/CMF ISOLATION VALVE W/ HDPE EXTENSIONS
H# XX	EXISTING FIELD SATELLITE PROVIDE EXPANSIONS TO EXISTING STATION CONTROLLER
H# XX	HUNTER PILOT FIELD CONTROLLER PROVIDE EXPANSIONS TO EXISTING STATION CONTROLLER
P	EXISTING PUMP STATION - CONNECT INTO EXISTING
—	IRRIGATION LATERAL LINE: HDPE PE4710 DR 13.5
—	IRRIGATION MAINLINE: HDPE PE4710 DR 13.5

**REFERENCE NOTES SCHEDULE**

CODE	DESCRIPTION
1	TIE INTO EXISTING IRRIGATION MAINLINE. CONTRACTOR TO CONFIRM FINAL LOCATION TIE IN POINT.
2	CAP MAINLINE PIPING FOR FUTURE PHASE TIE IN POINTS.

**DESIGN NOTES**

- ALL PRODUCT APPLICATIONS AND INSTALLATIONS MUST MEET MANUFACTURER'S REQUIREMENTS.
- FLOW RATES THROUGH HDPE PIPING NOT TO EXCEED MANUFACTURER'S RECOMMENDATIONS.
- PIPING AS SHOWN IS DIAGRAMMATIC IN NATURE. ALL PIPING TO BE LOCATED WITHIN OWNER'S PROPERTY LINES.
- CONTRACTOR IS RESPONSIBLE FOR PROPER OPERATION OF IRRIGATION SYSTEM. SYSTEM SHALL NOT EXCEED MANUFACTURER'S RECOMMENDATIONS AND SHALL WATER ALL SEEDED AND SODDED AREAS NOTED. IRRIGATION PLAN IS INTENDED TO INCLUDE EVERYTHING NECESSARY TO THE PROPER OPERATION OF SAID IRRIGATION SYSTEM. IF ADJUSTMENTS ARE REQUIRED, CONTRACTOR SHALL MAKE ADJUSTMENTS FOR SAME.
- IRRIGATION PLANS SHALL HAVE PRECEDENCE OVER IRRIGATION SPECIFICATIONS. ANY DISCREPANCIES BETWEEN THESE TWO DOCUMENTS MUST BE BROUGHT TO THE ATTENTION OF THE IRRIGATION CONSULTANT BEFORE INSTALLATION.
- IT IS THE INTENT TO KEEP IRRIGATION WATER OFF OF ALL BUILDINGS, SIDEWALKS AND PARKING AREAS. IT WILL BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO FIELD TUNE EACH SPRINKLER AS TO KEEPING IRRIGATION ADJUSTED TO GRASSED AND SEEDDED AREAS ONLY. IT WILL ALSO BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO SUPPLY THE OWNER WITH AN OPERATING SCHEDULE THAT WORKS WITH EXISTING PLANS AND ANY FIELD ADJUSTMENTS.
- IT IS THE INTENT OF THE IRRIGATION DESIGN TO ACHIEVE HEAD TO HEAD COVERAGE IN ALL GRASSED AND SEEDDED AREAS. IT WILL BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO ADJUST FOR SAME.
- IRRIGATION PLANS ARE DIAGRAMMATIC IN NATURE CONTRACTOR WILL BE RESPONSIBLE FOR THE LOCATION OF ALL EQUIPMENT AS STAKED BY IRRIGATION CONSULTANT. SAID EQUIPMENT, WHEN FIELD LOCATED, MAY VARY FROM PROPOSED PLAN DUE TO SITE CONDITIONS AND CONTRACTOR WILL MAKE ADJUSTMENTS ACCORDINGLY AT NO ADDITIONAL COST TO OWNER.

**PLUMBING NOTES:**

- ALL HDPE FITTINGS SHALL BE FUSION COMPATIBLE AND HEAT FUSED WITH SPRINKLERS MOUNTED ON AQUAFUSE FUSIBLE SADDLES. NO BRAND MIXING ALLOWED AND CONTRACTOR/EQUIPMENT TO BE SITE CERTIFIED BY SUPPLIER AS SPECIFIED - NO EXCEPTIONS.
- ALL PIPE SHALL BE CARRIED IN SEPARATE TRENCH.

**ELECTRICAL NOTES:**

- ALL 120 V.A.C. POWER SPLICES AT FIELD SATELLITES.
- ALL POWER WIRE TAPS AND CONNECTIONS SHALL CONFORM TO ALL LOCAL AND STATE CODES AND PERFORMED BY LICENSED ELECTRICIAN.
- 24" LOOP OF WIRE LOCATED BELOW EACH HEAD.
- ALL 24 V.A.C. SECONDARY WIRING SHALL BE (RED) #14 HOT AND (WHITE) #12 COMMON. (ONE HOT WIRE PER HEAD)
- ALL WIRE SHALL HAVE ENOUGH SLACK AS TO ACCOMMODATE FOR EXPANSION AND/OR CONTRACTION.
- ALL WIRE TO BE UL APPROVED FOR DIRECT BURIAL.
- ALL 120 V.A.C. PRIMARY, AND 24 V.A.C. SECONDARY POWER TO BE INSTALLED AS PER STATE AND LOCAL CODES. SIZED AS PER PLAN WITH GROUND WIRE; MEETING N.E.C. REQUIREMENTS.
- TWO SPARE HOT (#14) WIRE TO EACH GREEN AND ONE SPARE HOT (#14) TO WIRE TO EACH TEE COMPLEX AND MARKED AS SPACE (BLUE IN COLOR).

**PROGRAMMING NOTES:**

- FIELD SATELLITES SHALL CARRY APPROPRIATE STATION CARDS FOR INDIVIDUAL HEAD CONTROL OF ALL SPRINKLERS.
- ALL SPRINKLERS SHALL HAVE ONE WIRE (HOT 24 V.A.C.) TO RESPECTIVE FIELD SATELLITE.
- ALL SATELLITE LOCATIONS SHALL BE IN ACCORDANCE WITH RAIN FALL SURVEYS AND OUT OF 100 YEAR FLOOD PLAN.



**NEWMAN GOLF COURSE**  
PEORIA, IL

REVISIONS:

1	
2	
3	
4	
5	
6	

DRAWING TITLE: **IMPACT COVERAGE**

SCALE:

DATE: **11/18/2025**

SHEET #: **LI-1**



**BASE SCOPE OF WORK** - - - - -

THE BASE BID SCOPE OF WORK TO INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION COMPONENTS AND ADDITIONAL CONTROLS FOR HOLES #3, #2, AND #9 AS OUTLINED IN THE ABOVE DRAWING. THIS INCLUDES, BUT NOT LIMITED TO, CONNECTING TO THE EXISTING MAINLINE INFRASTRUCTURE TO ALLOW WATER TO ALL EXISTING PORTIONS OF THE COURSE. REFER TO EXISTING DRAWINGS. CONTRACTOR SHALL CONFIRM FINAL TIE IN POINTS.

**ALTERNATE #1 OF WORK** - - - - -

ALTERNATE SCOPE OF WORK SHALL INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #7 AND #8 AS OUTLINED IN THE ABOVE DRAWINGS.


**ALTERNATE #2 OF WORK** - - - - -

ALTERNATE SCOPE OF WORK SHALL INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #6 AS OUTLINED IN THE ABOVE DRAWINGS.

**ALTERNATE #3 OF WORK** - - - - -

ALTERNATE SCOPE OF WORK SHALL INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #4 AND #5 AS OUTLINED IN THE ABOVE DRAWINGS.

**HYDRAULIC PIPING PLAN**  
SCALE: 1" = 100'-0"



**LEGEND**

SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
●	TORO FLX34-338-1 (65) 1IN. ACME INLET TURF SPRINKLER, FULL CIRCLE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
●	TORO FLX34-358-1 (75) 1IN. ACME INLET TURF SPRINKLER, FULL CIRCLE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
○	TORO FLX35-348-1 (65) 1IN. ACME INLET TURF SPRINKLER, PART-CIRCLE AND FULL-CIRCLE IN ONE, PRESSURE REGULATION AT 80PSI, SPIKE GUARD SOLENOID.
○	TORO FLX35-378-1 (75) 1IN. ACME INLET TURF SPRINKLER, PART-CIRCLE AND FULL-CIRCLE IN ONE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
■	TORO 474-44 QUICK COUPLER VALVE
⊗	CLOW/CMP ISOLATION VALVE W/HOPE EXTENSIONS 3" TO 12" CAST IRON GATE VALVE, LINE SIZED.
⊕	AQUAFUSE 980 DEGREE PE BALL VALVE - 2"
Ⓐ	BERMAD C30 (2) AIR/VACUUM RELIEF VALVE TO BE FIELD LOCATED BY IRRIGATION CONSULTANT
Ⓛ	DRAIN VALVE 3" - CLOW/CMP ISOLATION VALVE W/ HOPE EXTENSIONS
Ⓜ	EXISTING FIELD SATELLITE PROVIDE EXPANSIONS TO EXISTING STATION CONTROLLER
Ⓝ	HUNTER PILOT FIELD CONTROLLER PROVIDE EXPANSIONS TO EXISTING STATION CONTROLLER
Ⓟ	EXISTING PUMP STATION - CONNECT INTO EXISTING
—	IRRIGATION LATERAL LINE: HDPE PE4710 DR 13.5
—	IRRIGATION MAINLINE: HDPE PE4710 DR 13.5

NOTE: QUANTITIES SHOWN ARE FOR REFERENCE ONLY. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL QUANTITIES AND TAKE OFFS FROM A SCALED AERIAL.

**REFERENCE NOTES SCHEDULE**

CODE	DESCRIPTION
Ⓛ	TIE INTO EXISTING IRRIGATION MAINLINE. CONTRACTOR TO CONFIRM FINAL LOCATION TIE IN POINT.
Ⓜ	CAP MAINLINE PIPING FOR FUTURE PHASE TIE IN POINTS.

- DESIGN NOTES**
- ALL PRODUCT APPLICATIONS AND INSTALLATIONS MUST MEET MANUFACTURER'S REQUIREMENTS.
  - FLOW RATES THROUGH HDPE PIPING NOT TO EXCEED MANUFACTURER'S RECOMMENDATIONS.
  - PIPING AS SHOWN IS DIAGRAMMATIC IN NATURE. ALL PIPING TO BE LOCATED WITHIN OWNER'S PROPERTY LINES.
  - CONTRACTOR IS RESPONSIBLE FOR PROPER OPERATION OF IRRIGATION SYSTEM. SYSTEM SHALL NOT EXCEED MANUFACTURER'S RECOMMENDATIONS AND SHALL WATER ALL SEEDED AND SODDED AREAS NOTED. IRRIGATION PLAN IS INTENDED TO INCLUDE EVERYTHING NECESSARY TO THE PROPER OPERATION OF SAID IRRIGATION SYSTEM. IF ADJUSTMENTS ARE REQUIRED, CONTRACTOR SHALL MAKE ADJUSTMENTS FOR SAME.
  - IRRIGATION PLANS SHALL HAVE PRECEDENCE OVER IRRIGATION SPECIFICATIONS. ANY DISCREPANCIES BETWEEN THESE TWO DOCUMENTS MUST BE BROUGHT TO THE ATTENTION OF THE IRRIGATION CONSULTANT BEFORE INSTALLATION.
  - IT IS THE INTENT TO KEEP IRRIGATION WATER OFF OF ALL BUILDINGS, SIDEWALKS AND PARKING AREAS. IT WILL BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO FIELD TUNE EACH SPRINKLER AS TO KEEPING IRRIGATION ADJUSTED TO GRASSED AND SEEDS AREAS ONLY. IT WILL ALSO BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO SUPPLY THE OWNER WITH AN OPERATING SCHEDULE THAT WORKS WITH EXISTING PLANS AND ANY FIELD ADJUSTMENTS.
  - IT IS THE INTENT OF THE IRRIGATION DESIGN TO ACHIEVE HEAD TO HEAD COVERAGE IN ALL GRASSED AND SEEDS AREAS. IT WILL BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO ADJUST FOR SAME.
  - IRRIGATION PLANS ARE DIAGRAMMATIC IN NATURE CONTRACTOR WILL BE RESPONSIBLE FOR THE LOCATION OF ALL EQUIPMENT AS STAKED BY IRRIGATION CONSULTANT. SAID EQUIPMENT, WHEN FIELD LOCATED, MAY VARY FROM PROPOSED PLAN DUE TO SITE CONDITIONS AND CONTRACTOR WILL MAKE ADJUSTMENTS ACCORDINGLY AT NO ADDITIONAL COST TO OWNER.

**PLUMBING NOTES:**

- ALL HDPE FITTINGS SHALL BE FUSION COMPATIBLE AND HEAT FUSED WITH SPRINKLERS MOUNTED ON AQUAFUSE FUSIBLE SADDLES. NO BRAND MIXING ALLOWED AND CONTRACTOR EQUIPMENT TO BE SITE CERTIFIED BY SUPPLIER AS SPECIFIED - NO EXCEPTIONS.
- ALL PIPE SHALL BE CARRIED IN SEPARATE TRENCH.

**ELECTRICAL NOTES:**

- ALL 120 V.A.C. POWER SPLICES AT FIELD SATELLITES.
- ALL POWER WIRE TAPS AND CONNECTIONS SHALL CONFORM TO ALL LOCAL AND STATE CODES AND PERFORMED BY LICENSED ELECTRICIAN.
- 24" LOOP OF WIRE LOCATED BELOW EACH HEAD.
- ALL 24 V.A.C. SECONDARY WIRING SHALL BE (RED) #14 HOT AND (WHITE) #12 COMMON. (ONE HOT WIRE PER HEAD)
- ALL WIRE SHALL HAVE ENOUGH SLACK AS TO ACCOMMODATE FOR EXPANSION AND/OR CONTRACTION.
- ALL WIRE TO BE UL APPROVED FOR DIRECT BURIAL.
- ALL 120 V.A.C. PRIMARY, AND 24 V.A.C. SECONDARY POWER TO BE INSTALLED AS PER STATE AND LOCAL CODES. SIZED AS PER PLAN WITH GROUND WIRE; MEETING N.E.C. REQUIREMENTS.
- TWO SPARE HOT (#14) WIRE TO EACH GREEN AND ONE SPARE HOT (#14) TO WIRE TO EACH TEE COMPLEX AND MARKED AS SPACE (BLUE IN COLOR).

**PROGRAMMING NOTES:**

- FIELD SATELLITES SHALL CARRY APPROPRIATE STATION CARDS FOR INDIVIDUAL HEAD CONTROL OF ALL SPRINKLERS.
- ALL SPRINKLERS SHALL HAVE ONE WIRE (HOT 24 V.A.C.) TO RESPECTIVE FIELD SATELLITE.
- ALL SATELLITE LOCATIONS SHALL BE IN ACCORDANCE WITH RAIN FALL SURVEYS AND OUT OF 100 YEAR FLOOD PLAN.




**NEWMAN GOLF COURSE**  
PEORIA, IL

DRAWING TITLE: **HYDRAULIC PIPING PLAN**  
SCALE: \_\_\_\_\_

DATE: 11/18/2025

SHEET #: **LI-2**




**BASE SCOPE OF WORK** - - - - -  
 THE BASE BID SCOPE OF WORK TO INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION COMPONENTS AND ADDITIONAL CONTROLS FOR HOLES #3, #2, AND #9 AS OUTLINED IN THE ABOVE DRAWING. THIS INCLUDES, BUT NOT LIMITED TO, CONNECTING TO THE EXISTING MAINLINE INFRASTRUCTURE TO ALLOW WATER TO ALL EXISTING PORTIONS OF THE COURSE. REFER TO EXISTING DRAWINGS. CONTRACTOR SHALL CONFIRM FINAL TIE IN POINTS.

**ALTERNATE #1 OF WORK** - - - - -  
 ALTERNATE SCOPE OF WORK SHALL INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #7 AND #8 AS OUTLINED IN THE ABOVE DRAWINGS.

**ALTERNATE #2 OF WORK** - - - - -  
 ALTERNATE SCOPE OF WORK SHALL INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #6 AS OUTLINED IN THE ABOVE DRAWINGS.

**ALTERNATE #3 OF WORK** - - - - -  
 ALTERNATE SCOPE OF WORK SHALL INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #4 AND #5 AS OUTLINED IN THE ABOVE DRAWINGS.

**ELECTRICAL SCHEMATIC**  
 SCALE: 1" = 100'-0"



**LEGEND**

SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
●	TORO FLX34-338-1 (65) 1IN. ACME INLET TURF SPRINKLER, FULL CIRCLE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
●	TORO FLX34-358-1 (75) 1IN. ACME INLET TURF SPRINKLER, FULL CIRCLE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
○	TORO FLX35-348-1 (65) 1IN. ACME INLET TURF SPRINKLER, PART-CIRCLE AND FULL-CIRCLE IN ONE, PRESSURE REGULATION AT 80PSI, SPIKE GUARD SOLENOID.
○	TORO FLX35-378-1 (75) 1IN. ACME INLET TURF SPRINKLER, PART-CIRCLE AND FULL-CIRCLE IN ONE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
■	TORO 474-44 QUICK COUPLER VALVE
⊕	CLOW/CMP ISOLATION VALVE W/HOPE EXTENSIONS 3" TO 12" CAST IRON GATE VALVE, LINE SIZED.
⊕	AQUAFUSE 980 DEGREE PE BALL VALVE - 2"
⊕	BERMAD C30 (2) AIR/VACUUM RELIEF VALVE TO BE FIELD LOCATED BY IRRIGATION CONSULTANT
⊕	DRAIN VALVE 3" - CLOW/CMP ISOLATION VALVE W/ HOPE EXTENSIONS
⊕	EXISTING FIELD SATELLITE PROVIDE EXPANSIONS TO EXISTING STATION CONTROLLER
⊕	HUNTER PILOT FIELD CONTROLLER PROVIDE EXPANSIONS TO EXISTING STATION CONTROLLER
⊕	EXISTING PUMP STATION - CONNECT INTO EXISTING
—	IRRIGATION LATERAL LINE: HDPE PE4710 DR 13.5
—	IRRIGATION MAINLINE: HDPE PE4710 DR 13.5

NOTE: QUANTITIES SHOWN ARE FOR REFERENCE ONLY. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL QUANTITIES AND TAKE OFFS FROM A SCALED AERIAL.

**REFERENCE NOTES SCHEDULE**

CODE	DESCRIPTION
⊕	TIE INTO EXISTING IRRIGATION MAINLINE. CONTRACTOR TO CONFIRM FINAL LOCATION TIE IN POINT.
⊕	CAP MAINLINE PIPING FOR FUTURE PHASE TIE IN POINTS.

- DESIGN NOTES**
- ALL PRODUCT APPLICATIONS AND INSTALLATIONS MUST MEET MANUFACTURER'S REQUIREMENTS.
  - FLOW RATES THROUGH HDPE PIPING NOT TO EXCEED MANUFACTURER'S RECOMMENDATIONS.
  - PIPING AS SHOWN IS DIAGRAMMATIC IN NATURE. ALL PIPING TO BE LOCATED WITHIN OWNER'S PROPERTY LINES.
  - CONTRACTOR IS RESPONSIBLE FOR PROPER OPERATION OF IRRIGATION SYSTEM. SYSTEM SHALL NOT EXCEED MANUFACTURER'S RECOMMENDATIONS AND SHALL WATER ALL SEEDED AND SODDED AREAS NOTED. IRRIGATION PLAN IS INTENDED TO INCLUDE EVERYTHING NECESSARY TO THE PROPER OPERATION OF SAID IRRIGATION SYSTEM. IF ADJUSTMENTS ARE REQUIRED, CONTRACTOR SHALL MAKE ADJUSTMENTS FOR SAME.
  - IRRIGATION PLANS SHALL HAVE PRECEDENCE OVER IRRIGATION SPECIFICATIONS. ANY DISCREPANCIES BETWEEN THESE TWO DOCUMENTS MUST BE BROUGHT TO THE ATTENTION OF THE IRRIGATION CONSULTANT BEFORE INSTALLATION.
  - IT IS THE INTENT TO KEEP IRRIGATION WATER OFF OF ALL BUILDINGS, SIDEWALKS AND PARKING AREAS. IT WILL BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO FIELD TUNE EACH SPRINKLER AS TO KEEPING IRRIGATION ADJUSTED TO GRASSED AND SEEDED AREAS ONLY. IT WILL ALSO BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO SUPPLY THE OWNER WITH AN OPERATING SCHEDULE THAT WORKS WITH EXISTING PLANS AND ANY FIELD ADJUSTMENTS.
  - IT IS THE INTENT OF THE IRRIGATION DESIGN TO ACHIEVE HEAD TO HEAD COVERAGE IN ALL GRASSED AND SEEDED AREAS. IT WILL BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO ADJUST FOR SAME.
  - IRRIGATION PLANS ARE DIAGRAMMATIC IN NATURE. CONTRACTOR WILL BE RESPONSIBLE FOR THE LOCATION OF ALL EQUIPMENT AS STAKED BY IRRIGATION CONSULTANT. SAID EQUIPMENT, WHEN FIELD LOCATED, MAY VARY FROM PROPOSED PLAN DUE TO SITE CONDITIONS AND CONTRACTOR WILL MAKE ADJUSTMENTS ACCORDINGLY AT NO ADDITIONAL COST TO OWNER.

- PLUMBING NOTES:**
- ALL HDPE FITTINGS SHALL BE FUSION COMPATIBLE AND HEAT FUSED WITH SPRINKLERS MOUNTED ON AQUAFUSE FUSIBLE SADDLES. NO BRAND MIXING ALLOWED AND CONTRACTOR EQUIPMENT TO BE SITE CERTIFIED BY SUPPLIER AS SPECIFIED - NO EXCEPTIONS.
  - ALL PIPE SHALL BE CARRIED IN SEPARATE TRENCH.

- ELECTRICAL NOTES:**
- ALL 120 V.A.C. POWER SPLICES AT FIELD SATELLITES.
  - ALL POWER WIRE TAPS AND CONNECTIONS SHALL CONFORM TO ALL LOCAL AND STATE CODES AND PERFORMED BY LICENSED ELECTRICIAN.
  - 24" LOOP OF WIRE LOCATED BELOW EACH HEAD.
  - ALL 24 V.A.C. SECONDARY WIRING SHALL BE (RED) #14 HOT AND (WHITE) #12 COMMON. (ONE HOT WIRE PER HEAD)
  - ALL WIRE SHALL HAVE ENOUGH SLACK AS TO ACCOMMODATE FOR EXPANSION AND/OR CONTRACTION.
  - ALL WIRE TO BE UL APPROVED FOR DIRECT BURIAL.
  - ALL 120 V.A.C. PRIMARY, AND 24 V.A.C. SECONDARY POWER TO BE INSTALLED AS PER STATE AND LOCAL CODES. SIZED AS PER PLAN WITH GROUND WIRE; MEETING N.E.C. REQUIREMENTS.
  - TWO SPARE HOT (#14) WIRE TO EACH GREEN AND ONE SPARE HOT (#14) TO WIRE TO EACH TEE COMPLEX AND MARKED AS SPACE (BLUE IN COLOR).

- PROGRAMMING NOTES:**
- FIELD SATELLITES SHALL CARRY APPROPRIATE STATION CARDS FOR INDIVIDUAL HEAD CONTROL OF ALL SPRINKLERS.
  - ALL SPRINKLERS SHALL HAVE ONE WIRE (HOT 24 V.A.C.) TO RESPECTIVE FIELD SATELLITE.
  - ALL SATELLITE LOCATIONS SHALL BE IN ACCORDANCE WITH RAIN FALL SURVEYS AND OUT OF 100 YEAR FLOOD PLAIN.

**NEWNAM GOLF COURSE**  
PEORIA, IL


REVISIONS:

1	
2	
3	
4	
5	
6	

DRAWING TITLE: **ELECTRICAL SCHEMATIC**  
SCALE:

DATE: 11/18/2025

SHEET #: **LI-3**




**BASE SCOPE OF WORK** - - - - -  
 THE BASE BID SCOPE OF WORK TO INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION COMPONENTS AND ADDITIONAL CONTROLS FOR HOLES #3, #2, AND #9 AS OUTLINED IN THE ABOVE DRAWING. THIS INCLUDES, BUT NOT LIMITED TO, CONNECTING TO THE EXISTING MAINLINE INFRASTRUCTURE TO ALLOW WATER TO ALL EXISTING PORTIONS OF THE COURSE. REFER TO EXISTING DRAWINGS. CONTRACTOR SHALL CONFIRM FINAL TIE IN POINTS.

**ALTERNATE #1 OF WORK** - - - - -  
 ALTERNATE SCOPE OF WORK SHALL INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #7 AND #8 AS OUTLINED IN THE ABOVE DRAWINGS.

**ALTERNATE #2 OF WORK** - - - - -  
 ALTERNATE SCOPE OF WORK SHALL INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #6 AS OUTLINED IN THE ABOVE DRAWINGS.

**ALTERNATE #3 OF WORK** - - - - -  
 ALTERNATE SCOPE OF WORK SHALL INCLUDE: THE IRRIGATION MAINLINE, LATERALS, IRRIGATION CONTROLS, AND IRRIGATION COMPONENTS FOR HOLES #4 AND #5 AS OUTLINED IN THE ABOVE DRAWINGS.

**SITE IRRIGATION PLAN**  
 SCALE: 1" = 100'-0"



**LEGEND**

SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
●	TORO FLX34-338-1 (65) 1IN. ACME INLET TURF SPRINKLER, FULL CIRCLE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
●	TORO FLX34-358-1 (75) 1IN. ACME INLET TURF SPRINKLER, FULL CIRCLE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
○	TORO FLX35-348-1 (65) 1IN. ACME INLET TURF SPRINKLER, PART-CIRCLE AND FULL-CIRCLE IN ONE, PRESSURE REGULATION AT 80PSI, SPIKE GUARD SOLENOID.
○	TORO FLX35-378-1 (75) 1IN. ACME INLET TURF SPRINKLER, PART-CIRCLE AND FULL-CIRCLE IN ONE, PRESSURE REGULATION AT 80PSI, STANDARD SOLENOID
SYMBOL	MANUFACTURER/MODEL/DESCRIPTION
⊠	TORO 474-44 QUICK COUPLER VALVE
⊠	CLOW/CMP ISOLATION VALVE W/HOPE EXTENSIONS 3" TO 12" CAST IRON GATE VALVE, LINE SIZED.
⊕	AQUAFUSE 980 DEGREE PE BALL VALVE - 2"
Ⓐ	BERMAD C30 (2) AIR/VACUUM RELIEF VALVE TO BE FIELD LOCATED BY IRRIGATION CONSULTANT
Ⓛ	DRAIN VALVE 5" - CLOW/CMP ISOLATION VALVE W/ HOPE EXTENSIONS
Ⓜ	EXISTING FIELD SATELLITE PROVIDE EXPANSIONS TO EXISTING STATION CONTROLLER
Ⓝ	HUNTER PILOT FIELD CONTROLLER PROVIDE EXPANSIONS TO EXISTING STATION CONTROLLER
Ⓟ	EXISTING PUMP STATION - CONNECT INTO EXISTING
—	IRRIGATION LATERAL LINE: HDPE PE4710 DR 13.5
—	IRRIGATION MAINLINE: HDPE PE4710 DR 13.5

NOTE: QUANTITIES SHOWN ARE FOR REFERENCE ONLY. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL QUANTITIES AND TAKE OFFS FROM A SCALED AERIAL.

**REFERENCE NOTES SCHEDULE**

CODE	DESCRIPTION
Ⓛ	TIE INTO EXISTING IRRIGATION MAINLINE. CONTRACTOR TO CONFIRM FINAL LOCATION TIE IN POINT.
Ⓜ	CAP MAINLINE PIPING FOR FUTURE PHASE TIE IN POINTS.

- DESIGN NOTES**
- ALL PRODUCT APPLICATIONS AND INSTALLATIONS MUST MEET MANUFACTURER'S REQUIREMENTS.
  - FLOW RATES THROUGH HDPE PIPING NOT TO EXCEED MANUFACTURER'S RECOMMENDATIONS.
  - PIPING AS SHOWN IS DIAGRAMMATIC IN NATURE. ALL PIPING TO BE LOCATED WITHIN OWNER'S PROPERTY LINES.
  - CONTRACTOR IS RESPONSIBLE FOR PROPER OPERATION OF IRRIGATION SYSTEM. SYSTEM SHALL NOT EXCEED MANUFACTURER'S RECOMMENDATIONS AND SHALL WATER ALL SEEDED AND SODDED AREAS NOTED. IRRIGATION PLAN IS INTENDED TO INCLUDE EVERYTHING NECESSARY TO THE PROPER OPERATION OF SAID IRRIGATION SYSTEM. IF ADJUSTMENTS ARE REQUIRED, CONTRACTOR SHALL MAKE ADJUSTMENTS FOR SAME.
  - IRRIGATION PLANS SHALL HAVE PRECEDENCE OVER IRRIGATION SPECIFICATIONS. ANY DISCREPANCIES BETWEEN THESE TWO DOCUMENTS MUST BE BROUGHT TO THE ATTENTION OF THE IRRIGATION CONSULTANT BEFORE INSTALLATION.
  - IT IS THE INTENT TO KEEP IRRIGATION WATER OFF OF ALL BUILDINGS, SIDEWALKS AND PARKING AREAS. IT WILL BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO FIELD TUNE EACH SPRINKLER AS TO KEEPING IRRIGATION ADJUSTED TO GRASSED AND SEEDED AREAS ONLY. IT WILL ALSO BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO SUPPLY THE OWNER WITH AN OPERATING SCHEDULE THAT WORKS WITH EXISTING PLANS AND ANY FIELD ADJUSTMENTS.
  - IT IS THE INTENT OF THE IRRIGATION DESIGN TO ACHIEVE HEAD TO HEAD COVERAGE IN ALL GRASSED AND SEEDED AREAS. IT WILL BE THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO ADJUST FOR SAME.
  - IRRIGATION PLANS ARE DIAGRAMMATIC IN NATURE CONTRACTOR WILL BE RESPONSIBLE FOR THE LOCATION OF ALL EQUIPMENT AS STAKED BY IRRIGATION CONSULTANT. SAID EQUIPMENT, WHEN FIELD LOCATED, MAY VARY FROM PROPOSED PLAN DUE TO SITE CONDITIONS AND CONTRACTOR WILL MAKE ADJUSTMENTS ACCORDINGLY AT NO ADDITIONAL COST TO OWNER.

- PLUMBING NOTES:**
- ALL HDPE FITTINGS SHALL BE FUSION COMPATIBLE AND HEAT FUSED WITH SPRINKLERS MOUNTED ON AQUAFUSE FUSIBLE SADDLES. NO BRAND MIXING ALLOWED AND CONTRACTOR EQUIPMENT TO BE SITE CERTIFIED BY SUPPLIER AS SPECIFIED - NO EXCEPTIONS.
  - ALL PIPE SHALL BE CARRIED IN SEPARATE TRENCH.

- ELECTRICAL NOTES:**
- ALL 120 V.A.C. POWER SPLICES AT FIELD SATELLITES.
  - ALL POWER WIRE TAPS AND CONNECTIONS SHALL CONFORM TO ALL LOCAL AND STATE CODES AND PERFORMED BY LICENSED ELECTRICIAN.
  - 24" LOOP OF WIRE LOCATED BELOW EACH HEAD.
  - ALL 24 V.A.C. SECONDARY WIRING SHALL BE (RED) #14 HOT AND (WHITE) #12 COMMON. (ONE HOT WIRE PER HEAD)
  - ALL WIRE SHALL HAVE ENOUGH SLACK AS TO ACCOMMODATE FOR EXPANSION AND/OR CONTRACTION.
  - ALL WIRE TO BE UL APPROVED FOR DIRECT BURIAL.
  - ALL 120 V.A.C. PRIMARY, AND 24 V.A.C. SECONDARY POWER TO BE INSTALLED AS PER STATE AND LOCAL CODES. SIZED AS PER PLAN WITH GROUND WIRE. MEETING N.E.C. REQUIREMENTS.
  - TWO SPARE HOT (#14) WIRE TO EACH GREEN AND ONE SPARE HOT (#14) TO WIRE TO EACH TEE COMPLEX AND MARKED AS SPACE (BLUE IN COLOR).

- PROGRAMMING NOTES:**
- FIELD SATELLITES SHALL CARRY APPROPRIATE STATION CARDS FOR INDIVIDUAL HEAD CONTROL OF ALL SPRINKLERS.
  - ALL SPRINKLERS SHALL HAVE ONE WIRE (HOT 24 V.A.C.) TO RESPECTIVE FIELD SATELLITE.
  - ALL SATELLITE LOCATIONS SHALL BE IN ACCORDANCE WITH RAIN FALL SURVEYS AND OUT OF 100 YEAR FLOOD PLAIN.










**NEWMAN GOLF COURSE**  
PEORIA, IL

DRAWING TITLE: **SITE IRRIGATION PLAN**  
SCALE: \_\_\_\_\_

DATE: 11/18/2025

SHEET #: **LI-4**





REVISIONS DATE BY:

**NEWMAN GOLF COURSE IRRIGATION SYSTEM**  
**RAIN BIRD SYSTEM**

ELSON AND ASSOCIATES  
 LAND PLANNING CONSULTANTS  
 1500 N. UNIVERSITY AVE. SUITE 100  
 PEORIA, IL 61614 (309) 695-9400

RAIN BIRD SYSTEM

JOB NUMBER	
DRAWN BY:	APPROVED:
SCALE:	DATE:
SHEET	<b>11</b>

**RAIN BIRD SYSTEM BID PACKAGE "A"-R**  
 SYSTEM REQUIREMENTS AT 80 P.S.I. AT HEAD  
 GREENS AND TEES 432.0 G.P.M.  
 FAIRWAY "A" 512.8 G.P.M.  
 FAIRWAY "B" 512.8 G.P.M.

SATELLITE CONTROLLERS AS FOLLOWS:  
 GREENS AND TEES 0-P-Q-R-S-T-U-V  
 FAIRWAY "A" A-C-E-G-I-K-N  
 FAIRWAY "B" B-D-F-H-J-L-M

SATELLITES A-F-K-N HAVE 2 91 DR OPERATING AT SAME TIME  
 SYSTEM DESIGNED TO ALLOW EVERY NIGHT WATERING OF TEES AND GREENS AND EVERY OTHER NIGHT WATERING OF FAIRWAYS

**PPE SIZING**  
 PPE SIZES SHALL BE AS SHOWN OR AS DETERMINED, IN THE FIELD, AT THE TIME OF CONSTRUCTION. VELOCITIES SHALL NOT EXCEED 5 F.P.S.  
 PPE SIZES ARE CALCULATED ON TOTAL G.P.M. AT 80 P.S.I. AT THE HEAD AS FOLLOWS:

SPRINKLER	G.P.M.	NOZZLE
91 DR	64J	5/32" x 5/64" STD.
95 DR	64J	5/32" x 5/64" STD.
51 DR	27J	5/16" x 3/16"

FOR PPE SIZES NOT SHOWN, THE FOLLOWING SHALL APPLY:  
 SERVICE LINE TO 91 DR = 2 1/2"  
 SERVICE LINE TO TWO 51 DR = 2"  
 SERVICE LINE TO SINGLE 51 DR = 1 1/2"

- LEGEND**
- RAIN BIRD 91DR FULL CIRCLE ROTOR 190' SPACING
  - ▲ RAIN BIRD 90DR PART CIRCLE ROTOR 190' SPACING
  - ▲ RAIN BIRD 51DR FULL CIRCLE ROTOR 169' SPACING
  - ▲ RAIN BIRD MODEL SRC QUICK COUPLING VALVE
  - ISOLATION VALVE-2"-6" SAME SIZE AS LINE
  - SYSTEM PIPING-SIZE AS SHOWN
  - ⊕ MANUAL DRAIN VALVE
  - ⓐ ⓑ RAIN BIRD SBM-1230-SS SATELLITE CONTROLLER
  - △ RAIN BIRD MAXI SYSTEM IV COMPUTER CONTROL
  - COMMUNICATION CABLE-PAIGE No. P70720
  - EXISTING WATER MAINS-SIZE AS SHOWN
  - EXISTING CONTOUR-2FOOT INTERVAL
  - DRINKING FOUNTAIN-EXISTING AND PROPOSED

**IRRIGATION PLAN NOTES**  
 IRRIGATION LINES SHOWN ON THIS DRAWING ARE ESSENTIALLY DIAGRAMATIC. EXACT LOCATION OF ALL SPRINKLER HEADS, VALVES, PIPING, WIRING, ETC. SHALL BE ESTABLISHED BY THE CONTRACTOR AT THE TIME OF CONSTRUCTION. CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROPER INSTALLATION AND OPERATION OF THE SYSTEM AND SHALL VERIFY ALL PPE SIZES AND EQUIPMENT BEFORE STARTING ANY WORK.  
 CONTRACTOR SHALL STAKE LOCATION OF EACH RUN OF PPE, SPRINKLER HEADS, VALVES AND OTHER EQUIPMENT AND SHALL HAVE SUCH PLAN APPROVED BY THE OWNER'S REPRESENTATIVE BEFORE INSTALLATION OF THE WORK.  
 CONTRACTOR SHALL VERIFY THE LOCATION OF ALL EXISTING AND PROPOSED UTILITIES AND STRUCTURES. DAMAGE BY THIS CONTRACTOR TO ANY WORK SHALL BE REPAIRED OR REPLACED AT HIS EXPENSE.

