

Peoria Park District
Planning, Design and Construction Department
1314 N. Park Road
Peoria, IL 61604
Telephone: (309) 686-3386

ADDENDUM NO. 1
PROJECT TITLE: Network Cabling

ISSUANCE DATE:

LOCATION: RiverPlex Recreation & Wellness Center

The proposed Contract Documents for this Work are modified as follows:

I. GENERAL INFORMATION:

- There is no asbestos in this building and hazardous material removal should not be included in bidding.

II. DRAWINGS:

- a) NETWORK CABLING RIVERPLEX RECREATION & WELLNESS CENTER – FLOOR PLAN
- Remove existing floorplan and replace with attached “FLOOR PLAN – REV”
 - MDF Location was incorrectly labeled on drawings, see revised attached drawing.
 - Fire Separation walls identified in attached revised drawing.

III. PROJECT MANUAL/SPECIFICATIONS:

a) SUPPLEMENTARY INSTRUCTIONS TO BIDDERS:

- 2. PROJECT DESCRIPTION
A.1: In first sentence, delete “Cat6 and”.

b) DESIGN PROGRAM:

- All new networking cabling shall be CAT6A, plenum rated, manufactured by Panduit.
- Provide and install one (1) 6U Vertical Manager for rack.
- Floor penetration for cabling from second floor into new server room is the responsibility of the awarded contractor. Location to be determined following award.
- Proper support for running cabling above ceiling tiles is required, J-hooks are acceptable.
- Cabling run lengths for exterior cameras and specified access points may exceed 100 meters resulting in non-certification, pending Owner’s Representative approval.
- Terminate data jacks for APs and cameras to a faceplate when feasible with color coded keystones. Colors shall match across entire install (all data white, all cameras blue, etc.).
- Grounding and bonding of server rack is the responsibility of the contractor.


IV. INVITATION TO BID: N/A

END OF ADDENDUM NO. 1

Addendum No. 1
Page 1 of 1


GENERAL NOTES:

1. A PRE-BID MEETING WILL BE HELD AT 9:00AM ON MONDAY, JULY 6, 2026 AT THE RIVERPLEX.
2. ALL NEW CABLING WORK MUST BE COMPLETED BETWEEN AUGUST 16, 2026 AND AUGUST 29, 2026 BETWEEN THE HOURS OF 8:00PM AND 5:00AM ONLY.
3. FACILITY TO REMAIN IN CONTINUOUS AND UNINTERRUPTED OPERATION DURING THE WORK.
4. ALL WORK SHALL BE COMPLETED IN ACCORDANCE WITH NEC, BICSI, ANSI/TIA, MANUFACTURER'S RECOMMENDATIONS, CONTRACT DOCUMENTS, APPLICABLE CODES AND REGULATIONS, AND BEST INDUSTRY STANDARDS.
5. CONTRACTOR SHALL BE RESPONSIBLE FOR VISITING SITE TO VERIFY EXISTING CONDITIONS, DIMENSIONS AND QUANTITIES PRIOR TO BIDDING.
6. PROVIDE AND INSTALL NEW CAT6/CAT6A NETWORK CABLING, AS REQUIRED, FROM MDF TO LOCATIONS INDICATED ON FLOOR PLAN.
7. ALL ETHERNET PORT LOCATIONS SHALL BE EQUIPPED WITH 4EA (FOUR EACH) CAT6A CABLES.
8. AT EACH DESIGNATED ETHERNET PORT LOCATION, PROVIDE AND INSTALL NEW 4-PORT KEYSTONE JACKS AND WALL PLATES IN COLORS CONSISTENT WITH OTHER WALL PLATES IN THE ROOM OF INSTALLATION.
9. CONFIRM EXACT OUTLET LOCATIONS WITH OWNER PRIOR TO INSTALLATION.
10. PROVIDE AND INSTALL ONE (1) 4-POST SERVER RACK; STARTECH 4POSTRACK42 42U SERVER RACK OR EQUIVALENT.
11. PROVIDE AND INSTALL ELEVEN (11) 24-PORT PATCH PANELS; PANDUIT MINI COM CPPL24WBLY OR EQUIVALENT. INCLUDE COMPATIBLE KEYSTONE JACKS. ALLOW 1U GAP BETWEEN PATCH PANELS.
12. COORDINATE WITH OWNER'S IT DIRECTOR REGARDING MIGRATION ACTIVITIES.
13. ADD ALTERNATE #1: AFTER CUTOVER, DEMO ALL OLD CABLING BACK TO POINT OF ORIGIN.



First Floor - Layout

Known fire separation walls.



Second Floor - Layout

| NETWORK DROP SCHEDULE - 1ST FLOOR | |
|---|----------|
| TYPE | QUANTITY |
| ETHERNET PORTS [4EA CAT6A CABLES X 34 LOCATIONS] | 136 |
| ACCESS POINTS | 20 |
| BULLET CAMERAS | 15 |
| PTZ CAMERAS [EXTERIOR] | 4 |

| NETWORK DROP SCHEDULE - 2ND FLOOR | |
|--|----------|
| TYPE | QUANTITY |
| ETHERNET PORTS [4EA CAT6A CABLES X 8 LOCATIONS] | 32 |
| ACCESS POINTS | 3 |
| BULLET CAMERAS | 6 |
| PTZ CAMERAS | 1 |

**NETWORK CABLING
RIVERPLEX RECREATION &
WELLNESS CENTER**

PLEASURE DRIVEWAY AND PARK DISTRICT OF PEORIA, ILLINOIS



| FLOOR PLAN - REV | | | |
|------------------|----------------|---------------------|-------------|
| DRAWN BY: TMJ | SCALE: NONE | DATE: 06/30/2026 | SHEET: 1 |